J-C-580B
AMENDMENT-3
June 11, 1985
SUPERSEDING
INT. AMENDMENT-2
October 2, 1984
AMENDMENT-1
June 27, 1975

## FEDERAL SPECIFICATION

CORD, ELECTRICAL AND WIRE, ELECTRICAL (0- TO 600- VOLT SERVICE)

This amendment, which forms a part of J-C-580B, dated October 15, 1974, is approved by the Assistant Administrator, Office of Federal Supply and Services, General Services Administration, for the use of all Federal Agencies.

Page 1.

Paragraph 1.2.1, line 2, delete "table I" and substitute "tables I and II".

Paragraph 1.2.2, line 4, delete "J-C-580B" and substitute "J-C-580".

Paragraph 1.2.3, delete "J-C-580B" and substitute "J-C-580".

Page 2.

Paragraph 1.2.9, delete "A - asbestos " and "AV - asbestos-varnished-cloth insulated";

add "E - thermoplastic elastomer".

Paragraph 1.2.10, delete "AB - asbestos covering"; add new designations:

"EJ - Thermoplastic elastomer jacket CP - Chlorinated Polyethylene (CPE)

CF - Chlorosulfonated Polyethylene (CSPE)

NB - Nitrile-Butadiene/Polyvinyl Chloride (NBR/PVC)".

Page 3.
Paragraph 3.1.3, second line, delete "harard" and substitute "hazard".
Paragraph 3.2.2, second line, add after SPT-3 as follows: "SPE-1, SPE-2, SPE-3".

Page 6.
Table I, delete flexible cord types: "AFC, AFPO, AFPD, AFSJ, P-2, and PO".
add flexible cord types as follows:

J-C-580B

TYPE	AWG SIZE	NUMBER	AWG SIZE OF	VOLTAGE	TEMP.
•		OF	INDIVIDUÁL		DEGREES
		CONDUCTORS	STRANDS	·	CELSIUS
SPE-1	18	: .2 or 3	36-34	300	105
SPE-2	18–16	2 or 3	36-34	. 300 ·	105
SPE-3	18–12	2 w/opt. Grd	36-30	300	. 105
SVEO	18-17	2 w/opt. Grd	36-34	300	105
SVE	18-17	2 w/opt. Grd	36-34	300	105
SJEO	18-10	2-5 w/opt. Grd	##	· 300	105
SE0	18-2	2 or more	•	600	105
SJE	18 <b>–</b> 10	2-5 w/opt. Grd	<b>=</b>	300 ·	105
SE	18-2	2 or more	· •	600	105
SRDE	10-4	2-4 w/opt. Grd	36-20	<u>, 300</u>	105

Type HPN may be substituted for types AFC, AFPO, AFPD, and AFSJ for applications below 90 degrees C.

Types SJ, SJO, SJT, SJTO, delete "18-14" and substitute "18-10".

\*\* delete "16-14" and substitute "16-10".

For types SP-1, SPE-1, SP-2, SPE-2, SPT-1, SPT-2, SP-3, SPE-3, and SPT-3, a grounding conductor is permitted.

MILITARY INTEREST

CIVIL AGENCY COORDINATING ACTIVITIES:

**CUSTODIANS:** 

ARMY - CR

GSA - PCD DC GOVT - DCG DOT - ACO

PREPARING ACTIVITY:

GSA - FSS