

W-C-1094
CANCELLATION
September 13, 1985

FEDERAL SPECIFICATION

CONDUIT AND CONDUIT FITTINGS, PLASTIC, RIGID

This cancellation is approved by the Assistant Administrator, Office of Federal Supply and Services , General Services Administration.

Federal Specification W-C-1094A, dated 3 July 1975, has been superseded by Underwriters Laboratories Standards (UL) as follows:

UL 514B covers W-C-1094-Conduit fittings all types, classes 1 thru 3 and 6 thru 10.

UL 514C covers W-C-1094- all types, class 5 junction box and cover in plastic (PVC).

UL 651 covers W-C-1094-Rigid PVC Conduit, types I and II, class 4.

UL 651A covers W-C-1094-Rigid PVC Conduit and HDPE Conduit type III and class 4.

The above UL standards have been adopted by GSA – FSS and DOD.

FSC 5975