

INCH-POUND

MIL-HDBK-1001/5

28 FEBRUARY 1990

MILITARY HANDBOOK

ROOFING AND WATERPROOFING



NO DELIVERABLE DATA REQUIRED BY THIS DOCUMENT

AREA FACR

DISTRIBUTION STATEMENT A. APPROVED FOR PUBLIC RELEASE: DISTRIBUTION IS UNLIMITED

MIL-HDBK-1001/5

THIS PAGE INTENTIONALLY LEFT BLANK

MIL-HDBK-1001/5

ABSTRACT

This military handbook covers many aspects of roof design and construction, beginning with the structural deck, choice of insulation, vapor control, many different systems of surfacing, and guidelines for plaza and below-grade waterproofing.

MIL-HDBK-1001/5

THIS PAGE INTENTIONALLY LEFT BLANK

MIL-HDBK-1001/5

FOREWORD

This handbook has been developed from an evaluation of facilities in the shore establishment, from surveys of the availability of new materials and construction methods, and from selection of the best design practices of the Naval Facilities Engineering Command, other Government agencies, and the private sector. This handbook was prepared using, to the maximum extent feasible, national professional society, association, and institute standards. Deviations from these criteria cannot be made without prior approval of NAVFACENGCOM HQ (Code 04).

Design cannot remain static any more than can the functions it serves or the technologies it uses. Accordingly, recommendations for improvement are encouraged and should be furnished to Commanding Officer, Chesapeake Division, Naval Facilities Engineering Command, Code 406C, Washington Navy Yard, Washington, DC 20374-2121; telephone (202) 433-3314.

THIS HANDBOOK SHALL NOT BE USED AS A REFERENCE DOCUMENT FOR PROCUREMENT OF FACILITIES CONSTRUCTION. IT IS TO BE USED IN THE PURCHASE OF FACILITIES ENGINEERING STUDIES AND DESIGN (FINAL PLANS, SPECIFICATIONS, AND COST ESTIMATES). DO NOT REFERENCE IT IN MILITARY OR FEDERAL SPECIFICATIONS OR OTHER PROCUREMENT DOCUMENTS.

MIL-HDBK-1001/5**ARCHITECTURAL CRITERIA MANUALS**

<u>CRITERIA MANUAL</u>	<u>TITLE</u>	<u>PA</u>
DM-1.01	Basic Architectural Requirements and Design Considerations	LANTDIV
MIL-HDBK-1001/2	Materials and Building Components	LANTDIV
DM-1.03	Architectural Acoustics	LANTIDV
DM-1.4	Earth-Sheltered Buildings (Textbook)	HDQTRS
MIL-HDBK-1001/5	Roofing and Waterproofing	CHESDIV

MIL-HDBK-1001/5

ROOFING AND WATERPROOFING

CONTENTS

		<u>Page</u>
Section 1	INTRODUCTION	
1.1	Scope	1
1.2	Roof Design Synthesis	1
1.3	Roof Designer	1
1.4	Design	1
1.5	Roof-Mounted Equipment	1
1.6	Climatic Conditions	2
1.6.1	Solar Radiation	2
1.6.2	Windspeed	2
Section 2	STRUCTURAL DECK	
2.1	Functions	3
2.2	Materials	3
2.3	Design Factors	3
2.3.1	Drainage	3
2.3.2	Deflections	4
2.3.3	Dimensional Stability	4
2.3.4	Deck Surface	4
2.3.5	Expansion Joints	4
2.3.6	Roof Assemblies	5
2.4	Specific Roof Decks	5
2.4.1	Precautions	5
2.4.2	Steel Roof Decks	5
2.4.3	Reinforced Concrete Roof Decks	5
2.4.4	Precast Concrete Panel Roof Decks	5
2.4.4.1	Description	5
2.4.4.2	Precautions	5
2.4.5	Prestressed Precast Concrete Roof Decks	6
2.4.5.1	Description	6
2.4.5.2	Precautions	6
2.4.6	Wood Board or Plywood Roof Decks	6
2.4.6.1	Description	6
2.4.6.2	Requirements	6
2.4.7	Cement-Wood Fiber Panel Roof Decks	6
2.4.7.1	Description	6
2.4.7.2	Requirements	7
2.4.7.3	Precautions	7
2.4.7.4	Roof Membrane Anchorage	7
2.4.8	Poured Gypsum Concrete Roof Decks	7
2.4.8.1	Description	7
2.4.8.2	Precautions	7
2.4.9	Lightweight Insulating Concrete Fills	8
2.4.9.1	Description	8
2.4.9.2	Precautions	8
Section 3	THERMAL INSULATION	
3.1	Thermal Resistance	9

MIL-HDBK-1001/5

	<u>Page</u>
3.1.1 Purposes for Insulation	9
3.1.2 Design Criteria	9
3.1.2.1 Documents	9
3.1.2.2 Variations	9
3.1.3 Evaluation	9
3.1.3.1 ASHRAE Methods	9
3.1.3.2 Life Cycle Cost	9
3.1.3.3 Important Considerations	10
3.1.4 Selection	10
3.1.5 Roof Color	10
3.1.6 Location	10
3.2 Materials	10
3.2.1 Board Insulation	10
3.2.2 Single Component Insulation	10
3.2.3 Composite Board Insulation	10
3.2.4 Insulating Concrete	10
3.2.5 Sprayed Plastic Foam	10
3.2.6 Properties	10
3.2.7 Application Criteria	11
3.3 Design Factors	11
3.3.1 Compressive Strength	11
3.3.2 Moisture Absorption	11
3.3.3 Dimensional Stability	11
3.3.3.1 Temperature	11
3.3.3.2 Moisture	11
3.3.3.3 Dimensional Compatibility	12
3.3.4 Compatibility	12
3.3.5 Thickness	12
3.3.5.1 Layering	12
3.3.5.2 Contractor Options	12
3.3.6 Anchorage	12
3.4 Tapered Insulation	12
Section 4 VAPOR CONTROL	
4.1 Psychrometrics	13
4.1.1 Vapor Pressures and Flow	13
4.1.1.1 Indoor	13
4.1.1.2 Outdoor	13
4.1.1.3 Design Criteria	13
4.1.2 Dewpoint	13
4.1.3 Influence on Roof	13
4.2 Control Methods	14
4.2.1 Vapor Resistance	14
4.2.1.1 Materials	14
4.2.1.2 Calculations	14
4.2.2 Vapor Retarders	14
4.2.2.1 Materials	14
4.2.2.2 Location	14
4.2.2.3 Application	14
4.2.3 Ventilation	15
4.2.3.1 Below Insulation	15
4.2.3.2 Above Insulation	15

MIL-HDBK-1001/5

		<u>Page</u>
Section 5	BITUMINOUS BUILT-UP ROOF MEMBRANE	
5.1	Material Description	17
5.1.1	Bitumen	17
5.1.2	Felts	17
5.1.3	Surfacing	17
5.2	General Requirements	17
5.2.1	Felts	17
5.2.2	Modified Bitumen Flashing	17
5.2.3	Compatibility	17
5.3	Membrane Design Recommendations	17
5.3.1	Equiviscous Temperature (EVT)	18
5.4	Flashings	18
5.4.1	Flashing Functions	18
5.4.2	Materials	18
5.4.2.1	Base Flashings	18
5.4.2.2	Counterflashings	18
5.4.3	Flashing Design Principles	18
5.4.3.1	Differential Movement	19
5.4.3.2	Contour Flashings	19
5.4.4	General Requirements for Flashings	19
5.4.4.1	Materials	19
5.5	Foot Traffic	19
5.6	Details	19
Section 6	SINGLE-PLY ROOFING SYSTEMS	
6.1	Single-Ply Defined	21
6.1.1	Single-Ply Materials	21
6.1.1.1	Elastomeric Sheets	21
6.1.1.2	Plasticized Thermoplastic Sheets	21
6.1.1.3	Uncured Elastomers	22
6.1.1.4	Modified Bitumens	22
6.1.2	Liquid-Applied Coatings	23
6.1.2.1	Uses	23
6.1.2.2	Advantages	23
6.1.2.3	Disadvantages	23
6.2	Perimeter Anchorage	23
6.3	Single-Ply Membrane Standards	23
6.4	General Design Recommendations	24
6.4.1	New Roofs	24
6.5	Basic Information Required for New Construction	25
6.5.1	Geographical Location, Climatic Conditions at Project Site	25
6.5.2	Roof Deck	25
6.5.3	Special Occupancy Factors	25
6.5.4	Roof Insulation	25
6.5.5	Roof Joints	25
6.5.6	Special Requirements	26
6.5.7	Temporary Roof	26
6.5.8	Roof Deck Treatment/Preparation	26
6.5.9	Vapor Retarder	26
6.5.10	Roof Insulation	26
6.6	Modified Bituminous Roofing Membranes	27

MIL-HDBK-1001/5

		<u>Page</u>
6.7	Thermoplastic Roofing Membranes	27
6.8	Elastomeric Roofing Membranes	27
6.9	Quality Control	28
6.10	Flashings, Cant Strips, Incorporation of Metal Flashings, Drainage Fitting Treatment	28
6.10.1	Related Sheet Metal Work	28
6.11	Applicable Details	28
Section 7	SPRAYED POLYURETHANE FOAM	
7.1	Material Description	29
7.2	Uses	29
7.3	Disadvantages	29
7.4	Design Recommendations	30
7.4.1	Wind-Uplift Resistance	30
7.4.2	Fire Rating	30
7.4.3	Vapor Retarder	30
7.4.4	Foam Thickness and Slope	30
7.4.5	Control Joints	30
7.4.6	Membrane Coatings	31
7.4.7	Flashings	31
7.5	Applicable Details	31
Section 8	PROTECTED MEMBRANE ROOF SYSTEM	
8.1	Description	33
8.2	General Design Recommendations	33
8.2.1	Structural Capacity	33
8.2.2	Slope	33
8.2.3	Water-Test	33
8.2.4	Climate	33
8.3	Specific Design Recommendations	34
8.3.1	Drainage	34
8.3.2	Protection Board	35
8.3.3	Percolation Course	35
8.3.4	Flashings	35
8.4	Variations	35
8.5	Other Considerations	35
8.5.1	Single-ply or Liquid Membrane	35
8.5.2	Expansion Joint	35
8.5.3	Flashings	35
8.5.4	Water Test	35
8.5.5	Interior Gutter	35
8.6	Applicable Details	35
Section 9	STEEP ROOFING	
9.1	Steep Roofing Description	37
9.2	Materials	37
9.3	General Design Requirements	37
9.3.1	Slopes	37
9.3.2	Decks	37
9.4	Underlayments	37
9.4.1	Underlayments for Steep Roofing	37

MIL-HDBK-1001/5

		<u>Page</u>
9.4.2	Underlayment for Wood Shake, Clay Tile, and Concrete Tile Roofs	39
9.5	Ventilation	39
9.5.1	Paths	39
9.5.2	Vents	39
9.6	Anchorage Techniques	40
9.6.1	Fasteners	40
9.6.2	Anchorage	40
9.6.3	Hurricane or High-wind Zones	40
9.7	Flashings	40
9.8	Applicable Details	40
Section 10	REROOFING	
10.1	Introduction	43
10.2	Basic Design Decision	43
10.2.1	Reroofing	43
10.3	Design	43
10.3.1	Drainage	43
10.4	Premature Failure Preliminary Investigation	44
10.4.1	Structural Influence	44
10.4.2	Interior Space Conditions	44
10.4.3	Topside Deficiencies	44
10.5	Considerations	44
10.5.1	The Insulation System	45
10.5.1.1	Tapered Insulation	45
10.5.2	Membrane System	45
10.6	Surfacing	46
10.6.1	Smooth-Surfaced Roofs	46
10.6.2	Aggregate-Surfaced Roofs	46
10.6.3	Coatings	46
10.6.3.1	Emulsions	46
10.6.3.2	Cutbacks	47
10.6.4	Ponding	47
10.7	Foot Traffic	47
10.8	Cold-Process Roofing	47
Section 11	FIRE RESISTANCE	
11.1	General	49
11.2	External Fire Resistance	49
11.2.1	Membranes	49
11.2.2	Tests	49
11.2.3	Ratings	49
11.3	Internal Fire Hazards	49
11.3.1	Background Research	49
11.3.2	Safeguard	49
11.3.3	Steel Deck	49
11.4	Time-Temperature Ratings	49
11.4.1	Temperature	50
11.4.2	Fire-endurance Test	50
11.4.3	Steel	50
11.5	Design Requirements	50

MIL-HDBK-1001/5

		Page
Section 12	WIND-UPLIFT RESISTANCE	
12.1	Wind-Uplift Hazards	51
12.1.2	Resistance	51
12.2	Failure	51
12.3	Ballasted Systems	51
12.4	Dead Load	51
12.5	Mechanical Fasteners	52
12.6	Design Data	52
Section 13	BELOW-GRADE WATERPROOFING	
13.1	Material Description	53
13.2	Uses	53
13.3	General Requirements	53
13.3.1	Substrates	53
13.3.2	Masonry	53
13.3.3	Membrane	53
13.3.4	Protection	53
13.3.5	Subterranean Space	53
13.3.6	Drain Tile	53
13.4	Design Requirements	53
13.4.1	Slope	54
13.4.2	Walls	54
13.4.3	Expansion Joints	54
13.4.4	Membrane Selection	54
13.5	Dampproofing	55
13.6	Applicable Details	55
Section 14	PLAZA WATERPROOFING	
14.1	System Description	57
14.2	Uses	57
14.3	Planters	57
14.4	General Requirements	57
14.4.1	Minimum Slope	57
14.4.2	Joint Construction	57
14.4.3	Vapor Retarder	57
14.4.4	Insulation	57
14.4.5	Waterproofing Termination	58
14.4.6	Flashings	58
14.4.7	Percolation Course	58
14.4.8	Filter Fabric	58
14.4.9	Pavers	58
14.4.10	Drains	58
14.4.11	Protection Boards	58
14.4.12	Testing	58
14.4.13	Overflow Drains	58
14.4.14	Interior Gutters	58
14.5	Applicable Details	58

MIL-HDBK-1001/5

TABLES

		<u>Page</u>
Table	1	Membrane Adaptability to Different Roof Systems
	2	Steep Roofing Slopes
	3	Fasteners for Steep Roofings
	4	Steep Roofing Flashing Guide
BIBLIOGRAPHY		59
REFERENCES		65
GLOSSARY		71

MIL-HDBK-1001/5

THIS PAGE INTENTIONALLY LEFT BLANK

MIL-HDBK-1001/5

Section 1: INTRODUCTION

1.1 Scope. This handbook sets forth guidelines for design of roofing and waterproofing systems. It includes low-slope and steep roof systems, design of new roof systems, and reroofing of existing buildings.

1.2 Roof Design Synthesis. Roof-system design requires a synthesis of the following design factors:

- a) Suitably firm and stable platform for roofing;
- b) Slope for drainage;
- c) Fire resistance (Refer to MIL-HDBK-1008, Fire Protection for Facilities Engineering, Design, and Construction);
- d) Wind-uplift resistance;
- e) Thermal resistance;
- f) Vapor control;
- g) Life-cycle costing of available systems;
- h) Ice dams and sliding snow.

1.3 Roof Designer. The roof designer should confer with his technical consultants. The structural engineer should be consulted on the first four items of the foregoing list (deck, slope, fire resistance and wind-uplift resistance), and the mechanical/electrical engineer should be consulted on the next two items (thermal resistance, vapor control), as well as location and support of rooftop equipment (HVAC condensers, mechanical vents, etc.).

1.4 Design. Design of roofing systems requires a constant balancing of advantages against disadvantages. This requirement is illustrated by the conflict between fire ratings and insulating efficiency. Thickening the insulation of a fire rated roof-ceiling assembly beneficially reduces heat loss through the assembly, but it raises ceiling-space temperature. This increased space temperature could reduce the roof assembly's time-temperature fire rating, e.g. buckling steel joists or accelerating the burning of other combustible structural members.

1.5 Roof-Mounted Equipment. Rooftop location of mechanical and electrical equipment should be avoided whenever practicable. Penthouses and covered ground level locations are preferred. Rooftop equipment creates many roofing problems:

- a) Difficult flashing details;
- b) Obstruction of drainage paths;
- c) Increases in hazardous roof top traffic by repairmen;

MIL-HDBK-1001/5

- d) Accelerated corrosion;
- e) Weathering of the equipment itself;
- f) Potential vibration annoyance.

1.6 Climatic Conditions. Varying climatic conditions have a big impact on roofing design. Vapor retarders are usually needed in cold climates and for buildings with high interior relative humidity. In warm, humid climates, however, -- e.g. Hawaii and Guam -- vapor flows downward through the roof toward an air-conditioned interior. Placing a vapor retarder on the deck and below the insulation is harmful in a tropical climate. It prevents the beneficial venting of water vapor to the interior, entrapping it in the roof sandwich where it may condense and wet the insulation (refer to Section 4).

This difference in predominant vapor-flow direction may influence the proper choice of roof system: conventional assembly with insulation sandwiched between the deck below and membrane above, or a Protected Membrane Roof (PMR) assembly, with membrane and insulation positions reversed: i.e., with insulation above the membrane. In a cold climate where the predominant vapor-flow direction is upward from a heated interior, the membrane in a PMR doubles as a vapor retarder. This is an efficient arrangement. In a humid tropical climate, however, where the predominant vapor-flow direction is downward, the conventional roof assembly's position with the membrane above the insulation may be more efficient, with the membrane again functioning both as waterproofing and vapor retarder.

1.6.1 Solar Radiation. Solar radiation embrittles asphaltic materials and thermoplastic sheets, which may lose plasticizer under combined heat and sunlight. Shielding of the membrane and flashings is thus important, with aggregate, mineral granules, or heat-reflective coatings required on various membranes, both to increase membrane service life and to cut cooling-energy costs.

1.6.2 Windspeed. Windspeed has an impact on roof design apart from the obvious requirement of better anchorage (or heavier ballast) in high-wind areas. "Windstripping" of aggregate-surfaced built-up bituminous membranes has been noted in such diverse locations as Guam and Grand Forks, ND.

MIL-HDBK-1001/5

Section 2: STRUCTURAL DECK

2.1 Functions. The structural deck serves two functions:

- a) For structural resistance to gravity, wind and seismic forces;
- b) As substrate for the roof system.

2.2 Materials. Structural decks come in a wide variety of materials, notably the following:

- a) Lightgage steel;
- b) Reinforced concrete;
- c) Precast concrete;
- d) Prestressed, precast concrete;
- e) Wood plank and plywood;
- f) Cement-wood fiber;
- g) Poured gypsum concrete;
- h) Lightweight insulating concrete.

2.3 Design Factors. Structural decks must be designed with consideration of the following design factors:

- a) Slope for drainage;
- b) Dimensional stability;
- c) Moisture absorption;
- d) Anchorage (for wind-uplift resistance);
- e) Deck surface and joints;
- f) Expansion joints.

2.3.1 Drainage. In new construction, slope for drainage should be provided in the structural deck, when practicable, with minimum slope of 1/2 inch per foot (12.7 mm per m) for Navy projects and 1/4 inch per foot (6.35 mm per m) for Army projects. Provide saddles or crickets in valleys and other locations requiring additional drainage-promoting techniques. Locate drains at low points -- i.e., at center of simple spans and other locations of maximum vertical deflection. Where provision of slope in the structural deck is impracticable specify tapered (sloped) insulation to provide slope. The choice between interior or exterior drains depends upon building size and configuration and local climate. Favor interior drains in cold climates where subfreezing temperatures may create drain-blocking ice in exterior drains.

MIL-HDBK-1001/5

Interior drains may, however, require insulation (to prevent condensation). Design the primary drainage system to accommodate the rainfalls listed in DM-3.01, Plumbing Systems.

Where the roof is bounded with perimeter parapets, design a scupper system as secondary drainage, with bottom scupper elevations designed to limit ponding depth to a structurally safe depth in case the primary drains are clogged. Design perimeter scupper drains by the same criteria as the primary drain system, by the "contracted-weir" formula.

$$\text{EQUATION:} \quad Q \text{ (ft}^3\text{/min.)} = 200(b - 0.2H) H^{1.5} \quad (1)$$

where

b = scupper width (feet)

H = hydraulic head (feet), assumed 2-inch maximum depth

Total scupper cross-sectional area shall be a minimum 3 times the cross-sectional area of the primary vertical drains, with minimum individual 3-inch scupper depth and minimum width/depth ratio of 2.5.

2.3.2 Deflections. Deflections maintained within normal limits (refer to para. 2.4.4.2) will have no practical effect on drainage on a roof surface with the minimum roof slope.

2.3.3 Dimensional Stability. Dimensional stability of a deck material depends upon two factors: (1) Coefficient of thermal expansion; and (2) dimensional change with changing moisture content. These factors vary greatly in different materials. Steel's dimensional stability depends totally on thermal expansion and contraction. By contrast, plywood's dimensional stability depends primarily on moisture content, which varies with relative humidity. As an intermediate material, concrete's dimensional stability depends on both temperature and moisture content.

2.3.4 Deck Surface. As working surfaces for application of insulation or built-up roofing, cast-in-place decks have the advantage over prefabricated decks (e.g. steel, precast concrete) in providing large deck areas without joints. Jointed decks have two liabilities:

a) They create elevation breaks or horizontal gaps in the substrate;

b) They may permit bitumen dripage into the space below.

Methods for leveling, smoothing and covering joint gaps are noted under specific deck materials, which will be discussed in subsequent parts of this section.

2.3.5 Expansion Joints. Roof expansion joints, coincident with building expansion joints, are recommended at the following locations:

a) Junctures between changes in deck material (e.g. from steel to concrete);

MIL-HDBK-1001/5

- b) Junctures between changes in span direction of the same deck material;
- c) Junctures between an existing building and later addition;
- d) Deck intersections with nonbearing walls or wherever the deck can move relative to the abutting wall, curb or other building component;
- e) Maximum spacings of 200 to 300 feet (61 to 91 m);
- f) Junctures in an H, L, E, U, or T-shaped building.

Expansion joints should be located at high points, with drainage directed away from them. They should allow for relative movement in three directions, vertical, transverse, and longitudinal, detailed for minimum 8-inch (203.2 mm), maximum 12-inch (304.8 mm) curb height, with base and counterflashing.

2.3.6 Roof Assemblies. Roof assemblies shall be designed to satisfy established fire ratings, and Factory Mutual (FM) or Underwriters Laboratories, Inc., (UL) requirements. (Refer to Section 11.)

2.4 Specific Roof Decks

2.4.1 Precautions

- a) If the building is expected to have high interior moisture, refer to Section 4 and consult deck material manufacturer for recommendations;
- b) Wood blocking around openings and drains must be installed before insulation and roofing is installed.

2.4.2 Steel Roof Decks. Design steel roof decks to conform with specifications of the Steel Deck Institute and FM. Welds should be coated with zinc-rich paint. Special steel deck rust inhibitive coatings may be required in high moisture areas. Calculate dew point.

2.4.3 Reinforced Concrete Roof Decks. A smooth, flat surface should be achieved by screeding and troweling. The surface should be finished to a texture equivalent to either a light "power-trowel" finish or a firm wood trowel finish.

2.4.4 Precast Concrete Panel Roof Decks

2.4.4.1 Description. Precast concrete roof deck panels are manufactured in the following cross-sectional shapes: plain slabs, channel slabs, tongue-and-groove planks, single or double tees.

2.4.4.2 Precautions

- a) Camber differentials that exceed 1/8 inch (3.175 mm) must be corrected by using a Portland cement fill or grout, feathered to a maximum slope of 1/8 inch per foot (3.175 mm per m);

MIL-HDBK-1001/5

b) Damaged precast concrete panels should be repaired by the decking contractor to ensure structural integrity;

c) To prevent bitumen drippage, joints should either be stripped in with tape or grouted with cement fillings where openings occur.

2.4.5 Prestressed Precast Concrete Roof Decks

2.4.5.1 Description. Prestressed concrete units are manufactured tees, double tees, channel slabs or hollow-core slabs. Prestressing generally results in camber (i.e., upward deflection, raising the center of the span above the supports).

2.4.5.2 Precautions. If rigid insulation is used, differentials in adjacent prestressed concrete units must be corrected by fill or grout, feathered to a maximum slope of 1/8 inch per foot (3.175 mm per m).

2.4.6 Wood Board or Plywood Roof Decks

2.4.6.1 Description

a) Wood Board Roof Decks - Minimum 1 inch (25.4 mm) (nominal) thickness seasoned lumber, normally supported by wood joists or purlins, 2 inches (50.8 mm) thick;

b) Plywood Roof Decks - Panels kiln-dried, minimum 5/8 inch (15.875 mm) thick, normally supported by wood joists or purlins.

2.4.6.2 Requirements

a) Structural - Wood board roof deck material should be sound, well seasoned lumber of tongue-and-groove construction, splined together at side joints and aligned at joints to provide adequate bearing support at each end. All boards should be attached to all intermediate supports. There must be a minimum of one intermediate support.

b) Plywood roof deck material should comply with the standards set forth in Department of Commerce Standard PS 1. Plywood panels should bear the APA or TECO trademark, graded C-D or better, provide a smooth surface, minimum 5/8 inch (15.875 mm) thick. Plywood deck panels should be installed with face grain perpendicular to supports.

c) For all wood decks, a barrier of rosin sized sheathing paper or similar material should be placed between the roof membrane and the deck to allow relative movement.

d) For wood board and plywood roof decks a building should be heated in gradual steps after roofing is completed to prevent rapid moisture content changes that could warp the wood.

2.4.7 Cement-Wood Fiber Panel Roof Decks

2.4.7.1 Description. Cement-wood fiber roof deck panels are composed of treated wood fibers bonded with Portland cement or other binder and compressed

MIL-HDBK-1001/5

or molded into flat panels. Furnished either as tongue-and-groove planks for application direct to joists or as rabbeted panels for use with sub-purlins, these deck units provide acoustical and thermal insulation.

2.4.7.2 Requirements

a) Manufacturer's specifications should be consulted for installation. Special attention should be given to erection and handling instructions.

b) Resistance to wind uplift and lateral movement is provided by one of the following anchorage techniques: (1) Clips, nails, or other devices anchoring the deck directly to the roof framing; or (2) Sub-purlins anchored to the roof framing system. Voids around tees should be grouted with material recommended by the deck manufacturer.

2.4.7.3 Precautions. Because of the vulnerability to moisture, insects, and in some cases fire, these panels may be prohibited by some Military Construction Offices. Request specific permission to use before specifying.

2.4.7.4 Roof Membrane Anchorage. Approved mechanical fasteners should be used for anchorage of the roof membrane to the deck. The anchorage recommendations of the manufacturer and insurance rating agencies should be followed. Above-deck insulation board should be solid-mopped to a mechanically anchored coated base sheet. Insulation may also be mechanically anchored if provided in two layers (e.g. bottom anchored, top set in hot bitumen).

2.4.8 Poured Gypsum Concrete Roof Decks

2.4.8.1 Description. Mixture of gypsum concrete reinforced with welded or woven galvanized wire fabric and mixed with either wood fibers or mineral aggregate, and water. It is poured on permanent formboards supported on steel sub-purlins. Various formboards are available to provide light reflectance and fire resistance, insulation, and acoustical control. Density varies from 30 to 55 pounds per cubic foot (480 to 881 kg/m³).

2.4.8.2 Precautions

a) When insulation requirements and thicknesses permit, insulation is generally incorporated in the formboards. This type of construction should be avoided where upward vapor drive is present as it does not lend itself to incorporation of a vapor retarder. A vapor retarder should be considered when specifications require the installation of additional insulation on the top side of the deck. Because of the difficulties in applying a vapor retarder, however, poured gypsum should be avoided where upward vapor flow is predominant.

b) The ceiling plenum should be adequately ventilated to the exterior or supplied with dehumidified air to prevent moisture buildup.

c) Consult manufacturer's instructions before painting formboard. Paint may prevent drying of the poured gypsum.

MIL-HDBK-1001/5

2.4.9 Lightweight Insulating Concrete Fills

2.4.9.1 Description. A lightweight insulating concrete roof deck is a cementitious roof deck insulation and roofing substrate. It is produced by combining lightweight insulating aggregates (such as perlite or vermiculite) with Portland cement and water or by blending pregenerated foam with Portland cement and water.

Depending upon the design mix, the cured insulating concrete should have an oven-dry density between 20 and 40 pounds per cubic foot (320 to 640 kg³) and attain a compressive strength between 100 and 500 psi (689 and 3,447 kilo Pascal (kPa)).

2.4.9.2 Precautions

a) To promote drying of the wet mix, lightweight insulating concrete should be limited to decks with underside venting: slotted, galvanized steel decks (minimum 1.5 percent open area) or permeable formboards (e.g. fiberglass).

b) Do not specify lightweight insulating concrete over highly humidified interiors, i.e., swimming pools, process plants, etc.

c) Use caution if specifying in climates subject to subfreezing temperatures. Prohibit casting of concrete fill if subfreezing temperatures are reported imminent.

d) Do not use over concrete decks. The material must dry to the interior space.

e) Where high thermal resistance is required, additional, specially designed, closed cell insulation should be incorporated into the concrete. The practice of installing additional preformed insulation boards directly upon the deck is not recommended because it inhibits the drying of the concrete fill by solar radiation.

f) Stored deck material should be placed on raised skids or platforms and protected from the weather.

g) Ceiling plenum must either be adequately vented to the exterior or supplied with dehumidified air to prevent moisture buildup.

h) Underlayment: Nail a "venting" base sheet, conforming to the American Society for Testing and Materials (ASTM) D 3672, Standard Specification for Venting Asphalt-Saturated and Coated Inorganic Felt Base Used in Roofing, with approved fasteners.

MIL-HDBK-1001/5

Section 3: THERMAL INSULATION

3.1 Thermal Resistance. The thermal resistance of roof insulation has a very substantial impact on the long term operating cost and comfort in a building.

3.1.1 Purposes for Insulation. There are several purposes for using roof insulation as follows:

- a) Reduce heating and cooling equipment capacity.
- b) Reduce heating and cooling energy use. The level of roof insulation thermal resistance has a significant impact on the quantity of energy used for heating and/or cooling throughout the life of the building.
- c) Occupant comfort.
- d) Condensation control.
- e) Provide smooth substrate for roofing membrane.
- f) Provide slope to flat roof decks.

3.1.2 Design Criteria. Roof insulation thermal resistance or R-value is determined by the application of design criteria and analysis of life cycle cost.

3.1.2.1 Documents. The 1985 American Society of Heating, Refrigerating and Air Conditioning Engineers (ASHRAE) 1985 Handbook - Fundamentals, Chapter 20, contains a discussion on economic insulation thickness for building envelopes.

3.1.2.2 Variations. High levels of thermal resistance are not always life cycle cost effective, especially in buildings having long hours of operation and internal heat gains. Refer to the discussion on "Buildings With Dominant Internal Loads" in Chapter 20 Errata of the ASHRAE 1985 Handbook - Fundamentals. Where these conditions exist, lower levels of thermal resistance may well be justifiable.

3.1.3 Evaluation. An energy evaluation shall be conducted for each building to determine if the roof insulation thermal resistance should be higher or lower than set forth above.

3.1.3.1 ASHRAE Methods. Chapter 28 of the ASHRAE 1985 Handbook - Fundamentals, provides a number of methods for estimating energy consumption associated with roof insulation. Hour by hour, detailed computer simulation methods are preferred. At least three levels of thermal resistance should be evaluated for the roof over each type of space in each building.

3.1.3.2 Life Cycle Cost. Economic evaluation of roof insulation shall be carried out in accordance with NAVFAC P-442, Economic Analysis Handbook, TM 5-802-1, Life Cycle Cost Analysis Handbook, or equivalent.

MIL-HDBK-1001/5

3.1.3.3 Important Considerations. Where some space heating is accomplished by means of heat recovery, or where some space cooling is accomplished by free cooling methods such as economy cycle, or cooling tower, or cooling resulting in lower purchased energy requirements, lower levels of thermal resistance can be justified on a life cycle cost basis. Where energy is expensive, higher levels can be justified.

3.1.4 Selection. Selection of the level of thermal resistance to use in roof insulation shall be based on a life cycle cost analysis.

Each area of a building may vary. The level of thermal resistance for each area of the building does not necessarily have to be the same throughout. Quite often, areas with long hours of operation and high internal heat gains will require less insulation than areas with little or no internal heat gain and/or short hours of operation. Compensate for reductions in R-value due to fasteners and structural members.

3.1.5 Roof Color. Roof surface color has an impact on energy consumption and membrane temperature and color shall be considered in the evaluation of energy and life cycle cost, and when determining the suitability of the roof membrane.

3.1.6 Location. Roof insulation can be located either above or below the roof deck. In low slope roof buildings, above deck insulation is preferred.

3.2 Materials. A wide variety of insulation materials are available for use as roof insulation in buildings. Each material usually has a unique set of properties and compatibility with other roofing components which must be properly evaluated so that the roof will perform satisfactorily.

3.2.1 Board Insulation

3.2.2 Single Component Insulation

3.2.3 Composite Board Insulation. In order to provide compatibility with certain types of roofing materials and also to provide the desired fire rating, composite board insulation is available, consisting of two or more pre-assembled layers of differing insulation materials. Use of composite board insulation often allows application criteria and thermal resistance criteria to be met with minimum insulation thickness.

3.2.4 Insulating Concrete. Several types of lightweight insulating concrete are available for roof insulation purposes. They are typically installed over ventilated roof decks or formboard on low slope roofs, since it is possible to slope the concrete in order to provide roof drainage. Concrete must be able to exhaust original mixing water to the interior space.

3.2.5 Sprayed Plastic Foam. Sprayed-in-place plastic polyurethane foam insulation is available for roof insulation. Refer to Section 7.

3.2.6 Properties. Physical property data are usually available from the insulation manufacturer and often consist of testing laboratory reports. Care should be taken that the data reported are appropriate for the conditions under which the roof will perform. Physical property data are also published

MIL-HDBK-1001/5

in the ASHRAE 1985 Handbook - Fundamentals, and the Manual of Built-up Roof Systems by Griffin. Where data reported by insulation manufacturers differs from that shown in handbooks, appropriate justification and explanation should be obtained. Where the thermal resistance declines with age, the aged values shall be used.

3.2.7 Application Criteria. It is extremely important that the type or types of insulation to be used are appropriate for the roof assembly. Refer to other sections in this handbook for specific criteria with each type of roof deck and/or roof membrane.

Carefully read and evaluate the detailed application criteria and limitations on use for several major manufacturers of the type of insulation to be utilized or permitted along with other sections of this handbook, in order to eliminate any incompatibility.

Specific provisions should be set forth for the insulation manufacturer and contractor to meet to set up requirements regarding storage and installation of insulation. The insulation must be kept dry, both when stored on the job site and when installed on the roof. Waterproof covering over stored insulation is essential, as is elevating the insulation so that ground water cannot enter. Require that stored material be adequately secured from blowing away. Newly installed insulation must be covered at the completion of each day's work with completed roofing.

3.3 Design Factors. A number of physical properties and application criteria must be considered in the design of each roof. Evaluation of these factors should consider the entire range of conditions that the roof assembly will be exposed to, including the extremes.

3.3.1 Compressive Strength. Consider the likely extent of roof traffic (including construction traffic) and insulation type and thickness.

3.3.2 Moisture Absorption. Where roof insulation is used in humidified buildings or in areas with large vapor pressure differentials, it is likely that moisture will accumulate in the insulation, even with the use of vapor retarders (refer to Section 4). Moisture absorption reduces the thermal resistance of insulation so that when it is probable that moisture will accumulate, the types of insulation material to be utilized should be those which have the least capability to absorb moisture.

3.3.3 Dimensional Stability

3.3.3.1 Temperature. Sufficient expansion joints should be provided in order to accommodate changes in dimension due to temperature. The temperature range should consider the annual extremes. During colder weather, clear sky radiation can result in roof temperatures lower than design temperatures. As a result of solar radiation, and depending upon roof color, roof temperatures in excess of 150 degrees Fahrenheit (F) (66 degrees Celsius (C)) can be reached. Temperature ranges of more than 100 degrees F (37.7 degrees C) can be experienced in a single day.

3.3.3.2 Moisture. Provisions for expansion and contraction of roof insulation due to changes in moisture content should be made in the same

MIL-HDBK-1001/5

manner as for temperature changes. Depending upon the type of insulation material utilized, the change in dimension due to moisture can exceed that due to temperature.

3.3.3.3 Dimensional Compatibility. Adequate provisions for changes in dimension should consider both the range of temperatures to be encountered and the likely range in moisture content, with the maximum of either being utilized to determine the necessary dimensions. In addition, the dimensional stability of the insulation relative to the other materials in the roof assembly, such as the roof membrane and roof deck, should be considered. Where the change in dimension due to temperature varies considerably between the insulation and some other component of the roof assembly, provision should be made to accommodate this differential change in dimension.

3.3.4 Compatibility. It is important to establish the physical compatibility between the insulation and other components of the roof assembly. When using unfaced plastic foam insulation under built-up roofing, specify an additional top layer of wood fiber, fiber glass, or perlite insulation to guard against membrane blistering.

3.3.5 Thickness. With the high thermal resistance and low U-values commonly used for roof insulation, the thickness of insulation can be a substantial consideration in roof design. Drawings shall allow adequate space for insulation and show required thermal resistance or R-value of insulation.

3.3.5.1 Layering. When board type insulation is used, it is often necessary and preferred to have multiple layers. The insulation boards should be as large as can be practically handled and the joints should be staggered and offset between layers. Proper type and length fasteners should be used and consideration given to possible lateral movement of the roof insulation. Layering will reduce fastener heat transfer when the bottom layer is mechanically fastened.

3.3.5.2 Contractor Options. Where the overall roof thermal resistance or conductance is specified and the contractor is given the option to install more than one type of insulation material, the limitations on thickness and compatibility should be clearly set forth. The design should account for variations in insulation thickness which are likely to occur, making provision for parapets, flashing, curbs, wood blocking, and treatment of slope to roof drains.

3.3.6 Anchorage. Means for securing the roof insulation to the roof deck, such as adhesives and/or corrosive resistant mechanical fasteners, which are compatible with the materials used, should be specified. Refer to Section 9.

3.4 Tapered Insulation. Where the roof deck is flat or level, one reasonable means available for providing adequate roof slope for drainage purposes is by using the insulation; tapered factory fabricated insulation may be used for this purpose. Manufacturers of several types of board insulation provide a variety of tapers. Where tapered insulation is to be used, careful detailing and dimensioning is necessary in order to ensure that the proper slope and positive drainage are achieved. The use of tapered insulation should be limited to reroofing of existing low slope roof buildings.

MIL-HDBK-1001/5

Section 4: VAPOR CONTROL

4.1 Psychrometrics. The design of roofing must take into account the principles of moisture in air in order to preclude condensation of moisture in roof insulation and under roof surfaces. The subject of psychrometrics deals with determination of the properties of moist air and utilization of these properties in analysis of conditions and processes involving moist air. A much more detailed discussion and tables of moist air properties are included in ASHRAE 1985 Handbook - Fundamentals, Chapter 6.

4.1.1 Vapor Pressures and Flow. In order to determine the magnitude and direction of water vapor flow, it is necessary to examine the range of indoor and outdoor conditions that will exist over the course of the year. Moisture vapor flows from regions of higher vapor pressure to regions of lower vapor pressure.

4.1.1.1 Indoor. Indoor water vapor pressure is increased by the liberation of original moisture in construction materials and occupants, as well as moisture generated by plants, processes and humidification. This tends to make the indoor vapor pressure higher than outdoor, causing the potential for flow of water vapor through the roof in cold weather. When indoor space is air conditioned, including dehumidification, it is possible for the indoor vapor pressure to be lower than outdoors.

4.1.1.2 Outdoor. Outdoor vapor pressure is continuously varying throughout the year in any given location. When outdoor vapor pressure is higher than indoor vapor pressure, there will be a tendency for vapor to flow from outdoors to indoors through the roof.

4.1.1.3 Design Criteria. NAVFAC P-89 Engineering Weather Data, (also designated TM 5-785 and AFM 88-29) shows outdoor design conditions for most locations throughout the world. Once indoor design conditions are established, the vapor pressure differential between indoor and outdoor can be readily determined. It is essential to examine the variations in indoor and outdoor vapor pressures throughout an entire typical year of building operation in order to establish both the magnitude and direction of potential water vapor flow under all conditions of operation.

4.1.2 Dewpoint. An analysis shall be conducted to determine the potential for condensation to take place throughout all conditions of operation, both within the roof itself and on the surfaces of the roofing assembly. Such an analysis will determine the need to consider increasing the thermal resistance of insulation and/or incorporating specific methods for controlling vapor flow. Refer to ASHRAE 1985 Handbook - Fundamentals, Chapter 21.

4.1.3 Influence on Roof. Moisture condensation in the roof can result in reductions in insulation thermal resistance and dripping of condensed water from the underside of the roof. The dew point analysis shall consider all potential condensation possibilities in order to provide proper control measures to preclude condensation. Generally, these control measures include

MIL-HDBK-1001/5

insulation, ventilation, and vapor retarders. The analysis shall consider not only design conditions of temperature and vapor pressure, but also diurnal and seasonal variations.

4.2 Control Methods. A variety of methods exist for controlling vapor in buildings and are generally set forth in ASHRAE 1985 Handbook - Fundamentals, Chapter 20.

4.2.1 Vapor Resistance. All building materials have some degree of resistance to vapor flow. A table of values for most building materials is included in ASHRAE 1985 Handbook - Fundamentals, Chapter 21, along with calculation methods to determine the magnitude of vapor flow and location of condensation planes.

4.2.1.1 Materials. It is generally accepted that any material to be used as a vapor retarder shall have a maximum rating of 1 perm (57 metric perms). Selection of the perm rating required for any given conditions shall be based on the analyses described above. Generally, when there are large vapor pressure differentials for long hours, vapor retarder materials having very low perm ratings are required in order to minimize the quantity of moisture flowing into the roof. Where moisture flow into the roof will not be substantial or not exist for long periods of time, materials having higher perm ratings can be used.

4.2.1.2 Calculations. Calculations for vapor flow shall be made in accordance with ASHRAE 1985 Handbook - Fundamentals, Chapter 21. Special consideration shall be given to those situations where vapor flow is continuous in the same direction for long periods of time, due to the large potential for moisture accumulation.

4.2.2 Vapor Retarders. Once the need for vapor retarders has been established, it is necessary to consider the types of materials to be used, their location and manner of application.

4.2.2.1 Materials. Water vapor retarders may be classified as rigid, flexible, or coating types of materials. The suitability of the materials chosen shall be examined in order to ensure long term performance and compatibility with other roofing materials. Most often used vapor retarders are the flexible type, including plastic films and coated krafts and felts. These materials are available in a wide variety of perm ratings.

4.2.2.2 Location. With moisture flow out of the building, the vapor retarder shall be located as close as possible to the inside surface of the building envelope, most often on the top of the roof deck or adjacent to the inside finished surface of the ceiling. Where moisture flow is into the building, the proper location for the vapor retarder is as close as possible to the outdoor surface of the roof. Most often, the roofing membrane provides adequate vapor resistance for the flow into the building. Where vapor flow is both into and out of the building, the general preference for vapor retarder location is close to the indoor surface, or none at all.

4.2.2.3 Application. Where vapor retarders are to be used, the design shall pay particular attention to the manner of installing and sealing the vapor retarder material. The design shall also consider the potential for

MIL-HDBK-1001/5

damage to the integrity of the vapor retarder both during construction and operation of the building.

4.2.3 Ventilation. To the extent that some moisture does accumulate in the insulation, it is possible to allow escape of the moisture by providing means for ventilation. In the case of wood frame residential type construction with attics, a variety of methods are commonly available to allow moisture which passes through the ceiling insulation to escape to the atmosphere. With low slope roof construction, where accumulations of moisture are expected in the insulation, other methods for ventilation are required. This approach can be called a self-drying system.

4.2.3.1 Below Insulation. Using boards or sheets with perforations or slots underneath low slope roof deck insulation will allow moisture to escape, provided numerous paths are readily available underneath the entire surface of the insulation and those paths are complete to the outdoors or indoors. Use caution when the space below has high humidity.

4.2.3.2 Above Insulation. Ventilation above the insulation in low slope roof decks can be accomplished either by using edge vents or top vents in rare or extreme cases. Vents which penetrate the membrane will increase the potential for leaks. Top vents, if used, should be spread uniformly throughout the roof area. Use caution when applying ventilation above or below insulation, because the same paths that allow moisture to escape will also allow moisture to enter if the vapor pressure differential is reversed. Top venting should not be used over insulation having limited moisture movement capability, such as plastic foams.

MIL-HDBK-1001/5

THIS PAGE INTENTIONALLY LEFT BLANK

MIL-HDBK-1001/5

Section 5: BITUMINOUS BUILT-UP ROOF MEMBRANE

5.1 Material Description. As the weatherproofing component of a built-up roof system, the built-up bituminous membrane comprises three elements: bitumen, felts, and surfacing.

5.1.1 Bitumen. Bitumen resists water penetration in both interply adhesive films mopped between felt layers and the bituminous surface-coating or flood coat. Contemporary bitumens come in three types: (1) blown (i.e. oxidized) asphalts; (2) coal tar pitch; and (3) rubberized asphalts, blended with elastomeric polymers to increase the natural asphalt's low-temperature flexibility and ductility.

5.1.2 Felts. Felts stabilize and reinforce the membrane, like steel reinforcement in a concrete slab. Felts also prevent excessive bitumen flow when the bitumen is warm and semi-fluid and distribute contractive tensile stress when the bitumen is cold and glasslike. Felt plies separate the interply bitumen moppings and provide the membrane's multiple lines of waterproofing defense.

5.1.3 Surfacing. Surfacing of built-up membranes comprises one of three basic types: mineral aggregate, asphalt (hot or cold-applied), or mineral-surfaced cap sheet.

5.2 General Requirements

5.2.1 Felts. Organic and asbestos felts are highly vulnerable to moisture-induced deterioration; use the more durable fiber glass felts. Organic felts can, however, be used in temporary membranes that are to be removed; in coal-tar pitch membranes; and as edge envelopes, where their lack of "memory" makes them suitable.

5.2.2 Modified Bitumen Flashing. Single-ply modified bitumen flashings are now the prime choice for flashing material.

5.2.3 Compatibility. Check with the manufacturer of built-up roofing membrane and flashing materials to assure that proposed roof system and materials are compatible with roof deck, vapor retarder, insulation and geographic location.

5.3 Membrane Design Recommendations

BITUMEN SLOPE LIMITS

<u>SLOPE</u> <u>(inches per foot)</u>	<u>BITUMEN TYPE</u>	<u>SOFTENING POINT</u> <u>(degrees F)</u>
1/2 or less	Asphalt, ASTM D 312, Type I	135 - 151
1/2 to 1-1/2	Asphalt, ASTM D 312, Type II	158 - 176
1 to 3	Asphalt, ASTM D 312, Type III	185 - 205
Steep and flashings	Asphalt, ASTM D 312, Type IV	205 - 225
1/4 or less	Coal Tar Pitch, ASTM D 450 Type I	126 - 140
1/2 or less	Coal Tar Pitch, ASTM D 450 Type III	133 - 147

MIL-HDBK-1001/5

5.3.1 Equiviscous Temperature (EVT). Require bitumen manufacturer to provide EVT stenciled on every bitumen container or tanker weight bill to facilitate application at proper viscosity (100-150 centistokes (0.004 to 0.005 m)).

For coal-tar pitch membranes, specify coal-tar impregnated glass fiber felts, or ASTM D 227, Standard Specification for Coal-Tar Saturated Organic Felt Used in Roofing and Waterproofing, or ASTM D 2178, Standard Specification for Asphalt Glass Felt Used in Roofing and Waterproofing, Type IV.

5.4 Flashings

5.4.1 Flashing Functions. Flashings seal the joints where the membrane is interrupted or terminated. Base flashings, essentially a continuation of the membrane, form the edges of an (ideally) watertight tray. Counterflashings shield or seal the exposed joints of base flashings.

5.4.2 Materials

5.4.2.1 Base Flashings. Since the virtual disappearance of reinforced asbestos base flashing materials in 1984, recommended materials are the following:

- a) One-ply modified bitumen sheets, 160 to 200 mils (0.004 to 0.005 m) thick, normally reinforced with polyester or glass fibers.
- b) Three-ply glass-fiber felt (sometimes reinforced and granular surfaced).
- c) Metal base flashings should be restricted insofar as practicable to vent-pipe seals, gravel-stop flanges, and drain flashings, where there are no practicable alternatives. Use bituminous base flashings, i.e., modified bitumens or glass fiber flashing felts, at parapets, walls, expansion joints, and curb framing access hatches, vents, or equipment openings.

5.4.2.2 Counterflashings. Counterflashings (sometimes called "cap flashings") are usually made of metal: aluminum, galvanized steel, stainless steel, copper, or lead sheets designed to shield exposed base flashing joints and shed water from vertical or slanting surfaces onto the roof. Compatible fasteners must be used to anchor metal counterflashing to prevent electrochemical corrosion.

5.4.3 Flashing Design Principles. Good flashing layout and design require the following:

- a) Elimination of as many penetrations as practicable;
- b) Location of individual roof penetrations at least 18 inches (457.2 mm) apart;
- c) Consolidation of as many openings as possible into a smaller number of larger openings;

MIL-HDBK-1001/5

- d) Location of flashed joints above the highest water level on the roof, with drainage away from flashed joints;
- e) Allowance for differential movement between base and counterflashing;
- f) Firm connection of flashings to solid supports;
- g) Contouring of bituminous base flashings with cants to avoid sharp bends;
- h) Avoidance of surface-applied cap flashings.

5.4.3.1 Differential Movement. Flashing details must provide for differential movement among the different parts of the building. Anchor base flashings to the structural roof deck, free of the walls or other intersecting elements. Anchor the counterflashing to the wall, column, pipe or other flashed building component. Review detailing carefully.

5.4.3.2 Contour Flashings. With built-up flashing materials, use cants with 45 degree slope. Cants may not be required for some modified bitumen flashings.

Wood cants (southern yellow pine, Douglas fir, or equivalent), pressure-treated with water-base preservatives, may be preferable to fiberboard cants, especially where they brace the right-angle joint between vertical and horizontal nailers at equipment or wall curbs. Avoid fiberboard cants for torch-applied modified-bitumen flashing.

5.4.4 General Requirements for Flashings

5.4.4.1 Materials. Check with roofing materials manufacturer for approval of all flashing details and materials including primers, bitumens, felts, surfaced cap sheets, bituminous mastic for use with flashing details, and application techniques. Avoid pitch pockets always in new construction and whenever possible in reroofing. When required, fill pitch pans with a crowned pourable sealer.

5.5 Foot Traffic. Refer to para. 10.7.

5.6 Details. For details on flashings, anchorage, felt laps, requirements on felt backnailing, all metal work, and application of built-up membranes to various substrates, refer to the National Roofing Contractors' Association (NRCA) Roofing and Waterproofing Manual, and Sheet Metal and Air Conditioning Contractors National Association (SMACNA) Architectural Sheet Metal Manual.

MIL-HDBK-1001/5

THIS PAGE INTENTIONALLY LEFT BLANK

MIL-HDBK-1001/5

Section 6: SINGLE-PLY ROOFING SYSTEMS

6.1 Single-Ply Defined. A membrane, sheet or liquid-applied, with only a single layer of material designed to resist water penetration.

6.1.1 Single-Ply Materials. Chemically, sheet-applied membranes can be classified as one of the following categories: elastomers (synthetic rubber), plasticized thermoplastic polymers, uncured elastomers, and/or modified bitumens. (Refer to Table 1 for membrane adaptability to different roof systems.)

6.1.1.1 Elastomeric Sheets. The most important elastomeric sheets are ethylene propylene diene monomer (EPDM) and neoprene (polychloroprene).

Even though it is more expensive than EPDM, neoprene has several advantages:

- a) superior resistance to chemical attack,
- b) superior external fire resistance,
- c) heat-reflective coatings, and
- d) easier adhesions for maintenance repairs.

Fire-retardant grades of EPDM are, however, superior to neoprene in repairability and weather resistance.

Field lap seams are the most vulnerable component in elastomeric systems. Thermosetting polymers, both EPDM and neoprene require use of contact adhesives. These contact adhesives generally require thorough cleaning with solvent-soaked rags, a waiting period for the contact adhesive to attain proper consistency, thorough pressure-sealing of the lap, and application of a side lap sealant for temporary protection while the contact adhesive cures. Defective contact-adhered seams made in elastomeric membranes are vulnerable to rainwater ponding, especially when frozen. Over a long period of time, water intrusion impairs the performance of neoprene-based contact adhesives. Newer, non-neoprene-based adhesives are significantly less vulnerable to moisture intrusion.

6.1.1.2 Plasticized Thermoplastic Sheets. Plasticized thermoplastic sheets are represented by PVC membrane sheets, in both reinforced and unreinforced sheets.

PVC sheet offers comparatively easy field-seaming of watertight lap joints by means of its solvent-welded or heat-welded lap seams. These seams, true fusions of base and jointing material, make a watertight joint.

A major liability of PVC sheet membranes is that they may become embrittled and shrink from loss of plasticizer. Unreinforced, they have an extremely high coefficient of thermal contraction-expansion. However, reinforcement (woven fiberglass mat or polyester reinforcement) can vastly improve dimensional stability.

MIL-HDBK-1001/5

Table 1
Membrane Adaptability to Different Roof Systems

MEMBRANE MATERIAL	LOOSE-LAID BALLASTED	ADHERED	ANCHORED MECHANICALLY FASTENED	
			BAR TYPE	INDIVIDUAL
Elastomeric, PVC,				
Uncured elastomeric sheets	Yes	Yes	Yes	Yes
Liquid-applied Coating	No	Yes	No	No
Modified-bitumen sheets	Yes ¹	Yes	No ²	Yes
Conventional Built-up Roof	No	Yes	No	Yes ³

¹Limited to a few products, "No" for the majority.

²Underlayment sheet is mechanically fastened; membrane is adhered to underlayment sheet by means of torch or asphalt mopping.

³Base sheet only.

Note: Select membrane systems which are currently covered by COE and/or NAVFAC Guide Specifications.

6.1.1.3 Uncured Elastomers. Uncured elastomers are chemically intermediate between the thermosetting (i.e., elastomeric) and thermoplastic polymers. The single-ply membranes containing these intermediate polymers are CPE (chlorinated polyethylene), CSPE (chlorosulfonated polyethylene, known commercially as Hypalon), and PIB (polyisobutylene). Their lap seams can be heat-or adhesive-bonded. A major disadvantage is that they lack the abrasion resistance of vulcanized rubber. Major advantages are: (1) easier field-forming of reliable lap seams; (2) may cure or vulcanize over a period of time and become thermosets.

6.1.1.4 Modified Bitumens. Modified bitumens are essentially rubberized asphalts. The addition of rubber to the asphalt imparts elastomeric properties to the asphalt and increases the membrane's breaking strain by a factor of 10 or more compared with a conventional built-up bituminous membrane's breaking strain.

The polymers used to make these physical improvements in the modified-bitumen membranes include APP (atactic polypropylene) and SBR (styrene-butadiene rubber) and SBS (styrene-butadiene-styrene block polymer). Reinforcement is generally polyester or glass fibers, sometimes in combination.

The Canadian General Standards Board (CGSB) system divides modified bitumen membranes into three categories:

a) By exposure: Type 1, exposed (always anchored); Type 2, shielded (anchored or loose-laid);

MIL-HDBK-1001/5

b) By surfacing: Class A, granule-surfaced; Class B, metallic-surfaced; Class C, plain-surfaced;

c) Service conditions: Grade 1, standard; Grade 2, heavy-duty.

6.1.2 Liquid-Applied Coatings. Liquid-applied coatings (i.e., membranes) are a special class of fully adhered membranes with limited assets but many liabilities. Chemically, they are synthetic rubbers.

6.1.2.1 Uses. A major use of liquid-applied coatings is on sprayed polyurethane (PUF) roof systems, which require a liquid-applied coating. Major liquid-applied coatings for sprayed PUF roofs include polyurethane, neoprene, hypalon, acrylic, and silicone.

Other acceptable substrates for these coatings are concrete and plywood.

6.1.2.2 Advantages. Within their narrow range of applicability, fluid-applied membranes have these notable advantages:

a) Conformance to irregular roof surfaces with good adhesion and little waste;

b) Continuous, seamless waterproofing (including base flashing at penetrations and edges for some systems).

6.1.2.3 Disadvantages. At the heart of the fluid-applied synthetics' disadvantages is their overwhelming dependence on high-quality fieldwork. In a concrete deck, cracks must be located, marked, and either sealed or taped. Cracks and seams greater than 1/64 inch must be sealed. A viscous mastic material seals cracks between 1/64 and 3/8 inches wide, and because of mastic shrinkage, satisfactory joint filling may require two mastic applications. Cracks or joints over 3/8 inches require taping. Cast-in-place concrete decks must be steel-troweled and then cured for at least four weeks to reduce repairs of post-application shrinkage cracks. To prevent moisture entrapment in the fluid-applied membrane, allow at least 2 days between the latest rainfall and membrane application.

6.2 Perimeter Anchorage. All membrane systems are anchored at their perimeters and at openings, with possible exception of modified bituminous or liquid-applied systems. Such anchorage serves several purposes:

a) To prevent stress concentration at flashings, which could either split or pull loose from their backings and become vulnerable to puncture. (Loose-laid systems receive maximum membrane tensile forces at perimeters and other terminations, according to field strain tests);

b) To restrain contraction in materials subject to long-term shrinkage;

c) To reduce membrane wrinkling which can obstruct drainage.

6.3 Single-Ply Membrane Standards. Where applicable, standards to be used for single-ply membrane materials are promulgated by the Rubber

MIL-HDBK-1001/5

Manufacturers Association (RMA), American Society of Testing and Materials (ASTM), and the CGSB, as follows:

RMA IPR-1/1985	<u>Minimum Requirements for Non-reinforced Black EPDM Rubber Sheets for Use in Roofing Applications</u>
RMA IPR-2/1985	<u>Minimum Requirements for Fabric-Reinforced Black Polychloroprene Rubber Sheets for Use in Roofing Applications</u>
RMA IPR-3/1985	<u>Minimum Requirements for Fabric-Reinforced Black Polychloroprene Rubber Sheets for Use in Roofing Applications</u>
ASTM D4434	<u>Standard Specification for Poly Vinyl Chloride Sheet Roofing</u>
ASTM D4637	<u>Standard Specification for Vulcanized Rubber Sheet Used in Single-Ply Roof Membrane</u>
CGSB 37-GP-56M	<u>Standard for Membrane, Modified Bituminous, Prefabricated and Reinforced for Roofing</u>

6.4 General Design Recommendations

6.4.1 New Roofs. For roofs on new facilities:

a) Require minimum 1/2 inch per foot slope for Navy facilities and minimum 1/4 inch per foot slope for Army facilities, 2 inch per foot maximum slope for loose-laid, ballasted systems.

b) Review material properties, limitations, advantages and disadvantages, and past performance of all systems under consideration (check 10-year performance in your geographical location);

c) Determine wind and fire resistance during this preliminary survey. Consult SPRI Wind Design Guide for ballasted single-ply roofing systems;

d) Check substrate for suitability: for sheet membranes, suitable substrates are structural concrete (cast-in-place and precast), lightweight insulating concrete with low moisture content, plywood, and rigid insulation board; for fluid-applied membranes, suitable substrates are structural concrete (cast-in-place and precast) and sprayed-in-place polyurethane foam;

e) For cast-in-place concrete decks, check concrete curing agents to ensure compatibility with synthetic membranes. Some curing agents can cause poor adhesion or even premature deterioration of the membrane;

f) Limit plywood to 5/8 inch minimum thickness, smooth-surfaced exterior grade, with edge support limiting differential deflection of adjacent panels to 1/8 inch at panel edges and 1/16 inch at ends;

MIL-HDBK-1001/5

g) Lightweight insulation concrete fills, gypsum deck, and rigid insulation boards are suitable substrates for mechanically fastened or loose-laid sheet membranes;

h) Do not specify fluid-applied synthetic membranes when substrate joint movement is anticipated;

i) Consider repairability in case of future damage.

6.5 Basic Information Required for New Construction

6.5.1 Geographical Location, Climatic Conditions at Project Site. Obtain from the following sources:

a) ASHRAE 1985 Handbook - Fundamentals;

b) NAVFAC, P-89.

6.5.2 Roof Deck

a) Structural capacity: For loose-laid, ballasted systems, design for additional 10 to 25 psf (160.2 to 400.5 kg/m³) dead-load capacity for ballast and/or concrete pavers;

b) Deck type: necessary to determine anchorage technique, vapor retarder, venting, wind-uplift, and fire requirements;

c) Slope: necessary to determine type of bitumen, if required for modified bitumen membrane, component anchorage, wood nailers, and insulation stops.

6.5.3 Special Occupancy Factors

a) Humidity: Necessary to determine need for vapor retarder and venting;

b) If there is waste spillage or exhaust onto roof surface, determine the nature of waste material. Periodic roof wash-down may be required; or other special membrane maintenance;

c) Chance for occupancy change (e.g. from low to high humidity).

6.5.4 Roof Insulation

a) Required thermal resistance (R-factor);

b) Maximum and minimum thickness required to span steel deck flutes;

c) Compressive strength required to resist rooftop traffic.

6.5.5 Roof Joints. Determine need for expansion joints, control joints, or area dividers.

MIL-HDBK-1001/5

6.5.6 Special Requirements. Determine requirements for flashing of walls, parapets, curbs, platforms, equipment platforms, penthouses, roof-traffic areas, conduit or pipe supports, etc.

6.5.7 Temporary Roof. Determine if temporary roofing is required due to location, construction schedule, and climate. Since the temporary roofing must be removed before permanent roof application, determine if the added cost is warranted.

6.5.8 Roof Deck Treatment/Preparation

a) Inspection of the structural elements of the roof deck for the following items: proper nailing, welding, hardness, dryness, and other requirements pertaining to the acceptability of other subcontractors' work should be made a provision under "testing and inspection" or other specification sections. (These conditions should not be the responsibility of the roofing contractor to accept or reject.)

b) Surface condition of decks to receive the roofing system, such as surface dryness, cleanliness, smoothness, adequacy for attachment, etc. - which directly affect the application of the roofing system - should require acceptance by the roofing contractor.

c) Provisions for priming of deck surfaces, if required, should be specified, including type of material and quantity.

d) Require all roof drains, penetrations, adjacent walls, etc. to be complete and installed prior to the start of the roofing system application.

e) If metal work is a vital component of the system, as in some Hypalon, CPE, and PVC systems, complete details on installation, joints, etc. should be included here.

6.5.9 Vapor Retarder. (Refer to Section 4)

a) Specify the type of material, method of securement, sealing at laps and projections, seal at drains, envelope at perimeter edges, etc.

b) Check compatibility of adhesives, films and insulations.

6.5.10 Roof Insulation. (Refer to Section 3)

a) Roof insulation by type.

b) Required R-factor with total thickness.

c) Application Criteria: One or more layers with two being preferred; anchorage techniques to deck or vapor retarder; protection both prior to and during installation from rain and wind. Determine if separator sheets are required.

MIL-HDBK-1001/5

6.6 Modified Bituminous Roofing Membranes

- a) Consider type of underlayment, anchorage technique, and manufacturer's specification criteria. Consider UL fire classifications and code criteria for underlayment and membrane material.
- b) Type of adhesive bitumen. Grade of bitumen; roof slopes; and heating or handling limitations, considering EVT or manufacturer's criteria.
- c) Application criteria: Sequence and criteria such as anchorage technique, brooming, extra reinforcement, protection of partially completed surfaces, torching or trowelling of laps, etc. Do not permit "torching" on buildings with combustible substrate components.
- d) Surfacing: Specify installation of appropriate surfacing, if required -- size, color and quantities of surfacing aggregate; if surface coatings are required, specify preparation of surfaces, quantities, approved method of application, number of coats, protection of adjacent surfaces, etc. If loose granules are to be sprinkled into exposed bitumen, so indicate.
- e) Protection: Of materials stored at the site, completed sections, building premises from stains and spills, etc.

6.7 Thermoplastic Roofing Membranes

- a) Type of underlayment or slip sheet, if required, lap-seaming techniques, placement of underlay at metal work, barrier properties for coal tar fumes, and bitumen contact.
- b) Anchorage techniques: for mechanical fastener, verify type that is appropriate for deck, specify length, how installed, size of washer, disc or nailer strip. If special tool or overdrive clutch is necessary, indicate here. For adhered systems, verify and detail appropriate substrate surface condition, cleaning, or priming. Specify type, quantity, and application methods for adhesives; specify dry time and tests for adhesion.
- c) Membrane: specify end and side laps, terminations, sealing methods, temperature or other weather limits for solvent or heat welding.
- d) Listing of materials required and application criteria.
- e) Surfacing: specify surfacing by quantity, screen gradation, or ASTM size. Indicate whether or not aggregate can be directly applied to membrane or whether stone protection is needed. For color coating, specify surface preparation, temperature limits, upper and lower limits on quantity per coat, method of application, curing requirements, etc.
- f) Protection: avoid bitumen contamination, specify appropriate non-bituminous protection boards and treatments for gas lines, etc.

6.8 Elastomeric Roofing Membranes

- a) Underlayment requirements, if any.

MIL-HDBK-1001/5

b) Anchorage techniques with special attention to nailer requirements on all systems, especially at perimeters. For adhered systems, verify and detail appropriate substrate surface condition, cleaning or priming details; specify type, quantity, and application methods for adhesives; and specify dry time, tests for adhesion.

c) Lap procedures: detail overlaps for end and sidelaps. Specify cleaning requirements and adhesive usage and sealants, if needed.

d) Listing of materials and application criteria.

e) Surfacing.

f) Protection. Some membranes will allow use of asphalt planks, coordinate planks, adhesives and membranes in specification so field mixing is avoided. Detail treatment for gas lines, etc. Caution: some adhesives will attack extruded polystyrene insulation.

6.9 Quality Control

a) Specify required quality control inspection services: pre-job and pre-application conferences; deck and substrate inspection; punch list and/or final inspection, and inspection of work in progress.

b) Test Cuts: single-ply -- manufacturers generally oppose field test cuts. However, tests of prototype lap seam and material specimens are a great help. Require manufacturer to provide.

c) Establishing permanent records: place 8-1/2-inch by 11-inch specimens of membrane material, manufacturer's current literature, manufacturer's maintenance instructions in a permanent file and supply to owner. Include all pertinent information on roof (date installed, name of contractors, type of membrane, type insulation, etc.).

d) Key all permanent inspection files, correspondence on deviations, etc. in the roofing file.

6.10 Flashings, Cant Strips, Incorporation of Metal Flashings, Drainage Fitting Treatment. All of these items must be clearly specified. Do not make the assumption that selection and specification of any roofing manufacturer's roof assembly specification will include these items. Cite specific detail plates or provide clear isometric drawings.

6.10.1 Related Sheet Metal Work. Depending upon trade practices, roofing sheet metal may either be included as a part of the roofing specifications, or may be a separate section. Regardless whether or not sheet metal work is done by the roofing contractor or by another contractor, it must be accurately specified, detailed and coordinated with the roofing work.

6.11 Applicable Details. Refer to SMACNA Architectural Sheet Metal Manual for manufacturers' information.

MIL-HDBK-1001/5

Section 7: SPRAYED POLYURETHANE FOAM

7.1 Material Description. Sprayed polyurethane foam (SPUF) is a field-produced, monolithic plastic foam roof insulation, produced in the field by nozzle-mixing of two separate liquid streams, an A (isocyanate) component and a B (hydroxyl or polyol) component. In addition to these basic chemical ingredients, the sprayed field mix also requires:

- a) a blowing agent (fluorocarbon gas) to form foamed cells that expand the polyurethane foam resin's volume;
- b) a surfactant to control cell size and cell-wall rigidity;
- c) catalysts to control the reaction rate between the two chemical components);
- d) fire retardants.

7.2 Uses. Sprayed polyurethane foam has its major use in reroofing. It offers the following advantages:

- a) High thermal resistance per unit thickness;
- b) Ultra-lightweight (roughly 1 psf for 3-inch thick foamed insulation plus membrane coating);
- c) Faster construction (generally two to three times the rate of conventional bituminous systems);
- d) Adaptability to steeply sloped, curved, and other irregular roof surfaces;
- e) Excellent adhesion, capable of producing 3,000 (48,055 kg/m³) psf uplift resistance when placed on a clean, dry, properly prepared substrate;
- f) Simpler flashing details.

7.3 Disadvantages. Compared with conventional built-up roof systems, sprayed polyurethane foam has some offsetting disadvantages:

- a) Added cost of recoating the fluid-applied membrane periodically;
- b) Greater difficulty in obtaining a level surface and uniform insulation thickness;
- c) Extremely high dependence on applicator's skill;
- d) High dependence on good substrate preparation;
- e) Reduced traffic and impact resistance;

MIL-HDBK-1001/5

- f) High vulnerability to degradation in hot, humid climates;
- g) Vulnerability to bird-pecking.

7.4 Design Recommendations. Roof system specifier must consider both design and field-application requirements. First, he must consider the following design items:

- a) Slope substrate minimum 1/2 inch per foot for Navy projects and 1/4 inch per foot for Army projects;
- b) Wind uplift resistance;
- c) Substrate requirements;
- d) Vapor retarder (if required);
- e) Membrane coating;
- f) Fire resistance ratings;
- g) Flashing details.

Do not specify foam application directly to a conventional ribbed steel deck. Specify minimum 3/8 inch thick exterior-grade plywood (untreated) fastened to the deck. Fastenings should conform with FM requirements for anchoring insulation boards.

7.4.1 Wind-Uplift Resistance. Well adhered sprayed polyurethane foam should satisfy the most rigorous wind-uplift forces.

7.4.2 Fire Rating. Class A when tested by UL 790 (external exposure) and FM Class 1 (interior fire exposure).

7.4.3 Vapor Retarder. As required in Section 4.

7.4.4 Foam Thickness and Slope. Polyurethane foam resins field-sprayed to uniform thickness (1 inch minimum thickness, 2-1/4 inches maximum thickness) for best control of foam cell size, density, and overall uniform foam quality (two to three inches in semi-tropical environments). Provide 1/2 inch per foot minimum slope for Navy projects and 1/4 inch per foot minimum slope for Army projects. Whenever possible, slope the deck rather than varying foam thickness to provide surface slope. Slope may also be provided by installation of compatible, tapered roof insulation as a substrate before spray application of uniformly thick foam. Uniform thickness is more apt to produce uniform quality because varying thickness requires varying spray rate to maintain uniform chemical reaction rate. If slope is provided by foam, use tapered boards to indicate proper surface contours of foam.

7.4.5 Control Joints. Provide control joints at all re-entry corners, with roof divided into sections of 10,000 square feet (929 m²) or less.

MIL-HDBK-1001/5

7.4.6 Membrane Coatings. Polyurethane foam requires a protective membrane covering. A good membrane coating must have these properties:

- a) Good adhesion;
- b) Temperature susceptibility (i.e., viscous at high temperature, but not brittle at low temperature);
- c) Abrasion resistance;
- d) Weather resistance (to solar radiation, rain);
- e) Maintainability (ease of repair when damaged, integration of repaired section with original material);
- f) Durability;
- g) Strength and elasticity;
- h) Low permeability in humid climates.

Membrane coatings applied to sprayed polyurethane foam substrates should always be fluid-applied. Fluid application works best with sprayed polyurethane foam because it fills the irregular substrate and adapts better to the slightly irregular surface of sprayed foam, to the "day's-work" termination details, and to the flashing of sprayed foam substrate. Foam applied today must be coated today. Coating shall be applied in two or more coats with total minimum thickness as follows: 30 mils (0.0008 m) for silicone, 40 mils (0.0010 m) for urethane or acrylic. In hot climates increase urethane to 45 mils (0.0011 m) and do not use acrylics.

7.4.7 Flashings. Fluid-applied flashings are generally self-sealing extensions of the membrane coating, applied simultaneously. Always specify cants.

7.5 Applicable Details. Polyurethane Foam Contractors' Division of the Society of Plastics Industry and Manufacturers' publications.

MIL-HDBK-1001/5

THIS PAGE INTENTIONALLY LEFT BLANK

MIL-HDBK-1001/5

Section 8: PROTECTED MEMBRANE ROOF SYSTEM

8.1 Description. The PMR, also known as the "Upside Down" roof, reverses the positions of membrane and insulation in the conventional built-up membrane roofing system. Instead of its conventional exposed position atop the insulation, a PMR membrane is sandwiched between the insulation above and the deck below.

The PMR is thus a change in materials location. A PMR, from bottom up, may include the following strata:

- a) Deck;
- b) Suitable underlayment leveling board (steel decks only);
- c) Additional layer of insulation for energy savings (may be tapered to improve slope to drain);
- d) Membrane;
- e) Protection board (best design);
- f) Percolation layer (best design);
- g) Insulation;
- h) Filter fabric;
- i) Ballast (aggregate or pavers).

8.2 General Design Recommendations

8.2.1 Structural Capacity. The designer must first consider the structure's load-carrying capacity. Lack of structural capacity to carry the additional ballast or paver dead load disqualifies the project for this option.

8.2.2 Slope. Slope deck and membrane a minimum 1/4 inch per foot for Army projects and minimum 1/2 inch per foot for Navy projects.

8.2.3 Water-Test. When practical, water-test completed membrane before installing insulation and surfacing with special attention to expansion joints and flashings.

8.2.4 Climate. PMR's are well-suited to cold climates, where the membrane doubles as a vapor retarder. The best location for a PMR membrane in a perpetually cold climate is obviously below the major insulation. (A thin layer of minor insulation, limited to less than 35 percent of the total R-value of the system, can level the membrane substrate and reduce heat/energy losses from convective and evaporative cooling following a rain. For additional energy savings, a layer of expanded polystyrene under the membrane may be more cost effective than excessive extruded polystyrene above the membrane.) In perpetually humid tropical climates, the best location for the

MIL-HDBK-1001/5

membrane is above the major insulation, such as for a conventional system, where the membrane serves as both roof and vapor retarder. The PMR system is excellent for areas with high ultraviolet exposure.

8.3 Specific Design Recommendations. PMR system design requires attention to the following aspects:

a) Drainage: slope to drains minimum 1/2 inch per foot for Navy projects and 1/4 inch per foot for Army projects;

b) Deck: slope minimum 1/2 inch per foot for Navy projects and 1/4 inch per foot for Army projects; designed to support ballast and live loads;

c) Membrane: bituminous fiber glass BUR; modified bitumen; single-ply sheets; liquid applied;

d) Protection board: 1/8- to 1/2-inch thickness, all edges sealed;

e) Percolation course: 1-1/2- to 2-inch minimum washed rock;

f) Insulation: use only extruded polystyrene ASTM C 578 Standard Specification for Preformed, Cellular Polystyrene Thermal Insulation, Type IV, above the membrane;

g) Filter fabric: non-rotting material (i.e. porous mat of polyester, polypropylene, polyethylene, etc.);

h) Ballast: 3/4- to 2-1/2-inch (19 to 63.5 mm) material, spread at a 10 to 20 psf density; concrete pavers, concrete wearing surface, composites of polystyrene and latex mortar. Large arrays of flat bottom pavers should be elevated on pedestals.

8.3.1 Drainage

a) The key to a properly functioning PMR is fast rainwater runoff, assured by a sloped membrane, percolation course, well-drained insulation, and surface finish.

b) Locate roof drains to avoid freezing.

c) Drains below must be thermally protected in cold regions.

d) Provide weep holes in drain at each sub-assembly level.

e) Use elevated scuppers in case drains become blocked.

f) In geographical areas subject to intense rainfall, overflow drains should be considered. Overflow drains are smaller in diameter than regular drains. They are placed upstream 10 to 15 feet and terminate at the top of the percolation course, with weep holes at the membrane level. The drain cage must be fine enough to prevent infiltration by percolation materials.

MIL-HDBK-1001/5

g) Provide interior gutter system as a back-up under expansion joints and skylight perimeters.

8.3.2 Protection Board. The membrane shall be protected at once by adhering a minimum 1/8 to 1/2 inch thick board manufactured for the purpose.

The joints of the board shall be filled and sealed with hot bitumen, to prevent water from migrating at the membrane-insulation board interface, or from being filled by fine aggregate from the percolation course. If construction sequence will require prolonged exposure, coat membrane protection board at once with PVA (polyvinyl acetate) white paint.

8.3.3 Percolation Course. The percolation course is designed to allow easy and free access of water to the drains and the insulation above to dry. This rock course shall be graded 1-1/2 to 2 inches maximum size. It must be rescreened before sending to the roof as fines develop in transit.

8.3.4 Flashings. Flashings for a PMR are essentially the same as for conventional roofs. They are, however, more vulnerable to damage, especially at cants adjacent to pavers. They should be carried a minimum 8-inch (203.2 mm) height above the roof's surface elevation.

8.4 Variations. There are variations in a protected membrane roofing system. The insulation may be placed directly on the membrane with its protection board, and the percolation course can be placed directly on the insulation with its filter fabric. The percolation course then serves as a ballasted finish.

8.5 Other Considerations

8.5.1 Single-ply or Liquid Membrane. A minimum four-ply fiberglass built-up system set in hot bitumen is a superior choice to a single-ply or liquid membrane.

8.5.2 Expansion Joint. In flush joints, never drape membrane materials in or over an expansion joint. Use preformed joint formers.

8.5.3 Flashings. Terminate all flashings a minimum of 8 inches above surface elevation.

8.5.4 Water Test. Leaks generally occur under expansion joints, flashings, and at embedded edge metal. Thoroughly water test before acceptance.

8.5.5 Interior Gutter. Provide interior gutter system connected to interior piping under expansion joints as a necessary auxiliary system.

8.6 Applicable Details. NRCA Roofing and Waterproofing Manual, SMACNA Sheet Metal Manual, Single-Ply Roofing Institute (SPRI) and design information and specifications of extruded polystyrene insulation manufacturers.

MIL-HDBK-1001/5

THIS PAGE INTENTIONALLY LEFT BLANK

MIL-HDBK-1001/5

Section 9: STEEP ROOFING

9.1 Steep Roofing Description. Steep roofing comprises a wide variety of roofing materials used on slopes ranging from 1-1/2 to 5 inches (38.1 to 127 mm) or more per foot. Shingles, shakes, and tiles depend on the gravitational-force component provided by slope to assure positive water-shedding. The gravitational water shedding force must exceed all the opposing forces (kinetic, capillary, and atmospheric suction) tending to draw water up the slope between overlapping roof units. Roll roofing, used on the lower slope ranges of steep roofing, relies relatively less on water-shedding principles and more on the water resistance provided by its double-layered roofing felts. The general 4 inches per foot (101.6 mm per m) slope used for most steep roofing systems is adequate to assure dependable water-shedding. Lower slopes require additional measures to assure good performance.

9.2 Materials. Steep roofing materials including the following: asphalt shingles, asphalt roll roofing, wood shingles and shakes, clay and concrete tiles, metal, and slate. These come in varied subgroups, such as roll and flat tiles. Consult the NRCA Steep Roofing Manual for details. Steep roofing materials also include metal in the form of standing seam and batten seam. Consult the SMACNA Architectural Sheet Metal Manual, and the ARMA Residential Asphalt Roofing Manual for details.

9.3 General Design Requirements

9.3.1 Slopes. Minimum slopes for various steep roofing materials are shown in Table 2. In snow country, designers should consider hazards of sliding and drifting snow.

9.3.2 Decks. Structural decks for steep-roofing systems include plywood, which facilitates the most convenient, economical, and dependable fastening techniques. Other materials, such as concrete, require installation of nailing strips, laths, horizontal battens, etc. These are described in the NRCA Steep Roofing Manual.

9.4 Underlayments. Several purposes are served by underlayments:

- a) To keep the deck dry until shingles or tiles are installed;
- b) To provide secondary water resistance protection if shingles or tiles are damaged, wind-lifted, or if wind-driven rain or water behind ice dams at cold eaves ever penetrate beyond the overlapped shingle;
- c) Form a cushion for slates;
- d) Minimize possible chemical reactions between resins in wood decks and asphalts in asphalt shingles or roll roofing.

9.4.1 Underlayments for Steep Roofing. Underlayments generally consist of one layer, non-perforated asphalt saturated felt for slopes of four inches per foot and higher. For lesser slopes, two layers of the same felt may be required and should be applied with a 19-inch (482.6 mm) overlap. Modified bituminous membranes are used at cold eaves in cold regions.

MIL-HDBK-1001/5

Table 2
Steep Roofing Slopes

MATERIAL	MIN. SLOPE (in./ft)	NOTES
Flat Shingle Tile (clay or concrete)	5	
One-piece Barrel Tile (clay or concrete)	4	Double-layer felt under- layment required 4-in. slope, single layer for slope greater than 4 in.
Two-piece Shingle Tile (clay)	4	
Interlocking Flat-ribbed Tile (clay or concrete)	4	
Asphalt Shingles	4	1 layer, non-perforated saturated felt underlay- ment 2-in. slope may be used if special pre- cautions, described in the NRCA <u>Steep Roofing Manual</u> and ARMA <u>Residen- tial Asphalt Roofing Manual</u> are taken.
Wood Shakes and Shingles	4	
Asphalt Shingles	2	Requires nonperforated, (square-tab strip) saturated felt under- layment double layered with 19-in. overlap.
Asphalt Roll Roofing (exposed nails)	2	Requires double-coverage roll, 3-in. top lap.
Asphalt Roll Roofing (Concealed nails)	1	6-in. end lap, 19-in. selvage.
Metal - Corrugated Steel, Aluminum	3	Refer to SMACNA Manual.
Copper, Terne	1/2	With double locked soldered seams.
Standing Seam, Metal	1/2	Requires floating-clip design. Refer to SMACNA Manual.

MIL-HDBK-1001/5

9.4.2 Underlayment for Wood Shake, Clay Tile, and Concrete Tile Roofs.
Underlayment is required only in the following areas:

- a) In valleys or eaves where ice dams may form;
- b) Where blowing dust or sand occurs regularly;
- c) In hurricane zones.

Regardless of the type of underlayment required, or the slope of the roof, in locations where the January mean temperature is 30 degrees F (-1.10 degrees C) or less, two plies of No. 15 felt, set in hot asphalt or mastic, or an adhered bitumen membrane should be applied as the underlayment starting from the eaves to a point 24 inches (609.6 mm) inside the inside wall line of the building to serve as an ice shield.

Wood shake roofs of less than 4 inches slope require other measures; i.e., one layer asphalt saturated felt underlayment nailed to wood decks followed by one layer of the same type of felt applied with hot moppings of asphalt, plus construction of a vented lattice work of boards above the structural deck. For felt underlayment specifications, patterns, laps, and other measures designed to improve water-resistance and overall roof system performance, refer to the NRCA Steep Roofing Manual.

9.5 Ventilation. Ventilation is required in attic spaces between the steep-roofing framing and the ceiling to prevent condensation from forming on cold surfaces when warm, humid air flows upward from heated interiors or, in warm climates where it is simply entrapped in these attic spaces. Air movement prevents or alleviates condensation on under-surfaces of shingles, tiles, or roof decks and thus prevents fungus rot of wood in the attic. Screened vents should be provided at eaves and gable ends to promote air movement that carries away humid stagnant air. Ventilation also reduces roof temperatures, thus prolonging membrane service life and in cold climates preventing ice dam formations and snow slides. Cold region designs require additional measures to assure good performance. Consult U. S. Army, Cold Regions Research and Engineering Laboratory (CRREL).

9.5.1 Paths. Natural vent paths must permit unobstructed air flow across the attic space by means of gable louver, screen vents, ridge vents, and eave soffit vents.

9.5.2 Vents. A minimum net free ventilation area of one square foot for every 300 square feet (27.9 m² of attic area is required. Ridge vents should be used whenever practicable, in conjunction with eave soffit vents, as they induce air-pressure differentials and thus accelerate air movement through the attic. In small gabled roofs without ridge vents, if the ceiling follows the rafter contour of a gabled roof, 1-inch (25.4 mm) diameter holes should be drilled through the ridge beam in every joist space to provide unobstructed transverse air flow to outside area.

Consult the NRCA Steep Roofing Manual for ventilating system details.

MIL-HDBK-1001/5

9.6 Anchorage Techniques

9.6.1 Fasteners. Nailing types and sizes for different steep roofing materials are shown in Table 3. For nail patterns and spacing, consult the NRCA Steep Roofing Manual. For asphalt shingles, consult the ARMA Residential Asphalt Roofing Manual, or ARMA Asphalt Roofing with Staples Manual. Fastener requirements for clay and concrete tile vary with slope and wind design conditions. Wiring may also be required for anchoring of ridge tiles.

9.6.2 Anchorage. In addition to fasteners, anchorage of various steep roofing material requires other techniques. Lap cement is used at seams in asphalt roll roofing (side, end, ridge and hip strips). Asphalt shingles have self-sealing strips. Clay and concrete tiles may require embedment in plastic cement. Use of plastic cement is standard to secure slate units at ridges and hips.

9.6.3 Hurricane or High-wind Zones. These require additional anchorage precautions. Clay and concrete tiles should be secured with special hurricane clips, additional fastening, and additional headlap (3 inches (76.2 mm) additional in 70 to 100 miles per hour (112.6 to 161 km/h) wind zones, 4 inches additional in hurricane zones of 100 plus miles per hour winds.)

9.7 Flashings. Flashings are required on steep roofs as well as low slope roofs to seal the joints at roof terminations and intersections - e.g., where roof planes intersect to form valleys, where dormers, chimneys, skylights, and other components pierce the roof, and at roof perimeters.

For general guide to the materials and techniques in flashing steep roofs refer to Table 4. Consult the NRCA Steep Roofing Manual for flashing details.

9.8 Applicable Details. NRCA Steep Roofing Manual, SMACNA Architectural Sheet Metal Manual, and ARMA manuals (latest issues).

MIL-HDBK-1001/5

Table 3
Fasteners for Steep Roofings

ROOF MATERIAL	FASTENER REQUIREMENTS
Asphalt Roll Roofing	No. 11 or 12 gauge hot dipped galvanized 3/8 inch minimum heads, shank length long enough to penetrate through the roofing and deck or at least 3/4 inch into a plywood or lumber deck.
Clay or Concrete Tile	No. 11; galvanized, yellow metal or stainless steel, shanks to penetrate minimum 3/4 inch into sheathing or through it.
Asphalt Shingles ¹	No. 11 or 12 gauge, hot-dipped galvanized, 3/8-inch minimum heads, with shank length long enough to penetrate through the roofing and through a wood panel deck or at least 3/4-inch into a lumber deck.
Wood Shakes, Shingles	Rust-resistant, galvanized or aluminum nails, 14-gauge, 3d x 1-1/4 inch long for 16-inch and 18-inch shingles or shakes; 14 gauge, 4d x 1-1/2-inch long for 24-inch shingles or shakes.
Slate	Copper slating nails only. 3d up to 18-inch long slates, 4d for 18 inches and longer slates, 6d nails at hips and ridges. Minimum length = 2 x slate thickness + 1 (e.g., 1-1/2 inch minimum length for 1/4-inch slate).

¹Staples may be substituted for nails, one-for-one, for wind-resistant shingles with factory-applied adhesives on new or recover construction. Consult ARMA Residential Asphalt Roofing Manual and individual manufacturers' instructions.

NOTE: "Hot" roofs in cold regions should slope 4 inches per foot or more (with backnailing) and have eave overhangs of less than 12 inches to minimize ice dam problems.

MIL-HDBK-1001/5

Table 4
Steep Roofing Flashing Guide⁴

ROOF MATERIAL FLASHING CONDITION	TILES (Clay, Concrete)	ASPHALT SHINGLES	WOOD (Shakes, Shingles)	SLATE	ASPHALT ROLL ROOFING
CHIMNEY CRICKET	NO	YES ¹	YES ¹	YES ²	YES
STEP FLASHINGS	YES	YES	YES	YES	NO
VALLEY FLASHINGS	METAL	MINERAL SURFACED ROLL ROOFING	METAL	METAL ³	CONSULT ARMA <u>RESIDENTIAL ROOFING MANUAL</u>
PERIMETER	METAL	METAL	METAL	METAL	MEMBRANE TERMINATION

¹DECK CRICKET²METAL CRICKET³OR "ROUND-VALLEY" CONSTRUCTION⁴Consult the NRCA Steep Roofing Manual and SMACNA Architectural Sheet Metal Manual for details

MIL-HDBK-1001/5

Section 10: REROOFING

10.1 Introduction. Buildings require reroofing because it is no longer economically viable to maintain the existing roof. Recovery is the process of covering an existing roof system with a new roof system. Replacement is the process of removing an existing roof system and providing a new roofing system. First determine why existing roof failed.

10.2 Basic Design Decision. The most basic design decision in reroofing is to either replace or recover. Never recover even a partially water-saturated insulation-membrane system. Always use nondestructive testing before designing. If the roof has been recovered once, a second recovering is not allowed. Leaking roofs which are classified as a premature failure must be evaluated for potential contributions to the failure (refer to para. 10.4).

10.2.1 Reroofing. Reroofing over existing steep roofing materials generally requires removal of old materials - either total or individual removal of copper, wrinkled, or other damaged units - in tile and slate roofs. For these materials, reroofing is governed by the same criteria as new construction.

For asphalt and wood shingles and shakes, however, recover roofing can be applied over existing roof units. Asphalt shingles can be applied over old asphalt shingles or old wood shakes or shingles and, conversely, wood shakes and shingles can be applied over old asphalt shingles.

Roll roofing can sometimes be safely re-covered with asphalt shingles, but it is generally prudent to remove old roll roofing before replacement.

For repairs and substrate examination and preparation required before recovering an old steep roofing system, consult the NRCA Steep Roofing Manual and the ARMA Residential Asphalt Roofing Manual. A major caution concerns the need for longer nails, sufficient to penetrate a wood deck a minimum 3/4 inch (19 mm).

10.3 Design. Design options are either recovery or replacement. Consider all options for best choice.

10.3.1 Drainage. Adding slope will eliminate the major cause of premature failure, however, on some existing low slope decks it is costly or impractical to create a 1/2-inch per foot slope with tapered insulation. Where existing low slope or near level roofs have failed due to old age, consider replacement in kind. It obviously was the right roof on the right building in the right geographical location. Otherwise replace the membrane with a minimum of four plies in coal-tar pitch and aggregate surfacing with additional drains where necessary. Asphalt, single-ply, or foam systems are not permitted on any roofs which will pond.

It is recommended, where practical, that a new roof design should incorporate positive slope which will eliminate all standing water conditions within a 24 hour period after rain. Review the number, type, sizing and location of old and new additional drains, use of scuppers for overflow, and

MIL-HDBK-1001/5

use of crickets for slope to prevent ponding between the drains. Never use wet fills to achieve slope.

10.4 Premature Failure Preliminary Investigation. The roof must be analyzed with the following in mind:

- a) Structural conditions contributing to the roofing problem;
- b) Interior space psychrometrics contributing to the roofing problem;
- c) Topside deficiencies contributing to the roofing problem.

10.4.1 Structural Influence. The original roof deck, supporting structure and, in many cases, the wall sections projecting above the roof elevation have a direct bearing on the longevity of the roofing composite. Structural influences which must be considered include the following:

- a) Type of roof deck material;
- b) Deterioration of roof deck and/or structure;
- c) Deflection of roof deck and/or structure;
- d) Expansion joints and/or control joints;
- e) Structural adequacy or load-bearing capacity in conformance to current design criteria;
- f) Deterioration of parapet walls and/or adjacent step-up walls.

10.4.2 Interior Space Conditions. Psychrometric factors which must be considered include the following:

- a) Building occupancy (current and proposed);
- b) Existing building heating, ventilating, air conditioning, and humidification systems;
- c) Maximum hour location of dew point within the roof composite;
- d) Vapor retarder requirements. Be aware of vapor pressure direction in humid climates which is usually downward.

10.4.3 Topside Deficiencies

- a) Design;
- b) Materials;
- c) Workmanship.

10.5 Considerations

MIL-HDBK-1001/5

10.5.1 The Insulation System. Consider the following:

- a) Required R-value of the system;
- b) Formation of roof slope including preformed tapered insulation;
- c) Method of attachment to the substrate and new components to old ones;
- d) Compatibility with adjacent roof composite materials;
- e) Fire and wind requirements;
- f) Load carrying ability of the structure;
- g) Dimensional stability as it relates to moisture intrusion and temperature change;
- h) Product availability and maintainability;
- i) Costs, life cycle economics, etc.

10.5.1.1 Tapered Insulation. Tapered insulation has the following disadvantages:

- a) Difficult design coordination for flashing heights and other roof details affected by varying insulation thickness;
- b) Require fairly complex field operations for some materials involving special drawings and coded insulation pieces;
- c) Hazards of excess insulation thickness.

10.5.2 Membrane System. The most common roofing membranes include standard built-up bituminous roofing and single-ply systems. In making a selection of membrane system consider the following:

- a) Ponding water conditions, slow draining roofs and potential formation of ice;
- b) Minimum slope restrictions. Standard is 1/2 inch per foot for Navy projects and 1/4 inch per foot for Army projects;
- c) Special construction logistics;
- d) Weight limitation dictated by existing deck;
- e) Expansion and/or control joint requirements;
- f) Flashing requirements;
- g) Fire and wind requirements;
- h) Roof traffic requirements;

MIL-HDBK-1001/5

- i) Maintenance requirement;
- j) Susceptibility to vandalism;
- k) Material track record of past performance;
- l) Product availability of all components from one manufacturer;
- m) Product compatibility with adjacent roofing products and materials within the new roof composite;
- n) Method of attachment;
- o) Tensile or "T" peel strength requirements, especially lap seams of single-ply systems;
- p) Cost.

10.6 Surfacing

10.6.1 Smooth-Surfaced Roofs. Smooth-surfaced roofs are relatively easy to inspect visually and repair but they require periodic recoating with cutbacks or emulsions. Coatings can be a cost-effective way of extending the useful life of a bituminous built-up membrane. However, a dry, brittle or delaminated membrane should not be recoated. A system containing wet insulation or other subsurface problems should not be recoated. Roofs that pond water should not be recoated. Coatings should be fibrated. Aluminized coatings can significantly lower the temperature of the membrane, prolonging its useful life. However, the extra benefits of "penetrating coatings" (sometimes called resaturants) are disputed. Their extra cost is seldom justified. Smooth-surfaced roofs are not as durable as aggregate-surfaced roofs and should be considered only where aggregate-surfaced roofs have some disadvantages (e.g. at airports, structural considerations, etc.).

Surfacing with cap sheets or sprayed granules eliminates the need for periodic recoating but does not provide as durable a surfacing as aggregate. Cap sheets are prone to blistering, especially when they are installed in cold weather.

10.6.2 Aggregate-Surfaced Roofs. Aggregate surfacing is a very effective way of armoring a bituminous built-up membrane against the weather, roof traffic, and other external abuse. However, when an aggregate-surfaced roof has deteriorated, it is very difficult to extend its useful life. In very limited cases it is possible to remove all loose aggregate and dirt, repair all flashing and membrane defects, then spray a coating of cutback asphalt or pitch as required onto the existing system and surface it with new gravel.

10.6.3 Coatings

10.6.3.1 Emulsions. Dispersions of asphalt or coal-tar in water with an emulsifier agent such as clay are approximately 50 percent solids. The material has a consistency of mayonnaise. It may be brushed or sprayed. Emulsions must be protected from freezing until all water has evaporated from them.

MIL-HDBK-1001/5

10.6.3.2 Cutbacks. Cutbacks have approximately 50 percent solids suspended in a solvent base vehicle.

10.6.4 Ponding. (Refer to para. 10.3.1)

10.7 Foot Traffic. Provide walkway pads to accomodate periodic traffic over the roofing surface. Since the walkway pad will shrink while losing water, do not adhere thick pads directly to the roof surface. The shrinkage strain will not be transmitted to the roof membrane. Splits or blisters will not occur at these points. Adhered modified bitumen sheets or precut pavers placed on filter fabric may also be used.

10.8 Cold-Process Roofing. Cold-process systems are life extension and maintenance procedures on smooth roofs. There are coating and overlay types in asphalt or coal tar base with or without reinforcement. They must be placed on clean, dry surfaces with no entrapped wet insulation below.

MIL-HDBK-1001/5

THIS PAGE INTENTIONALLY LEFT BLANK

MIL-HDBK-1001/5

Section 11: FIRE RESISTANCE

11.1 General. Fire hazards to roof systems are broadly classified as follows:

- a) External, above-deck fire exposure from flying brands or burning debris blown over from neighboring building on fire;
- b) Internal, below-deck fire exposure from interior inventory or equipment fires;
- c) Time-temperature or fire resistance classifications.

11.2 External Fire Resistance

11.2.1 Membranes. Roofing membranes are tested and rated for their resistance to external fire. They should not spread flame rapidly, produce flying brands endangering adjacent buildings, or permit ignition of supporting roof decks.

11.2.2 Tests. According to the industry standard for rating roof coverings, ASTM E 108 Standard Test Methods for Fire Tests of Roof Coverings, classified roof coverings "are not readily flammable, do not slip from position, and possess no flying brand hazard." Their performance is rated for different fire intensities:

11.2.3 Ratings. Roof coverings are rated as Class A, B, or C, depending on their resistance to external fires of varying intensity. Class A coverings provide the greatest resistance, Class C the least.

11.3 Internal Fire Hazards

11.3.1 Background Research. Background research on acceptable fire spread from internal (i.e., below-deck) fires has focused chiefly on steel-deck roof assemblies, which are especially important because of steel's predominance among deck materials. Because of its extremely high thermal conductivity, steel deck immediately transmits the heat energy of an interior fire to the above-deck roof components.

11.3.2 Safeguard. The chief safeguard required against internal fire is limitation of flame spread along the underside of the roof assembly.

11.3.3 Steel Deck. A steel deck roof assembly with 1-inch, mechanically anchored, plain vegetable fiberboard insulation and a four-ply, aggregate-surfaced built-up membrane has become the standard roof construction for both UL and FM; the criteria for evaluating other roof-deck assemblies. To qualify for UL listing as "acceptable," a roof deck assembly must not spread the flame of a UL 1256, Fire Test for Roof Deck Constructions, flamespread test farther than this standard steel-deck assembly. (FM Class 1)

11.4 Time-Temperature Ratings

MIL-HDBK-1001/5

11.4.1 Temperature. A roof assembly's time-temperature rating (given in time units of hours and fractions of hours) is established by its performance when tested as specified in ASTM E 119 Standard of Fire Tests of Building Construction and Materials furnace test, which subjects the tested assembly to a constantly rising temperature.

11.4.2 Fire-endurance Test. The fire-endurance test measures roof assembly performance in carrying loads and confining fire. To qualify for a given fire rating, the tested assembly must: sustain the applied design load, permit no passage of flame or gases hot enough to ignite cotton waste on the unexposed surface, and limit the average temperature rise of the unexposed surface to a maximum 250 degrees F (163 degrees C) above its initial temperature or a 325 degrees F (121 degrees C) rise at any point.

11.4.3 Steel. For steel assemblies with structural steel, prestressed, or reinforced concrete beams spaced more than 4 feet on centers, there are several other complex requirements set forth in UL 263, Fire Tests of Building Construction and Materials.

11.5 Design Requirements. Roof designers shall follow MIL-HDBK-1008 Sections entitled:

- a) Parapets,
- b) Roof Exposure,
- c) Roof Coverings, and
- d) Roof Deck Assemblies.

MIL-HDBK-1001/5

Section 12: WIND-UPLIFT RESISTANCE

12.1 Wind-Uplift Hazards. Wind-uplift hazards to roof systems depend on the phenomenon known as the Bernoulli principle: increased air velocity reduces the pressure exerted perpendicular to the direction of air flow. As a consequence, low slope roofs, in particular, experience maximum wind-uplift pressures.

12.1.2 Resistance. Wind-uplift resistance on low slope roofs is based on two radically different principles:

a) Resistance from fasteners and/or adhesives anchoring the various roof system components to the supporting structural deck;

b) Ballast, in the form of loose gravel or concrete pavers, designed to overcome wind-uplift pressure through gravitational counter pressures.

12.2 Failure. Failure modes for the two different anchorage techniques are radically different. Anchored roof systems usually fail by blow offs of membrane and insulation boards, which are rolled back, exposing the deck. Ballasted systems have a more complex failure mode. Failure starts with wind scour, which exposes the loose-laid membrane in areas subject to highest wind-uplift pressures (generally at building corners.) Scouring may be followed by membrane ballooning, with possible membrane tearing, and is sometimes accompanied by insulation displacement into sub-membrane "hills" on the roof deck.

Although the 10 to 25 psf (49 to 122 kg/m²) ballast weight may be only a minor fraction of the wind-uplift forces, ballasted systems seldom bare the huge deck areas that are sometimes exposed in failed anchored systems. An adhered system usually experiences a blow off from local failure, like the tensile failure of the weakest link in a chain. In contrast, in a ballasted system, any wind-lifted or ballooned area normally shifts its ballast to an adjacent area, where the uplift resistance is consequently increased.

12.3 Ballasted Systems. Ballasted systems are limited to single-ply membranes, usually elastomeric or plastic sheets, but also for some modified bituminous membranes, and protected membrane roofs.

12.4 Dead Load. The additional dead load of 10 to 25 psf for gravel ballast or pavers is readily accommodated in new construction. But reroofing of existing buildings obviously requires a check of the original structural design to determine if the structural framing has excess capacity over its original design load, and inspection of the roof's structural components to assure its sound condition. Additional ballast load required at the roof perimeter may sometimes be averted by a combination anchored/ballasted system, described in Factory Mutual Data Sheet 1-29 Technical Advisory Bulletin, Loose-laid Ballasted Roof Coverings.

MIL-HDBK-1001/5

12.5 Mechanical Fasteners. For manufacturers' approved mechanical fasteners and fastener patterns, refer to the latest edition of the Factory Mutual Approval Guide.

12.6 Design Data. For design guidance on wind-uplift pressures for various U.S. locations, wind-design procedures, and other details, consult Factory Mutual Publications. For design guidance for locations outside the U.S., refer to MH-1002/2, Loads.

MIL-HDBK-1001/5

Section 13: BELOW-GRADE WATERPROOFING

13.1 Material Description. Basic considerations for below-grade waterproofing are the same as for plaza waterproofing (refer to Section 14). Below-grade adds the extra ingredient of probable static ground water pressure; therefore, the primary objective is to drain away the water and prevent the build-up of hydrostatic pressure.

For both horizontal and vertical surfaces, multiple systems are superior. These systems may be applied hot or cold. Fluid-applied and single-ply sheet applications can be considered if conditions will not be severe and if access in case of failure is easy. Bentonite clay panels are sometimes used for waterproofing, especially below slabs and on vertical walls.

13.2 Uses. Below grade waterproofing may be required for basement slabs, foundation walls, planters, mud slabs, tunnels, sidewalk vaults, etc.

13.3 General Requirements

13.3.1 Substrates. All substrates must be free of laitance, sharp projections, facial imperfections, curing compounds, oil, grease, and moisture in any form.

13.3.2 Masonry. In all cases, masonry requires priming with a material compatible with the selected membrane system.

13.3.3 Membrane. Membrane reinforcing must be provided at all joints, reinforced, non-reinforced, or expansion joints. (Refer to ASTM C 981, Guide for Design of Built-Up Bituminous Membrane Waterproofing Systems for Building Decks.) Reinforcing must also occur at all sharp turns, flashing terminations, penetrations, pedestals, drains, etc.

13.3.4 Protection. All membranes must be protected with protection board of sufficient thickness to withstand anticipated abuse. Boards conforming to ASTM C 208, Standard Specification for Insulating Board (Cellulosic Fiber), Structured and Decorative, ASTM C 726 Standard Specification for Mineral Fiber and Mineral Fiber, Rigid Cellular Polyurethane Composite Roof Insulation Board, or ASTM C 578, Type II Grade 2, are acceptable.

13.3.5 Subterranean Space. If the subterranean waterproofed space is to be occupied, it should be thermally insulated with of extruded polystyrene insulation, having a minimum R-value of 8.34, 10 feet (3.05 m) back from the footings under the ground slab around the entire perimeter and the exterior of the foundation wall from footings to grade line, before backfilling.

13.3.6 Drain Tile. Walls in excavations for waterproofed exteriors shall be blanketed with coarse rock, underlain at foundation level with perforated drain tile connected to adequate sumps or existing storm water systems. Drain tile must be sloped.

13.4 Design Requirements

MIL-HDBK-1001/5

13.4.1 Slope. All horizontal surfaces shall have slope of 1/4 to 1/2 inch per foot (6.35 to 12.7 mm per m) in the monolithic pour if possible. Dead level slabs are often unavoidable, however.

13.4.2 Walls. Walls may require nailers to secure the top of the membrane 6 to 8 inches (152.4 to 203.2 mm) above grade. Horizontal nailers should be provided at 6 foot elevation intervals, set in a bed of bituminous material and waterproofed with additional layers of fabric and bituminous cement. Plies of felt or fabric shall run vertically.

13.4.3 Expansion Joints. These joints must receive preformed neoprene rubber gaskets, properly flashed.

13.4.4 Membrane Selection. The membrane may include use of felts, fabric and/or proprietary-coated fabric set in hot or cold bituminous material or proprietary adhesive. System shall be multiplied, with sufficient plies to withstand the anticipated hydrostatic pressure. The following table offers guidelines for determining the number of felt and/or fabric plies and moppings needed to resist different hydrostatic pressures:

HEAD OF WATER (in Ft.)	PLIES OF FELT AND/OR FABRIC	BITUMEN MOPPINGS	APPROX. TOTAL LBS. OF PITCH/ 100 ft ²	APPROX. TOTAL LBS. OF ASPHALT/ 100 ft ²
1-3	2	3	75-98	60-75
4-10	3	4	100-120	80-100
11-25	4	5	125-150	100-125
26-50	5	6	150-180	120-150

If sheet-applied membranes, such as PVC, neoprene, butyl, EDPM, Hypalon, etc., are elected, great care must be taken in the provision and testing of the lap seams before covering or back filling. All systems must be protected with insulation board which also serves as a protection board for the membrane. Extruded polystyrene is excellent for this purpose.

Preformed membranes: This class is factory-produced, consisting of a film of paper, polyethylene, polyvinylchloride, etc., and coated on both sides with rubberized asphalt or coal tar pitch. Specify membrane manufacturer's recommended primer and adhesives.

Single-ply sheet waterproofing requires immediate ultraviolet protection and/or backfilling to prevent blistering. In direct, hot sunlight, blistering can occur in 20 minutes or less on some materials.

MIL-HDBK-1001/5

13.5 Dampproofing. Many installations do not require an absolute waterproofed surface but only retarding of moisture penetration.

This retardation can be accomplished with brushable or trowelable bituminous or synthetic materials hot or cold. All such materials require the appropriate primer when applied over masonry. At least two coats are usually required.

13.6 Applicable Details. Refer to NRCA Roofing and Waterproofing Manual.

MIL-HDBK-1001/5

THIS PAGE INTENTIONALLY LEFT BLANK

MIL-HDBK-1001/5

Section 14: PLAZA WATERPROOFING

14.1 System Description. Some buildings provide large open promenade spaces with planters for aesthetics and pedestrian traffic roof areas for occupants and visitors.

Typical plaza systems and subsystems almost always contain free water, flowing in quantity. It is impossible to keep all the water out all the time. The basic system must be designed to excrete water that does get in, without damage to the interior space.

This section covers basic membrane options - i.e., hot-applied built-up roof membrane, elastomeric sheet, and liquid-applied waterproofing.

14.2 Uses. Of the three types, the hot applied built-up bituminous offers the most advantages:

- a) Multiple lines of waterproofing defense (via alternating layers of felt and bitumen);
- b) Adaptability to hot-applied protection boards;
- c) Excellent adhesion to concrete substrates;
- d) Familiarity to waterproofing mechanics;
- e) Known performance criteria.

14.3 Planters. Planters are notorious leakers. Whether precast or poured-in-place, they should not interrupt the main deck waterproofing. If poured-in-place planters are selected, they must be handled as a perimeter flashing. Precast planters are recommended. Never locate a planter across an expansion joint.

14.4 General Requirements

14.4.1 Minimum Slope. Provide minimum 1/4 inch per foot slope, built into base slab (1/2 in. is preferred). Do not rely on additional fills to provide slope. Provide crickets between drains at perimeter walls.

14.4.2 Joint Construction. Specify all joint construction with "watershed" concept in base slab (refer to ASTM C 981). These raised sections keep water freely drained from these very critical areas. All perimeter construction and expansion joints shall be provided with appropriately shaped preformed joint formers flashed into adjoining membrane.

14.4.3 Vapor Retarder. Calculate the vapor drive and use vapor retarder where required. (Refer to Section 4).

14.4.4 Insulation. Specify insulation of low water absorption in sufficient thickness to maintain membrane temperature above dew point.

MIL-HDBK-1001/5

14.4.5 Waterproofing Termination. Terminate waterproofing at top of cant strip against all walls and other projections.

14.4.6 Flashings. All flashings must project onto horizontal membrane a minimum 4 inches (101.1 mm) with two additional plies of stripping and terminate a minimum of 8 inches (203.2 mm) above finished grade of the plaza deck. Choose compatible elastomeric material to provide for movement.

14.4.7 Percolation Course. Specify a percolation course 2 inches (50.8 mm) thick, below insulation. Use washed smooth round river rock to drain water from insulation and to promote free flow to drains. Insulation board with preformed drainage channels is also acceptable.

14.4.8 Filter Fabric. Specify filter fabric over the percolation or insulation course to prevent clogging from dirt or other debris.

14.4.9 Pavers. Specify poured-in-place concrete slab wearing surface, pavers on mortar bed or pavers on pedestals. Pavers on pedestals are recommended for easy access in case of leaks. Do not specify bituminous wearing courses that require rolling for compaction.

Pavers must be set and elevated to allow sufficient opening between joints and substrate to filter ponded water to percolation course and into drains. Pavers should be leveled on all four corners.

14.4.10 Drains. All drains must have weep holes at every sub-assembly level and flashed into selected membrane. (Consult drain manufacturers for special assemblies.)

14.4.11 Protection Boards. Require protection boards for membrane and insulation, or both, depending on location of these components.

14.4.12 Testing. Completely water test all completed waterproofing with special care given to flashings, expansion joints and drains where most leaks occur before additional composites are added.

14.4.13 Overflow Drains. Refer to Section 8, para. 8.3.1.

14.4.14 Interior Gutters. Require interior metal gutters under expansion joints or skylight perimeters connected to interior drainage system, as most failures occur there.

14.5 Applicable Details. Refer to ASTM C 898 Guide for Use of High Solid Content, Cold Liquid-Applied Elastomeric Waterproofing Membrane with Separate Wearing Course, ASTM C 981, and the NRCA Roofing and Waterproofing Manual.

MIL-HDBK-1001/5

BIBLIOGRAPHY

American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc. (ASHRAE), 1791 Tullie Circle, N.E., Atlanta, GA 30329.

ASHRAE Brochure 1977

Psychrometry

American Society for Testing and Materials (ASTM) Standards, 1619 Race Street, Philadelphia, PA 19120.

Annual Book of ASTM Standards

Section 4

- Vol. 04.04 Roofing, Waterproofing, and Bituminous Materials
- Vol. 04.06 Thermal Insulation; Environmental Acoustics
- Vol. 04.07 Building Seals and Sealants; Fire Standards; Building Construction

Section 9

- Vol. 09.01 Rubber, Natural and Synthetic - General Test Methods, Carbon Black

- ASTM C 836 Specification for High Solids Content, Cold, Liquid-Applied Elastomeric Waterproofing Membrane for Use With Separate Wearing Course
- ASTM STP 603 Roofing Systems
- ASTM STP 779 M. Lieff and H. R. Treschel, Moisture Migration in Buildings
- ASTM STP 790 W. H. Gumpertz, Single-Ply Roofing Technology

Army Corps of Engineers Guide Specifications, Department of the Army, Publications Depot, Alexandria, VA 22304

- CEGS-06100 Rough Carpentry
- CEGS-07112 Bituminous Waterproofing
- CEGS-07220 Insulation for Roofing
- CEGS-07311 Roofing, Strip Shingles
- CEGS-07414 Protected Metal Roofing and Siding
- CEGS-07463 Asbestos-Cement Roofing and Siding
- CEGS-07510 Built-Up Roofing
- CEGS-07530 Elastomeric Roofing (EPDM)
- CEGS-07540 Elastomeric Roofing (Fluid Applied)
- CEGS-07600 Sheet Metal Work, General
- CEGS-07840 Roof Ventilators, Gravity-Type

Army Corps of Engineers, Cold Regions Research and Engineering Laboratory (CRREL), Hanover, NH (various publications)

Baker, M. C., Roofs: Design, Application and Maintenance, Multiscience Publications, 1980.

MIL-HDBK-1001/5

Bureau of Reclamation, Engineering & Research, April 1976, "Laboratory and Field Investigations of New Material for Roof Construction"

Callender, John, H., Time-Saver Standards for Architectural Design Data. New York: McGraw-Hill Book Co., 1974, page 561 - Insulation Board

Cinquemani V., Owenby, J. R., and Baldwin, R. G., Input Data for Solar Systems, U. S. Department of Energy, November, 1978.

The Construction Sciences Foundation SPECTEXT:

07213	Batt and Blanket Insulation
07212	Board Insulation

Construction Specifications Institute Manual, 601 Madison Street, Alexandria, VA 22314, Division 7 - Thermal and Moisture Protection Elastomeric Sheet Membrane Waterproofing and Fluid-Applied Waterproofing.

TM-5-809	Load Assumptions for Buildings
----------	--------------------------------

Degenkolb, John., An Explanation Into the Nature of Foamed Plastics. Southern Building, (February-March, 1982)

Department of Health, Education and Welfare-Office of Architectural and Engineering Services (Guide) Specifications:

0750	Building Insulation
------	---------------------

Department of the Interior, National Park Service Guide Specifications:

07210	Building Insulation
-------	---------------------

Federal Specifications, (FS), available from Superintendent of Documents, U. S. Government Printing Office, Washington, D.C. 20402

L-P-375 (3)	Plastic Film, Flexible, Vinyl Chloride
O-F-506C	Flux, Soldering; Paste and Liquid.
FF-S-107C(2)	Screws, Tapping and Drive.
HH-I-1030B	Insulation, Thermal (Mineral Fiber, for Pneumatic or Poured Application).
HH-I-1972	Gen and Subs Insulation Board, Thermal, Faced, Polyurethane or Polyisocyanurate (applies equally to Phenolic rigid boards)
QQ-A-250F/GEN	Aluminum and Aluminum Alloy, Plate and Sheet; General Specification for.
QQ-C-450A INT AMD 1	Copper-Aluminum Alloy (Aluminum Bronze) Plate, Sheet, Strip, and Bar (Copper Alloy Numbers 606, 610, 613, 614 and 630)
QQ-C-576B(1)	Copper lat Products with Slit, Slit and Edge Rolled, Sheared, Sawed, or Machine Edges, (Plate, Bar, Sheet, and Strip).

MIL-HDBK-1001/5

QQ-C-585B	Copper-Nickel-Zinc Alloy, Plate, Sheet, Strip, and Bar (Copper Alloy Numbers 735, 745, 752, 762, 766 and 770).
QQ-N-281D INT AMD 1	Nickel-Copper Alloy, Bar, Rod, Plate, Sheet, Strip, Wire, Forgings, and Structural and Special Shaped Sections.
QQ-N-286D	Nickel-Copper-Aluminum Alloy, Wrought.
QQ-S-571E(2)	Solder, Tin-Alloy; Tin-Lead Alloy; and Lead Alloy.
QQ-S-698(3)	Steel Sheet and Strip, Low Carbon.
QQ-S-700C (1)	Steel Sheet and Strip, Low Carbon.
QQ-S-775E INT AMD 1	Steel Sheets, Carbon, Zinc-coated.
QQ-Z-301C	Zinc Sheet and Strip.
UU-B-790A INT AMD 1	Building Paper, Vegetable Fiber (Kraft, Waterproofed, Water-Repellent, and Fire- Resistant).

General Services Administration (GSA) Guide Specifications:

4-0723	Building Insulation
07212	Board Insulation

Griffin, C. W. Energy Conservation in Buildings: Techniques for Economical Design. Alexandria, VA: The Construction Specifications Institute, 1974.

Kawaller, Seymour, I. The Spec Writer and the Great Plastic Foam Controversy. The Construction Specifier, p. 45 (November, 1975).

Madden, Gary, Foil Insulation for Metal Buildings. Metal Building Review, p. 68 (March, 1982).

Maxwell, Baker C., Roof Designs, Application and Maintenance, Multiscience Publications, Ltd. 1980, page 194.

Military Specifications, available from Superintendent of Documents, U.S. Government Printing Office, Washington, D. C. 20402

MIL-I-2819	Insulation Block, Thermal (FSC) 5640
MIL-I-14511	Insulation Sheet, Cellular, Plastic, Thermal (FSC) 5640

Mineral Insulation Manufacturers' Association, Inc. (MIMA)

Insulation Manual, Homes, Apartments, Second Edition, 1979.

The Insulation Report

Mineral Wool, Batts and Blankets (BBO-10)

Mineral Wool, Blowing Wool (BW-20)

MIL-HDBK-1001/5

National Association of Architectural Metal Manufacturers (NAAMM)

S1-1a70

Flexible Fibrous Glass Insulation

National Roofing Contractors Association (NRCA) One O'Hare Center, 6250 River Road, Rosemont, IL 60018

Roofing Spec (monthly since 1968)

National Academy of Sciences, Washington, DC 20418, Expansion Joints in Buildings, Technical Report No. 65, 1974

National Aeronautics and Space Administration (NASA)

07210

Building Insulation

7J

Building Insulation

Navy Civil Engineering Laboratory, Technical Note, Coultrap, 1980.
"Principals of Urethane Foam Roof Application."

NAVFACENGCOM Design Criteria

Department of Defense activities may obtain copies of Design Manuals and P-Publications from the Commanding Officer, Naval Publications and Forms Center, 5801 Tabor Road, Philadelphia, PA 19120. Department of Defense activities must use the Military Standard Requisitioning and Issue Procedure (MILSTRIP), using the stock control number obtained from NAVSUP Publication 2002.

Other Government Agencies and commercial organizations may procure Design Manuals and P-Publications from the Superintendent of Documents, U. S. Government Printing Office, Washington, D. C. 20402.

DM-1.01	Basic Architectural Requirements and Design Considerations
MIL-HDBK-1001/2	Materials and Building Components
MIL-HDBK-1002/5	Timber Structures
MIL-HDBK-1006/1	Policy and Procedures for Construction Drawings and Specifications
MIL-HDBK-1006/2	Policy and Procedures for Guide Specification Preparation
NFGS 07111	Elastomeric Waterproofing System, Sheet Applied
NFGS 07120	Elastomeric Waterproofing System, Fluid Applied
NFGS-07221	Masonry Wall Insulation
NFGS-07222	Tapered Roof Insulation
NFGS-07230	Perimeter and Under-Slab Insulation
NFGS-07232	Ceiling, Wall, and Floor Insulation
NFGS-07540	Fluid-Applied Elastomeric Roof Coatings Over Polyurethane Foam (PUF)
NFGS-07545	Sprayed Polyurethane Foam (PUF) for Roofing Systems

MIL-HDBK-1001/5

NAVFACENGCOM SOUTH DIV, Air Conditioned Buildings in Humid Climates. Guidelines for Design, Operation and Maintenance, April, 1980, also available from National Technical Information Service, (NTIS) AD-A090145, 5285 Port Royal Road, Springfield, VA 22161

National Bureau of Standards (NBS) documents are available from the National Technical Information Service (NTIS), 5285 Port Royal Road, Springfield, VA 22161; or through the Superintendent of Documents, U.S. Government Printing Office, Washington, D.C.

National Bureau of Standards, Center for Building Technology, Building 226, Room B348, Washington, DC 20234.

Summer Attic and Whole-House Ventilation, 548

National Bureau of Standards Technical Studies, Superintendent of Documents, U. S. Government Printing Office, Washington, DC 20402

BSS-9	Building Science Series - Thermal Shock Resistance for Built-up Roofing
B55-131	Laboratory Evaluation of Non-Destructive Methods to Measure Moisture in Built-up Roofing Systems
NBS Report 10 693	Guidelines for Selection of and Use of Foam Polyurethane Roofing Systems
NBS-55	Building Science Series-Preliminary Performance Criteria for Bituminous Membrane Roofing
NBS-89	Monograph - Effects of Thermal Shrinkage on Built-up Roofing
NBS-92	Building Science Series- The Viscosities of Roofing Asphalts at Application Temperatures
NBS-473	Technical Note-Laboratory Field Comparisons of Built-up Roofing Membranes
NBS-863	Technical Note-Fatigue Tests of Bituminous Membrane Roofing Specimens
NBS TN 1146	Moisture Detection in Roofing by Non-Destructive Means.
NBSIR 86-3455	Investigation of the Use of Nondestructive Methods for Inspection of Seams of Single Ply Roofing Membranes

Portland Cement Association, Skokie, IL 60076, Building Movements and Joints, 1982

U.S. Department Publications: available from U. S. Government Printing Office, Washington, D. C. 20402:

U. S. Department of Agriculture/Farmers Home Administration

FmHA Construction Standard

MIL-HDBK-1001/5

U. S. Department of Defense-Guide Specifications for Military Family Housing:

OCE, GSH 6.4a	Army Guide Specifications
FAC,GSH 6.4a	Navy Guide
AFM84-25, Sec. 6.4a	Air Force Manual

U. S. Department of Housing and Urban Development/Federal Housing
Administration HUD/FHA - Minimum Property Standards

Minimum Property Standards (Thermal Requirements) for One and Two Family
Dwellings

Urethane Foam Contractors' Division of the Society of the Plastic Industry
(SPI/PFCD), Washington, D.C. (various publications)

Veterans Administration, Office of Construction - Master Construction (Guide)
Specifications:

07210	Building Insulation
-------	---------------------

MIL-HDBK-1001/5

REFERENCES

NOTE: Unless otherwise specified in the text, users of this handbook should utilize the latest revisions of the documents cited herein.

FEDERAL/MILITARY SPECIFICATIONS, STANDARDS, BULLETINS, HANDBOOKS, AND NAVFAC GUIDE SPECIFICATIONS:

The following specifications, standards, and handbooks form a part of this document to the extent specified herein. Unless otherwise indicated, copies are available from Commanding Officer, Naval Publications and Forms Center, ATTENTION: NPODS, 5801 Tabor Avenue, Philadelphia, PA 19120-5099.

HANDBOOKS

MIL-HDBK-1002/2

Loads

MIL-HDBK-1008

Fire Protection for Facilities Engineering Design and Construction

NAVY MANUALS, DRAWINGS, P-PUBLICATIONS, AND MAINTENANCE OPERATING MANUALS:

Available from Commanding Officer, Naval Publications and Forms Center (NPFC), 5801 Tabor Avenue, Philadelphia, PA 19120-5099. To Order these documents: Government agencies must use the Military Standard Requisitioning and Issue Procedure (MILSTRIP); the private sector must write to NPFC, ATTENTION: Cash Sales, Code 1051, 5801 Tabor Avenue, Philadelphia, PA 19120-5099.

P-89 (also
AFM 88-29; TM 5-785)

Engineering Weather Data

P-442 (or
TM 5-802-1)

Economic Analysis Handbook
Life Cycle Cost Analysis Handbook

OTHER GOVERNMENT DOCUMENTS AND PUBLICATIONS:

The following Government publication forms a part of this document to the extent specified herein.

DEPARTMENT OF COMMERCE

Department of Commerce Standard PS 1

(Unless otherwise indicated copies are available from Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402).

MIL-HDBK-1001/5

NON-GOVERNMENT PUBLICATIONS:

Griffin, C. W., Manual of Built-Up Roof Systems, 2nd ed., available from McGraw-Hill, Book Company, New York, NY 10020.

Polyurethane Foam Contractor Division of The Society of the Plastics Industry (SPI/PFCD), 1275 K Street, NW, Suite 400, Washington, D.C. 20005 (various publications)

The following publications form a part of this document to the extent specified herein. Unless otherwise specified, the issues of the documents which are DoD adopted are those listed in the Department of Defense Index of Specification & Standards (DODISS).

AMERICAN SOCIETY OF HEATING, REFRIGERATING, AND AIR-CONDITIONING ENGINEERS, INC. (ASHRAE)

1985 Handbook - Fundamentals

(Unless otherwise indicated copies are available from American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc. (ASHRAE), 1791 Tullie Circle, N.E., Atlanta, GA 30329

AMERICAN SOCIETY OF PLUMBING ENGINEERS (ASPE)

American Society of Plumbing Engineers Data Book

Volume 1, Chapter 2 Storm Drainage Systems

Section 1 Roof and Area Drainage

(Unless otherwise indicated copies are available from American Society of Plumbing Engineers (ASPE), 15233 Ventura Boulevard, Sherman Oaks, CA 91403, 1983-84.)

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

ASTM E 108	Standard Test Methods for Fire Tests of Roof Coverings
ASTM E 119	Standard of Fire Tests of Building Construction and Materials (DoD adopted)
ASTM C 208	Standard Specification for Insulating Board (Cellulosic Fiber), Structural and Decorative (DoD adopted)
ASTM C 273	Standard Test Method for Shear Properties in Flatwise Plane of Flat Sandwich Construction or Sandwich Cores (DoD adopted)
ASTM C 578	Standard Specification for Preformed, Cellular Polystyrene Thermal Insulation (DoD adopted)

MIL-HDBK-1001/5

ASTM C 726	Standard Specification for Mineral Fiber, Rigid Cellular Polyurethane Composite Roof Insulation Board (DoD adopted)
ASTM C 898	Guide for Use of High Solid Content, Cold Liquid-Applied Elastomeric Waterproofing Membrane With Separate Wearing Course.
ASTM C 981	Guide for Design of Built-Up Bituminous Membrane Waterproofing Systems for Building Decks
ASTM C 1050	Standard Specification for Rigid Cellular Polystyrene - Cellulosic Fiber Composite Roof Insulation.
ASTM D 227	Standard Specification for Coal-Tar Saturated Organic Felt Used in Roofing and Waterproofing (DoD adopted)
ASTM D 312	Standard Specification for Asphalt Used in Roofing (DoD adopted)
ASTM D 450	Standard Specification for Coal Tar Pitch for Roofing, Dampproofing, Waterproofing (DoD adopted)
ASTM D 751	Standard Methods of Testing Coating Fabrics (DoD adopted)
ASTM D 1621	Test Method for Compressive Properties of Rigid Cellular Plastics (DoD adopted)
ASTM D 1623	Test Method for Tensile and Tensile Adhesion Properties of Rigid Cellular Plastics (DoD adopted)
ASTM D 2178	Standard Specification for Asphalt Glass Felt Used in Roofing and Waterproofing (DoD adopted)
ASTM D 2829	Practice for Sampling and Analysis of Built-Up Roofs
ASTM D 2842	Standard Test Method for Water Absorption of Rigid Cellular Plastics
ASTM D 2856	Standard Test Method for Open Cell Content of Rigid Cellular Plastics by the Air Pycnometer (DoD adopted)
ASTM D 3617	Practice for Sampling and Analysis of New Built-Up Roof Membranes

MIL-HDBK-1001/5

ASTM D 3672	Standard Specification for Venting Asphalt-Saturated and Coated Inorganic Felt Base Sheet Used in Roofing (DoD adopted)
ASTM D 4434	Standard Specification for Polyvinyl Chloride Sheet Roofing
ASTM D 4637	Standard Specification for Vulcanized Rubber Sheet Used in Single-Ply Roof Membrane
ASTM E 84	Standard Test Method for Surface Burning Characteristics of Building Materials (DoD adopted)
ASTM E 96	Standard Test Method for Water Vapor Transmission of Materials (DoD adopted)
ASTM E 108	Standard Test Methods for Fire Tests of Roof Coverings
ASTM E 119	Standard Test Methods of Fire Tests of Building Construction and Materials (DoD adopted)

(Unless otherwise indicated copies are available from American Society for Testing and Materials, 1619 Race Street, Philadelphia, PA 19120.)

ASPHALT ROOFING MANUFACTURERS ASSOCIATION (ARMA)

Asphalt Roofing With Staples Manual

Residential Asphalt Roofing Manual

(Unless otherwise indicated copies are available from Asphalt Roofing Manufacturers Association (ARMA), 6288 Montrose Road, Rockville, MD 20852.)

CANADIAN GENERAL STANDARDS BOARD, (CGSB)

CGSB 37-GP-54M January, 1979	Test Standards for PVC Sheet Membranes
CGSB 37-GP-56M-1980	Standard for Membrane, Modified Bituminous, Prefabricated and Reinforced for Roofing
CGSB 37-GP-56M July, 1980	Test Standards for Modified Bitumen Roof Membranes
CGSB 37-GP52M August, 1984	Test Standards for Elastomeric Sheet Membranes

(Unless otherwise indicated, copies are available from Canadian General Standards Board, (CGSB), Ottawa, Canada K1A-IG6.)

MIL-HDBK-1001/5

FACTORY MUTUAL SYSTEM (FM)

Factory Mutual Approval Guide (latest issue)

Factory Mutual Data Sheets:

I-7 Wind Forces on Buildings

I-28 Insulated Steel Deck

I-29 Loose-laid Ballasted Roof Coverings

I-47 Roof Coverings

I-48 Repair Procedures for Wood and Cementitious Roofs

I-49 Perimeter Flashing

I-52 Field Uplift Tests

I-54 Roof Collapse

(Unless otherwise indicated, copies are available from Factory Mutual System, 1151 Boston-Providence Turnpike, Norwood, MA 02062.)

NATIONAL ROOFING CONTRACTORS' ASSOCIATION (NRCA)

Roofing and Waterproofing Manual

(Unless otherwise indicated, copies are available from National Roofing Contractors' Association (NRCA), One O'Hare Center, 6250 River Road, Rosemont, IL 60018.)

RUBBER MANUFACTURERS ASSOCIATION

RMA IPR-1/1985	Minimum Requirements for Nonreinforced Black EPDM Rubber Sheets for Use in Roofing Applications
RMA IPR-2/1985	Minimum Requirements for Fabric-Reinforced Black Polychloroprene Rubber Sheets For Use in Roofing Applications
RMA IPR-3/1985	Minimum Requirements for Fabric-Reinforced Black Polychloroprene Rubber Sheets for Use in Roofing Applications

(Unless otherwise indicated, copies are available Rubber Manufacturers Association (RMA), 1400 K Street, N. W., Washington, D.C. 20005.)

MIL-HDBK-1001/5

SHEET METAL AND AIR CONDITIONING CONTRACTORS ASSOCIATION (SMACNA)

Architectural Sheet Metal Manual

(Unless otherwise indicated, copies are available from Sheet Metal and Air Conditioning Contractors' National Association, Inc., P.O. Box 70, Merrifield, VA 22116.)

SINGLE PLY ROOFING INSTITUTE (SPRI)

Wind Design Guide for Ballasted Single-Ply Roof Systems Single-Ply Roofing: A Professional's Guide to Specifications

(Unless otherwise indicated, copies are available from Single Ply Roofing Institute (SPRI), 104 Wilmot Road, Suite 201, Deerfield, IL 60015.)

STEEL DECK INSTITUTE

Design Manual for Composite Decks, Form Decks, and Roof Decks, Pub. No. 24

(Unless otherwise indicated, copies are available from Steel Deck Institute, P.O. Box 3812, St. Louis, MO 63122.)

UNDERWRITERS LABORATORIES, INC., (UL)

UL 263 Fire Tests of Building Construction and Materials

UL 790 Test for Resistance of Roof Covering Materials

UL 1256 Fire Test for Roof Deck Constructions

(Unless otherwise indicated, copies are available from Underwriters Laboratories, Inc., 333 Pfingsten Road, Northbrook, IL 60062.)

MIL-HDBK-1001/5

GLOSSARY

Aggregate: Gravel, crushed stone, washed round river gravel slag or mineral granules either (a) embedded in a conventional built-up membrane's bituminous flood coat, or (b) laid on a membrane as a protective ballast. Crushed stone should be avoided if possible.

Alligatoring: Deep shrinkage cracks, progressing down from the surface, in smooth-surfaced membrane coatings and sometimes in bare spots of aggregate-surfaced membranes, a consequence of photo-oxidative hardening, shrinkage due to loss of aromatics.

Asphalt: A dark brown to black, highly viscous, hydrocarbon produced from the residuum left after the distillation of petroleum, used as the waterproofing agent of built-up roofs and other building components.

Atactic polypropylene: High molecular-weight, thermoplastic, amorphous polymers used as a chemical ingredient to improve flexibility, elasticity, and ductility of bitumen, used in some single-ply modified bitumen membranes for torching applications.

Backnailing: Slippage-preventing technique of "blind" (i.e., concealed) nailing in addition to hot-mopping.

Ballast: Aggregate, concrete pavers, or other material designed to prevent wind uplift or flotation of a loose-laid roof or insulation system. Aggregate should be smooth, round, without flat faces and sharp edges.

Base Flashing: See Flashing.

Base ply: A felt or mat, usually coated, placed as the first non-shingled ply in a multi-ply built-up roof membrane.

Batten: Narrow metal or wood band used to anchor a membrane against wind uplift.

Bitumen: Generic term for an amorphous, semisolid mixture of complex hydrocarbons derived from petroleum or coal. In the roofing industry there are two basic bitumens: asphalt and coal-tar pitch. Before application, they are either (1) heated to a liquid state, (2) dissolved in a solvent, or (3) emulsified.

Blindnailing: Nailing of felts with nail heads covered by overlapping top felts.

Blister: A spongy, humped portion of a roof membrane, formed by entrapped air/vapor mixture under pressure, with the blister chamber located either between felt plies (i.e., interply) or at the membrane-substrate interface (interfacial).

MIL-HDBK-1001/5

Blocking: Continuous wood components anchored to the deck at roof perimeters and openings and doubling as cross-sectional fillers and anchorage bases, used in conjunction with nailers.

Brooming: The field procedure of pressing felts into a layer of fluid, hot bitumen to obtain continuous adhesion - i.e., elimination of blister originating voids - of the bitumen film.

Btu: (British thermal unit): Heat energy required to raise the temperature of 1 pound of water 1F.

Built-up roof membrane: A continuous, semiflexible roof covering of laminations or plies of saturated or coated felts or mats alternated with layers of bitumen, usually surfaced with mineral aggregate or asphaltic materials.

"Bull": Roofer's term for plastic cement.

BUR: Abbreviation for built-up roof.

Camber: Upward deflection built into a structural member subjected to flexural stresses to counteract the downward deflection from gravity loads.

Cant strip: Strip of wood, wood-fiber, or perlite board, triangular or trapezoidal in cross section, serving as transitional plane between horizontal and vertical surfaces. The cant provides backing for the stiff flashing felts of built-up roof construction, reducing the risk of cracking by halving the bend angle from 90 to 45 degrees.

Cap flashing: See Flashing.

Cap sheet: A mineral-surfaced, coated felt or mat used as the top ply of a built-up roof membrane.

Centistoke (cs): Unit of viscosity (antonym of fluidity). Water has a viscosity of roughly 1 cs; light cooking oil, 100 cs.

Channel mopping: See Strip mopping, under Mopping.

Chlorinated polyethylene: Synthetic rubber, used for single-ply membranes, composed of high-molecular-weight polyethylene, chlorinated to impart elasticity.

Chlorosulfonated polyethylene: Synthetic rubber based on high molecular-weight polyethylene with pendant sulphonyl chloride.

Coal-tar pitch: Dark brown to black solid hydrocarbon obtained from the residuum of distilled coke-oven tar, used as waterproofing agent of dead level or low-slope built-up roofs.

Cold-process roofing: A bituminous membrane comprising layers of saturated felts bonded with cold-applied asphalt roof cement and surfaced with a cutback or emulsified asphalt roof coating.

MIL-HDBK-1001/5

Counterflashing: See Flashing.

Crack: A membrane fracture produced by bending, often at a ridge (see Ridging).

Creep: (1) Permanent elongation or shrinkage of the membrane resulting from thermal or moisture changes. (2) Permanent deflection of structural framing or structural deck resulting from plastic flow under continued stress or dimensional changes accompanying changing moisture content or temperature.

Criker: Ridge, triangular in cross section, built-up in flat valley or perimeter to direct rainwater to a drain.

Crosslinking: Chemical bond formed between long-chain molecules in cured polymers.

Curing: The final step in the irreversible polymerization of a thermosetting plastic, requiring a combination of heat, radiation, and pressure.

Cutback: Solvent-thinned bitumen used in cold-process roofing adhesives, flashing cements, and roof coatings.

Cutoff: A detail designed to prevent lateral water movement into the insulation where the membrane terminates at the end of a day's work or at an isolated roof section, usually removed before work continues.

Dead level: Absolutely horizontal, or zero slope (See Slope).

Deck: Structural supporting surface of a roof system.

Delamination: Separation of felt plies in a built-up membrane or separation of previously factory-laminated insulation boards.

Dew Point: Temperature at which condensation of water vapor in a space begins for a given state of humidity and pressure as the vapor temperature is reduced; the temperature corresponding to saturation (100% relative humidity) for a given absolute humidity at constant pressure.

DFT: Dry film thickness, used as a measure of liquid-applied coatings.

Double pour: A doubling of the flood-coat, graveling-in operation, to provide additional waterproofing integrity to the membrane (done once, loose aggregate removed and done again).

Edge stripping: Application of narrow felt strips to cover a joint between flashing and built-up membrane.

Elastomer: A macromolecular material that rapidly regains its original shape after release of a light deforming stress.

Elastomeric: Having elastic properties, capable of expanding or contracting with the surfaces to which the material is applied without rupturing.

MIL-HDBK-1001/5

Emulsion: An intimate mixture of bitumen and water, with uniform dispersion of the bitumen globules achieved through a chemical or clay emulsifying agent.

Envelope: The continuous edge formed by folding an edge base felt over the plies above, securing it to the top felt. The envelope thus prevents bitumen seepage through the exposed edge joints of the laminated, built-up roofing membrane.

Equilibrium Moisture Content: The moisture content of a material at a given temperature and relative humidity, expressed as percent moisture by weight.

Equiviscous Temperature (EVT): The temperature at which bitumen has the viscosity of 125 centistokes for hot mopping.

Ethylene propylene diene monomer (EPDM): A thermosetting, synthetic rubber used in single-ply elastomeric sheet roof membranes.

Expansion joint: A flashed, structural separation between two building segments, designed to permit free movement without damage to the roof system.

Exposure: Transverse dimension of a felt not overlapped by an adjacent felt in a built-up roof membrane. Correct felt exposure in a shingled, built-up membrane is computed by dividing the felt width minus 2 in. by the number of plies - e.g., for four plies of 36-inch-wide felt, exposure = $36 - 2/4 = 8 \frac{1}{2}$ inches.

Fabric: Woven cloth of organic or inorganic filaments, threads, or yarns.

Fallback: Reduction in bitumen softening point, sometimes caused by refluxing or overheating in a closed container.

Felt: Flexible sheet manufactured by interlocking of fibers with a binder or through a combination of mechanical work, moisture, and heat.

Felt layer: Spreader-type, wheel-mounted equipment for laying felt and simultaneously dispensing hot bitumen.

Finger wrinkling: Wrinkling of exposed felts in small, finger-sized ridges parallel to the longitudinal direction of the felt roll, caused by transverse moisture expansion of the felt.

Fishmouth: Membrane defect consisting of an opening in a membrane felt edge lap.

Flashing: Connecting devices that seal membrane joints at walls, expansion joints, drains, gravel stops, and other places where the membrane is interrupted. Base flashing forms the upturned edges of the watertight membrane. Cap or counterflashing shields the exposed edges and joints of base flashing.

Flashing cement: A trowelable, plastic mixture of bitumen and asbestos (or other inorganic) reinforcing fibers, and a solvent (a stiffer, more sag-resistant material than plastic cement).

MIL-HDBK-1001/5

Flash point: Temperature of combustible material, as oil, at which there is sufficient vaporization to support combustion of the vapor.

Flux: Bituminous material used as a feed stock for further processing and as a material to soften other bituminous materials.

Glaze coat: A thin, protective coating of bitumen applied to the lower surface or to the top ply of a built-up roof when application of flood coat and aggregate is delayed. It sometimes refers to an asphalt coating on a smooth-surfaced, built-up membrane.

Grain: Weight unit equal to 1/7,000 lb, used in measuring atmospheric moisture content.

Granule: See Mineral Granules.

Gravel: Coarse, granular aggregate resulting from natural erosion or crushing of rock, used as protective surfacing or ballast on roof systems.

Gravel stop: Flanged device, usually metallic, with vertical projection above the roof level and fascia, designed to prevent loose aggregate from rolling or washing off the roof and to provide a finished edge detail for the roof.

Gravelling in: Process of embedding aggregate surfacing into a bituminous membrane flood coat.

Grout: A fluid mixture of cement and water, or a mixture of cement, sand and water.

Head lap: Minimum distance, measured perpendicular to eave along the face of a felt or shingle from its upper edge to the nearest exposed surface.

Holiday: Area where interply bitumen mopping or other fluid-applied coating is discontinuous.

Hood: Sheet-metal cover over piping or other rooftop equipment.

"Hot stuff" or "hot": Roofer's term for hot bitumen.

Hygroscopic: Absorptive of moisture; readily absorbs and retains moisture.

Ice dam: Drainage-obstructive ice formation at eave of snow-covered sloped roof, caused by refreezing of water melted by escape of interior heat.

Inorganic: Comprising matter not of plant or animal origin.

Insulation: See Thermal Insulation.

Laitance: Weak material, consisting principally of lime, that is formed on the surface of concrete, especially when excess water is mixed with the cement.

MIL-HDBK-1001/5

Loose-laid roof system: Design concept in which insulation boards and/or membrane are not anchored to the deck but ballasted by loose aggregate or concrete pavers.

Lap: The dimension that a felt covers an underlying felt or sheet in a multiple built-up bituminous membrane or single-ply membrane. Edge lap indicates the transverse cover; end lap indicates the cover at the end of the roll.

Mat: Flexible, heat-cured sheet made of inorganic fibers and a resinous binder.

Membrane: A flexible or semi-flexible roof covering, the waterproofing component of the roof system.

Mineral granules: Natural or synthetic aggregate particles, ranging in size from 500 microns (1 micron = 10^{-6} meter) to 1/4-inch diameter, used to surface cap sheets, asphalt shingles, and some cold-process membranes and modified bitumens.

Mineral-surfaced sheet: Asphalt-saturated felt, coated on one or both sides and surfaced with mineral granules.

Monomer: Class of molecules with molecular weight ranging roughly between 30 and 250, capable of combining into huge, polymeric macromolecules, 100 to 10,000 times as large as the basic monomeric molecules, through chainlike repetition of the basic monomeric chemical structure.

Mop-and-flop: A technique which roof system components (insulation boards, felt plies, cap sheets, etc.) are first placed upside down adjacent to their final locations, coated with adhesive, and turned over and adhered to the substrate (a generally bad practice).

Mopping: Application of hot, fluid bitumen to substrate or to plies of built-up membrane with a manually wielded mop or a mechanical applicator.

Solid mopping: A continuous coating.

Spot mopping: A pattern of hot bitumen application in roughly circular areas, generally about 18-inch diameter, on a grid of unmopped, perpendicular bands.

Strip mopping: A mopping pattern featuring parallel mopped bands.

Sprinkle mopping: A random pattern of bitumen beads hurled onto the substrate from a broom, mop, or machine.

Nailer: A wood member bolted or otherwise anchored to a deck or wall to provide nailing anchorage of membrane roof felts or flashings.

Neoprene: A synthetic rubber (chemically polychloroprene) used in fluid or sheet-applied elastomeric single-ply roof membranes or flashing.

MIL-HDBK-1001/5

One-on-one: Non-shingled application pattern of a single ply of felt followed by application of a second ply (see Phased application).

Organic: Carbon and hydrogen atom matter of plant or animal origin.

Parting Agent: Powdered mineral (talc, mica, etc.) placed on coated felts to prevent adhesion of concentric felt layers in the roll (sometimes called a releasing agent or anti-stick compound).

Perlite: An aggregate used in lightweight insulating concrete and in preformed insulating board, formed by heating and expanding siliceous volcanic glass.

Perm: A unit of water-vapor transmission, defined as 1 grain of water vapor per square foot per hour per inch of mercury pressure difference. (1 in. Hg= 0.491 psi.)

Permeance: An index of a material's resistance to water-vapor transmission. (See Perm)

Phased application: The practice of applying the felt plies of a roofing or waterproofing membrane in two or more operations.

Picture framing: Rectangular membrane ridging forming over insulation board joints, found predominantly in smooth-surfaced membranes.

Pitch pocket: Flanged, open-bottomed metal container placed around a column or other roof-penetrating element and filled with bitumen or plastic cement to seal the opening.

Plastic cement: Trowelable, plastic mixture of bitumen and asbestos (or other inorganic) stabilizing fibers and a solvent, used mainly for horizontal surfaces as opposed to Flashing cement, which is designed for vertical surfaces requiring sag-resistance.

Plasticizer: High-boiling-point solvent or softening agent added to a polymer to facilitate processing or to increase flexibility or toughness in the manufactured material.

Ply: A layer of felt in a roof membrane; a four-ply membrane has at least four plies of felt at any vertical cross section cut through the membrane.

Polymer: Long-chain macromolecules produced from monomers, for the purpose of increasing tensile strength of sheets used as membranes or flashing.

Polyvinyl chloride (PVC): A thermoplastic polymer, formulated with a plasticizer, used as a single-ply sheet membrane material.

Power-Trowel: Term applied to finish of a structural concrete deck slab's surface by a power-driven steel-troweling machine.

Primer: Thin liquid applied to seal a surface, to absorb dust, and to promote adhesion of subsequently applied material.

MIL-HDBK-1001/5

Protected membrane roof (PMR): A roof assembly with insulation atop the membrane instead of vice versa, as in the conventional roof assembly. (Also known as an inverted or upside-down roof assembly).

Psychrometric chart: A graphical representation of the properties of moist air, usually including wet and dry bulb temperatures, specific and relative humidities, enthalpy, and density.

Psychrometry: The branch of physics concerned with the measurement or determination of atmospheric conditions, particularly the moisture in air.

R-Value: In thermal insulation, the thermal resistance of insulation materials or constructions. See thermal resistance.

Re-covering: Covering an existing roof assembly with a new membrane instead of removing the existing roof system before installing the new membrane.

Rake: Edge of a roof at a gable.

Reglet: A horizontal groove in a wall or other vertical surface for anchoring flashing.

Relative humidity: Ratio (expressed as percentage) of the mass per unit volume (or partial pressure) of water vapor in an air-vapor mixture to the saturated mass per unit volume (or partial pressure) of the water vapor at the same temperature.

Rep: Unit of vapor-permeance resistance, reciprocal of perm.

Replacement: Process of removing and replacing an existing roof system (as opposed to mere re-covering, see above), also called tearoff-replacement.

Reroofing: The re-covering or replacement of an existing roof.

Resin: Basic raw material for manufacturing polymers, a synthetic polymer containing no deliberately added ingredients.

Ridging: Membrane defect characterized by upward displacement of the membrane, usually over insulation board joints (see Picture Framing).

Roll roofing: Coated felts, sometimes mineral-surfaced, supplied in rolls and designed for use without field-applied surfacing.

Roofer: Roofing contractor or subcontractor.

Roofing system: An assembly of interacting components designed to weatherproof, and normally to insulate, a building's top surface.

R-Factor: See Thermal Resistance.

Saddle: See Cricket.

Saturated felt: Felt that has been immersed in hot saturant bitumen.

MIL-HDBK-1001/5

Scupper: Channel through parapet designed for peripheral drainage of the roof, usually as safety overflow to limit accumulation of ponded rainwater caused by clogged drains.

Scuttle: Curbed opening, with hinged or loose cover, providing access to roof (synonymous with hatch).

Self-healing: Property of the least viscous roofing bitumens, notably coal-tar pitch, that enables them to seal cracks formed at lower temperatures.

Selvage joint: Lapped joint detail for two-ply, shingled roll-roofing membrane, with mineral surfacing omitted over a transverse dimension of the cap sheets to improve mopping adhesion. For a 36-inch-wide sheet, the selvage (unsurfaced) width is 19 inches.

Shakes: A wood roofing product that is split from a log and shaped by the manufacturer for commercial use. The three basic types of wood shakes are:

- handsplit and resawn shakes
- taper split shakes
- straight split shakes

Shark fin: Curled felt projecting up through the aggregate surfacing of a built-up membrane.

Shingles: Asphalt saturated roofing felt coated on both sides with asphalt, alone or stabilized with a finely powdered mineral material, the top coating usually being significantly thicker than the back coating and covered with roofing granules impressed in its surface. Most commonly used 12 inch x 36 inch, 3 tab self-sealing strip shingle.

Shingling: The pattern formed by laying parallel felt rolls with lapped joints so that one longitudinal edge overlaps the longitudinal edge of one adjacent felt, whereas the other longitudinal underlaps the other adjacent felt. (See Ply.) Shingling is the normal method of applying felts in a built-up roofing membrane.

Single-ply membrane: A membrane, either sheet or fluid-applied, with only a single layer of material designed to prevent water intrusion into the building

Skater's cracks: Curved cracks observed in smooth-surfaced built-up membranes

Slag: Porous aggregate used as built-up bituminous membrane surfacing, comprising silicates and alumino-silicates of calcium and other bases, developed with iron with a blast furnace.

Slippage: Relative lateral movement of adjacent felt plies in a membrane. It occurs mainly in sloped roofing membranes, exposing the lower plies, or even the base ply, to the weather.

MIL-HDBK-1001/5

Slope: The tangent of the angle between the roof surface and the horizontal, in inches per foot. The Asphalt Roofing Manufacturers' Association ranks slopes as follows:

Level: 1/2-inch maximum

Low slope: over 1/2 inch up to 1-1/2 inches

Steep slope: over 1-1/2 inches

Smooth-surfaced roof: A roofing membrane surfaced with a layer of hot-mopped asphalt or cold-applied asphalt-clay emulsion or asphalt cutback, or sometimes with an unmopped, inorganic felt.

Softening point: Temperature at which bitumen becomes soft enough to flow, as measured by standard laboratory test in which a steel ball falls a measured distance through a disk made of the tested bitumen.

Softening point drift: Change in softening point from temperature change during storage or application (see also Fallback).

Solid mopping: See Mopping.

Split: Membrane tear resulting from tensile stress.

Spot mopping: See Mopping.

Sprinkle mopping: See Mopping.

Spudder: Heavy steel implement with a dull, bevel-edged blade designed to remove embedded aggregate from a membrane surface (also called a Scraper).

Strawberry: Small bubble in flood coat of gravel-surfaced membrane.

Stripping: (1) The technique of sealing the joint between base flashing and membrane plies or between metal and roofing membrane with one or two plies of felt or fabric and hot- or cold-applied bitumen. (2) The technique of taping joints between insulation boards or deck units.

Styrene-Butadiene Rubber: High molecular weight emulsion polymers, cross-linked to maximize elasticity via copolymerization of styrene butadiene monomers, used as the modifying compound in some modified bitumen roofing membranes.

Styrene-Butadiene-Styrene Copolymer (SBS): High molecular weight emulsion polymers, with both elastomeric and thermoplastic properties, formed by the block copolymerization of styrene and butadiene monomers. The tri-block copolymer formed has a mid-block of butadiene with end blocks of styrene in some modified bitumen single-ply membranes.

Tearoff: Process of removing an existing roof system down to the structural deck.

MIL-HDBK-1001/5

Terne: Terne metal, prime copper-bearing steel, coated both sides with terne alloy, 20% tin, 80% lead. Terne metal is manufactured in a form of rolls in various widths and can be formed for standing seam roofs, batten seam roofs, and many types of flashing.

Thermal conductance (C-factor): The time rate of heat flow through unit area of a body induced by a unit temperature difference between the body surfaces. See thermal resistance.

Thermal conductivity (k-factor): The time rate of heat flow through unit thickness of a flat slab of a homogeneous material in the perpendicular direction to the slab surfaces induced by unit temperature gradient.

Thermal insulation: Material used on walls, ceilings, roofs and floors to retard the passage of heat.

Thermal resistance: Under steady conditions, the mean temperature difference between two defined surfaces of material or construction that induces unit heat flow through unit area. Note: Thermal resistance and thermal conductance are reciprocals. Thermal resistances are R-values; to obtain the U-factor, overall thermal transmittance, the R-value for either materials or constructions must first be evaluated because, by definition, the U-factor is the reciprocal of the R-value.

Thermal shock: Stress-producing phenomenon resulting from sudden temperature drop in a roof membrane when, for example, a rain shower follows brilliant sunshine.

Thermal shock factor (TSF): Mathematical expression for calculating the theoretical temperature drop required to split a rigidly held membrane sample under tensile constructive stress. (TSF=tensile strength at 0 divided by load strain modules at 0F times coefficient of expansion in temperature range of 0-30 degrees F.)

Thermal transmittance (U-factor): The time rate of heat flow per unit area under steady conditions from the fluid on the warm side of a barrier to the fluid on the cold side, per unit temperature difference between the two fluids. It is evaluated by first evaluating the R-value and then computing its reciprocal.

Thermoplastic: Changing viscosity under thermal cycling (fluid when heated, solid when cooled).

Thermosetting: Hardening permanently when heated, owing to cross-linking of polymeric resins into a rigid matrix.

Through-wall flashing: Water-resistant membrane or material assembly extending through a wall's horizontal cross section, and designed to direct flow through the wall toward the exterior.

Tiles: Roofing tiles are produced by baking plates of molded clay into tile, with density determined by the length of time heated and by heating

MIL-HDBK-1001/5

temperatures. Clay tile offers a wide range of design possibilities for residential roofs due to the variety of tiles available, i.e. roll tile and flat tile.

U-factor: See Thermal transmittance.

Vapor barrier: See Vapor Retarder.

Vapor migration: Flow of water vapor from a region of high vapor pressure to a region of lower vapor pressure.

Vapor retarder: A vapor-resistant layer of material applied to a surface to prevent vapor flow to a point where it may condense due to lower temperature.

Vent: Opening designed to convey water vapor, or other gas, from inside a building or building component to the atmosphere.

Vermiculite: Aggregate used in lightweight insulating concrete, formed by heating and consequent expansion of mica rock.

Viscoelastic: Characterized by changing mechanical behavior, from nearly elastic at low temperature to plastic, like a viscous fluid, at high temperature.

Viscosity: That property of semifluids, fluids, and gases by which they resist an instantaneous change of shape or arrangement of parts, the cause of fluid friction whenever adjacent layers of fluid move with relation to each other.

Walking in: Technique of manually forcing insulation boards against previously installed boards to tighten the joints and to embed board into a hot-applied adhesive.

Wood Trowel: Term applied to the finish of a structural concrete deck slab's surface by a manually operated wood float.

Wrinkling: See Ridging.

CUSTODIAN
NAVY - YD
ARMY

PREPARING ACTIVITY
NAVY - YD

PROJECT NO.
FACR-0264

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL (See Instructions - Reverse Side)	
1. DOCUMENT NUMBER MIL-HDBK-1001/5	2. DOCUMENT TITLE ROOFING AND WATERPROOFING
3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION (Mark one) <input type="checkbox"/> VENDOR <input type="checkbox"/> EFD/PWO <input type="checkbox"/> USER <input type="checkbox"/> AE <input type="checkbox"/> CONTRACTOR <input type="checkbox"/> MANUFACTURER <input type="checkbox"/> OOC/ROCC <input type="checkbox"/> OTHER (Specify): _____
b. ADDRESS (Street, City, State, ZIP Code)	
5. PROBLEM AREAS	
a. Paragraph Number and Wording:	
b. Recommended Wording:	
c. Reason/Rationale for Recommendation:	
6. REMARKS	
7a. NAME OF SUBMITTER (Last, First, MI) - Optional	b. WORK TELEPHONE NUMBER (Include Area Code) - Optional
c. MAILING ADDRESS (Street, City, State, ZIP Code) - Optional	d. DATE OF SUBMISSION (YYMMDD)

DD FORM 1426
62 MAR

PREVIOUS EDITION IS OBSOLETE.

NAVFAC Overprint

INSTRUCTIONS: In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge (DO NOT STAPLE), and mailed. In block 5, be as specific as possible about particular problem areas such as working which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE: This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or amend contractual requirements.

(Fold along this line)

(Fold along this line)

DEPARTMENT OF THE NAVY



NO POSTAGE
NECESSARY
IF MAILED
IN THE
UNITED STATES

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE \$300

BUSINESS REPLY MAIL

FIRST CLASS PERMIT NO. 12503 WASHINGTON D.C.

POSTAGE WILL BE PAID BY THE DEPARTMENT OF THE NAVY

COMMANDING OFFICER
CHESAPEAKE DIVISION (Code 406C)
NAVAL FACILITIES ENGINEERING COMMAND
WASHINGTON NAVY YARD
WASHINGTON, DC 20374-2121