

NOTICE OF CHANGE

MIL-HDBK-1004/2
NOTICE 1
15 FEBRUARY 1991

MILITARY HANDBOOK
POWER DISTRIBUTION SYSTEMS

TO ALL HOLDERS OF MIL-HDBK-1004/2:

1. THE FOLLOWING PAGES OF MIL-HDBK-1004/2 HAVE BEEN REVISED AND SUPERSEDE THE PAGES LISTED:

NEW PAGE	DATE	SUPERSEDED PAGE	DATE
xi	15 February 1991	xi	31 March 1988
xia	15 February 1991	xi	31 March 1988
xii	15 February 1991	xii	REPRINTED WITHOUT CHANGE
39	15 February 1991	39	31 March 1988
39a	15 February 1991	39	31 March 1988
40	15 February 1991	40	31 March 1988
40a	15 February 1991	40	31 March 1988

2. RETAIN THIS NOTICE AND INSERT BEFORE TABLE OF CONTENTS.

3. Holders of MIL-HDBK-1004/2 will verify that all changes indicated above have been made. This notice page will be retained as a check sheet. This issuance, together with appended pages, is a separate publication. Each notice is to be retained by stocking points until the military handbook is completely revised or canceled.

CUSTODIAN:
NAVY-YD

PREPARING ACTIVITY:
NAVY-YD

PROJECT NO.
FACR-1054

AMSC N/A

AREA FACR

DISTRIBUTION STATEMENT A. APPROVED FOR PUBLIC RELEASE: DISTRIBUTION
UNLIMITED

MIL-HDBK-1004/2
Change 1, 15 February 1991

	<u>Page</u>
5.2.3.2 Double-Ended	33
5.2.3.3 Secondary Spot-Network	35
5.2.4 Transformer Insulations	35
5.2.4.1 Dry-Type Units	35
5.2.4.2 Nondry-Type Units	35
5.2.4.3 Insulation Comparisons	35
5.2.5 Unit Substation Rooms	36
5.2.5.1 Drainage	36
5.2.5.2 Access	37
5.2.5.3 Ventilation	37
5.2.5.4 Noise	37
5.2.5.5 Emergency Lighting	37
5.3 Outdoor Utilization Voltage Substations	37
5.3.1 Secondary Unit Substation Types	37
5.3.2 Pad-Mounted Compartmental-Type Transformer Units	37
5.3.2.1 Units 500 Kilovolt-Amperes and Smaller	37
5.3.2.2 Units Larger than 500 Kilovolt-Amperes	37
5.4 Outdoor Distribution Voltage Substations	38
5.4.1 Structure-Mounted Equipment	38
5.4.2 Transformers	38
5.4.3 Connection to Primary Distribution Lines	38
5.5 Substation Considerations	38
5.5.1 Site Effects	38
5.5.2 Electric Configuration	38
5.5.3 Incoming-Line Switching	39
5.5.3.1 Circuit Breakers	39
5.5.3.2 Switches	39
5.5.3.3 Current Limiting Protectors	39
5.5.4 Outgoing-Feeder Switchgear	39
5.5.4.1 600 Volts and Less	39
5.5.4.2 Over 600 Volts	39a
5.5.5 Substation Structures	40
5.5.6 Transformers	40
5.5.6.1 Selection	40
5.5.6.2 Cooling	40
5.5.6.3 Transformer Capacity	40
5.5.6.4 Fire Protection	40
5.5.6.5 Transformer Noise	40
5.5.7 Lightning Protection	41
5.5.7.1 Classes	41
5.5.7.2 Types	41
5.5.7.3 Additional Requirements	41
5.5.8 Control Features	42
5.5.8.1 Instrumentation	42
5.5.8.2 Energy Monitoring	42
5.5.8.3 Control Cables	42
5.6 Working Space and Access Requirements	42

MIL-HDBK-1004/2
Change 1, 15 February 1991

	<u>Page</u>
5.6.1 Design	42
5.6.2 Existing Construction	42
5.7 Grounding	42
5.7.1 Grounding Electrode Systems	42
5.7.1.1 Girdle Type	43

MIL-HDBK-1004/2
Change 1, 15 February 1991

	<u>Page</u>
5.7.1.2 Grid Type	42
5.7.1.3 Special Techniques	43
5.7.2 Equipment Grounding	43
5.7.3 System Grounding	43
5.7.3.1 Neutral Grounding	43
5.7.3.2 Ground Fault Protection	43
5.7.4 Grounding Continuity	43
5.7.4.1 Fault Current	44
5.7.4.2 Portable Substations	44
5.8 Safety Considerations	44
5.8.1 Fencing	44
5.8.2 Metal Enclosures	44
5.8.3 Locking of Gates	44
5.8.4 Bonding of Gates	44
5.8.5 Legal Warning Signs	44
APPENDICES	
APPENDIX A SI Conversion Factors	45
FIGURES	
1 Duct Line Sections	18
2 Compartmental-Type Transformer Installation	29
3 Radial-Type Articulated Secondary Unit Substation Installation	30
4 Secondary Unit Substation Grounding	31
5 Preferred Design for a Transmission to Distribution (Primary) Substation	32
6 Secondary-Selective-Type Articulated Secondary Unit Substation Installation	34
TABLES	
1 Information Required for Circuit Design	4
2 Height and Class of Wood Poles	5
3 Wood Pole Sizes for Single Pole Transformer Installations	6
4 Conductor Sizes for Overhead Lines	7
5 Substation Terminology	27
6 Comparison of Types of Transformer Insulation	36
REFERENCES	47

MIL-HDBK-1004/2
Change 1, 15 February 1991

- c) overhead or underground supply required, and
- d) primary switching.

For feeder or load circuits, determine the following conditions:

- a) number of circuits,
- b) capacity of circuits,
- c) voltage and phase, and
- d) overhead or underground distribution required.

Finally, consider coordination of circuit protective devices between supply and feeder circuits.

5.5.3 Incoming-Line Switching. Design the substation with a minimum of incoming-line switching consistent with good maintenance and operation. For rating of equipment, refer to MIL-HDBK-1004/3, Switchgear and Relaying. Also, consider the methods described in paras 5.5.3.1 through 5.5.3.3.

5.5.3.1 Circuit Breakers. Circuit breakers should be utilized only when the circuit interrupting or relaying requirements do not allow the use of switches. Provide a disconnect and bypass switching features where drawout circuit breakers cannot be utilized.

5.5.3.2 Switches. Switches are covered in Section 2 of this handbook. For voltages of 15 kV or less, load interrupter or disconnect switches are available. Load interrupter switches disconnect circuits under fully loaded conditions and are therefore usually the most desirable choice. Use disconnect switches only to interrupt transformer exciting currents. The use of disconnect switches is not recommended, except for primary incoming lines where secondary circuit breakers can interrupt loads. Assure that operators do not open disconnect switches under load, either by interlocking with load switching equipment or by operating procedures.

5.5.3.3 Current Limiting Protectors. Current Limiting protection devices are covered in Section 2. They are generally inappropriate for substation use where metal-enclosed or metal-clad switchgear for 15-kV applications provides a more desirable design.

5.5.4 Outgoing-Feeder Switchgear. For ratings and selection of equipment, refer to MIL-HDBK-1004/3.

5.5.4.1 600 V and Less. For load circuits below 600 V, select from one of the following:

- a) metal-enclosed (low-voltage power) circuit breakers where reliability and the longer withstand rating period are desirable; or
- b) molded-case circuit breakers. Molded-case circuit breakers must be further defined as to tripping and interrupting currents and whether

MIL-HDBK-1004/2
Change 1, 15 February 1991

fully-rated capability or other features are desirable. The use of the term "insulated case" conveys no minimum requirements in accordance with any recognized industry specification and should not be used.

5.5.4.2 Over 600 Volts. For load circuits over 600 V, use criteria in

MIL-HDBK-1004/2
Change 1, 15 February 1991

MIL-HDBK-1004/3 to select from the following:

a) either oilless, metal-clad, medium-voltage circuit breakers, preferably of the vacuum circuit breaker type; or

b) grounded, metal-tank type, frame-mounted circuit breakers, with open disconnecting switches. Circuit breakers may be oil, gas, vacuum, or compressed air type. Oil-insulated type shall be installed only in outdoor locations and only for voltages exceeding 35 kV.

5.5.5 Substation Structures. Depending on the chosen design, the substation structure may consist of the following:

a) flat concrete base without elevated structures, applicable for underground supply and load circuits served by metal-clad switchgear;

b) steel or aluminum superstructures mounted on concrete piers; or

c) a combination of either of the aforementioned systems.

5.5.6 Transformers

5.5.6.1 Selection. Consider the types of insulation that are suitable for the site and the system voltages (see Table 6). Select oil-insulated for outdoor applications, except where fire safety considerations require the use of less-flammable, liquid-insulated insulation which is not usually available for voltages above 34.5 kilovolts. For indoor installations, see the paragraph on transformer insulations of this section.

5.5.6.2 Cooling. Forced cooled ratings are only available on larger size transformers and the designer should check their availability before specifying. Dependent upon standard ratings and overload capacity calculations, specify the cooling method from one of the following:

- a) self-cooled, type OA,
- b) one-stage forced-cooled, type FA,
- c) two-stage forced-cooled, type OA/FA,
- d) one-stage double-forced-cooled; forced-oil, forced-air, type

FOA, or

- e) triple-rated, types OA/FA/FOA/ or OA/FA/FA.

5.5.6.3 Transformer Capacity. Choose the transformer rating by considering the maximum load to be carried for normal and contingency conditions and the possibility of accepting overloading with accelerated loss of system life. Transformers should be sized for 10-25 percent more than calculated loads to minimize future growth costs.

MIL-HDBK-1004/2
Change 1, 15 February 1991

5.5.6.4 Fire Protection. For minimum safe distances of transformers to buildings and other fire protection criteria refer to MIL-HDBK-1008. Also refer to IEEE 979, Guide for Substation Fire Protection.

5.5.6.5 Transformer Noise. Specify transformer noise levels as given in NEMA TR-1. When standard noise levels are found to be too high, estimate the cost effectiveness of sound minimizing methods such as:

- a) specifying a transformer with a lower noise level,