

INCH-POUND
MIL-PRF-2939G(SH)

w/AMENDMENT 2

06 October 2015

SUPERSEDING

MIL-PRF-2939G
w/INT. AMENDMENT 1

09 May 2012

MIL-PRF-2939G

20 July 2001

PERFORMANCE SPECIFICATION

COOLING COILS, AIR, DUCT TYPE AND GRAVITY TYPE, NAVAL SHIPBOARD ENVIRONMENTAL CONTROL SYSTEMS

This specification is approved for use by the Naval Sea Systems Command and is available for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers duct type and gravity type air cooling coils for use in naval shipboard environmental control systems.

1.2 Classification. Air cooling coils are of the following classes, sizes, and compositions, as specified (see 6.2).

Class 1	Chilled water (DW), duct mounted
Class 3	Chilled Water (GW), gravity
Size:	Class 1 - 61-68
	Class 3 - 1G, 3G, 5G
Composition:	M - Magnetic
	N - Nonmagnetic

2. APPLICABLE DOCUMENTS

2.1 General. The documents listed in this section are specified in sections 3 and 4 of this specification. This section does not include documents cited in other sections of this specification or recommended for additional information or as examples. While every effort has been made to ensure the completeness of this list, document users are cautioned that they must meet all specified requirements documents cited in sections 3 and 4 of this specification, whether or not they are listed.

2.2 Government documents.

2.2.1 Specifications, standards, and handbooks. The following specifications, standards, and handbooks form a part of this document to the extent specified herein. Unless otherwise specified, the issues of these documents are those cited in the solicitation or contract.

Comments, suggestions, or questions on this document should be addressed to: Commander, Naval Sea Systems Command, ATTN: SEA 05S, 1333 Isaac Hull Avenue, SE, Stop 5160, Washington Navy Yard DC 20376-5160 or emailed to CommandStandards@navy.mil, with the subject line "Document Comment". Since contact information can change, you may want to verify the currency of this address information using the ASSIST Online database at <https://assist.dla.mil>.

MIL-PRF-2939G(SH)
w/AMENDMENT 2

DEPARTMENT OF DEFENSE SPECIFICATIONS

- MIL-S-901 - Shock Tests, H.I. (High-Impact) Shipboard Machinery, Equipment, and Systems, Requirements for
MIL-PRF-32514 - Anti-Sweat, Refrigerant, and Thermal Foam

DEPARTMENT OF DEFENSE STANDARDS

- MIL-STD-167-1 - Mechanical Vibrations of Shipboard Equipment (Type I - Environmental and Type II - Internally Excited)
MIL-STD-2142 - Magnetic Silencing Characteristics, Measurement of (Metric)

(Copies of these documents are available online at <http://quicksearch.dla.mil/>.)

2.2.2 Other Government documents, drawings, and publications. The following other Government documents, drawings, and publications form a part of this document to the extent specified herein. Unless otherwise specified, the issues of these documents are those cited in the solicitation or contract.

NAVAL SEA SYSTEMS COMMAND (NAVSEA) PUBLICATIONS

- S9074-AR-GIB-010/278 - Requirements for Fabrication, Welding and Inspection, Casting Inspection and Repair for Machinery, Piping and Pressure Vessels

(Copies of this document are available online via Technical Data Management Information System (TDMIS) at <https://mercury.tdmis.navy.mil/> by searching for the TMIN without the suffix. Refer questions, inquiries, or problems to: DSN 296-0669, Commercial (805) 228-0669. This document is available for ordering (hard copy) via the Naval Logistics Library <https://nll.ahf.nmci.navy.mil>. For questions regarding the NLL, contact the NLL Customer Service at nllhelpdesk@navy.mil, (866) 817-3130, or (215) 697-2626/DSN 442-2626.)

NAVAL SEA SYSTEMS COMMAND (NAVSEA) DRAWINGS

- 803-6397313 - Cooling coils, air, class I, duct mounted, chilled water, sizes 61 through 66
803-6397314 - Cooling coils, air, class I, duct mounted, chilled water, sizes 67 and 68
S3803-532636 - Cooling Coils, Gravity Type

(Copies of these documents are available from the applicable repositories listed in S0005-AE-PRO-010/EDM, which can be obtained online at <https://nll.ahf.nmci.navy.mil>, may be requested by phone at 215-697-2626, or may be requested by email at nllhelpdesk@navy.mil. Copies of these documents may also be obtained from the Naval Ships Engineering Drawing Repository (NSEDR) online at <https://199.208.213.105/webjedmics/index.jsp>. To request an NSEDR account for drawing access, send an email to [NNSY JEDMICS NSEDR HELP DESK@navy.mil](mailto:NNSY_JEDMICS_NSEDR_HELP_DESK@navy.mil).)

2.3 Non-government publications. The following documents form a part of this document to the extent specified herein. Unless otherwise specified, the issues of these documents are those cited in the solicitation or contract.

AIR CONDITIONING AND REFRIGERATION INSTITUTE (ARI) - DELETED

ASHRAE

- ASHRAE 25 - Methods of Testing Forced Convection and Natural Convection Air Coolers for Refrigeration
ASHRAE 33 - Methods of Testing Forced Circulation Air Cooling and Air Heating Coils

(Copies of these documents are available online at www.ashrae.org.)

ASME

MIL-PRF-2939G(SH)
w/AMENDMENT 2

ASME Boiler and Pressure Vessel Code - Section VIII – Rules for Construction of Pressure Vessels
Division 1

Section IX – Welding, Brazing, and Fusing Qualifications

(Copies of this document are available online at www.asme.org.)

ASTM INTERNATIONAL

DELETED

DELETED

ASTM A262 - Standard Practices for Detecting Susceptibility to Intergranular Attack in Austenitic Stainless Steels

ASTM F1166 - Standard Practice for Human Engineering Design for Marine Systems, Equipment, and Facilities

(Copies of these documents are available online at www.astm.org.)

AMERICAN WELDING SOCIETY (AWS)

AWS B2.1/B2.1M - Specification for Welding Procedure and Performance Qualification

AWS B2.2/B2.2M - Specification for Brazing Procedure and Performance Qualification

(Copies of these documents are available online at www.aws.org.)

SHEET METAL AND AIR CONDITIONING CONTRACTORS' NATIONAL ASSOCIATION, INC.
(SMACNA) - DELETED

NATIONAL ENVIRONMENTAL BALANCING BUREAU (NEBB)

NEBB Procedural Standards for Testing, Adjusting and Balancing of Environmental Systems

(Copies of this document are available online at www.nebb.org.)

2.4 Order of precedence. Unless otherwise noted herein or in the contract, in the event of a conflict between the text of this document and the references cited herein, the text of this document takes precedence. Nothing in this document, however, supersedes applicable laws and regulations unless a specific exemption has been obtained.

3. REQUIREMENTS

3.1 Qualification. Coils furnished under this specification shall be products that are authorized by the qualifying activity for listing on the applicable qualified products list before contract award (see 4.2 and 6.3).

3.2 Materials. Materials shall be corrosion-resistant or material shall be protected against corrosion after fabrication. Material degraded during the fabrication process shall be normalized to restore any recoverable properties before being assembled in any cooling coil. Selected materials shall be capable of meeting all of the operational and environmental requirements specified herein.

3.2.1 Hazardous materials. Materials for use in the construction of cooling coils shall have no effect on the health of personnel when the materials are used for their intended purpose. Regardless of other requirements, materials and parts containing asbestos, cadmium, lithium, mercury, or radioactive material shall not be used.

3.2.2 Fasteners. Material for all bolts, nuts, studs, screws, and similar fasteners shall be corrosion-resistant, passivated, or of a material rendered resistant to corrosion. Sheet metal screws shall not be used. Galling shall be prevented. Tapped holes shall be reinforced where shearing of thread can occur.

3.2.3 Dissimilar metals. Cooling coils shall not be degraded due to electrolysis (see 6.7).

MIL-PRF-2939G(SH)
w/AMENDMENT 2

3.2.4 Nonmagnetic material. When nonmagnetic cooling coils are specified (see 6.2), parts shall be fabricated of nonmagnetic material which has a permeability of less than 2.0 (Air = 1.0) after fabrication.

3.2.5 Recycled, recovered, environmentally preferable, or biobased materials. Recycled, recovered, environmentally preferable, or biobased materials should be used to the maximum extent possible, provided that the material meets or exceeds the operational and maintenance requirements, and promotes economically advantageous life cycle costs.

3.3 Painting. Equipment and component items shall be delivered with the manufacturer's standard finish, except as to comply with the requirements of 3.2.

3.4 Welding, brazing, and allied processes. Surfaces of parts to be welded or brazed shall be free from rust, scale, paint, grease, and other foreign matter. Welding and allied processes shall be performed by personnel certified to AWS B2.1/B2.1M and B2.2/B2.2M or ASME Boiler and Pressure Vessel Code, Section IX standards. NAVSEA Technical Publication S9074-AR-GIB-010/278 may be used for guidance.

3.5 Identification. Each type of cooling coil shall be provided with a permanently attached corrosion-resistant identification plate. Attachment method shall be corrosion-resistant. The plate shall contain the following information:

- a. Nomenclature (U.S. Navy Standard Cooling Unit).
- b. Size (see 3.13.2).
- c. Part or identifying number (see 3.5.1).
- d. Manufacturer's part number, name, and address.

3.5.1 Part or identifying number (PIN). Cooling coils should be identified by a code number arranged sequentially by specification number, class, size, and composition as defined in 1.2 and the following example:



3.6 Interchangeability. In no case shall parts be physically interchangeable or reversible unless such parts are also interchangeable or reversible with regard to function, performance, and strength.

3.7 Operating life. The equipment shall have an operating life of 40 years (see appendix C).

3.8 Reliability. DELETED.

3.9 Workmanship. The cooling coils shall be free from defects that affect appearance and operation. Tube sheets shall not show cracks from punching or forming and fin collars (if used) shall not show cracks after tubes are expanded into collars. Fin edges shall be free of burrs and not be bent. Casing corners shall be square. Flanges shall be parallel and smooth.

3.10 Human engineering. The cooling coils shall be arranged so as to achieve safe, reliable, and effective performance by the operator and maintenance personnel and to optimize personnel skill requirements. ASTM F1166 may be utilized as a guideline in applying human engineering design criteria for the cooling coils.

3.11 Maintainability. The cooling coils shall be constructed so that (see 6.2):

- a. The leading edges of the cooling elements can stand brushing for cleaning without bending. Brushing shall be in the direction of the fins with a nylon scrub brush with a minimum 0.012-inch diameter bristles.

MIL-PRF-2939G(SH)
w/AMENDMENT 2

b. Without bending of the cooling element or other damage to the cooling coil, the coil can be cleaned by a pressure driven washer at pressures up to 1000 pounds per square inch (lb/in^2) at a flow rate of 2.2 gallons per minute using a 15-degree nozzle and an environmentally safe cleaning mixture. The flow shall be directed parallel to the fins.

c. The condensate system can be cleaned without disassembly of the cooling coil.

d. The cooling coil is drainable to prevent freezing when subject to air below 32 °F. The water shall drain to the cooling coil condensate system.

e. The cooling coil is capable of being vented of air. Any water coming from the vent shall be collected by the cooling coil condensate system. There shall be means to provide visual indication of flow in the vent.

3.12 General shipboard design conditions. General shipboard design characteristics shall be as follows:

a. Entering dry bulb (DB) temperatures of 75 °F minimum to 105 °F maximum.

b. Entering wet bulb (WB) temperatures of 59 °F minimum to 102 °F maximum.

c. Entering chilled water temperature of 45 °F.

d. Chilled water flow rate of 3.6 gallons per minute per ton of refrigeration.

e. Replenishment air introduced to duct type cooling coil is sea air at 40 °F to 105 °F dry bulb.

f. The cooling coil shall perform and condensate shall drain without degradation when the coil is subjected to a permanent tilt of 15 degrees in any direction.

3.12.1 Shock. Unless otherwise specified in 6.2, cooling coils shall meet the shock requirements of MIL-S-901 Grade A, Class I equipment.

3.12.2 Vibration. The cooling coils shall meet the environmental vibration requirements of MIL-STD-167-1.

3.13 Cooling coils. Duct mounted type.

3.13.1 General design. The cooling coils supplied under this specification shall use chilled water for the cooling and dehumidification of air. The cooling coils shall be built as a single unit consisting of supporting framework, drain pan, and cooling element. Each cooling coil shall be ready for installation and connection to the appropriate water supply and return lines and condensate drainage piping. The following drawings define cooling coil interfaces and principal dimensions for replaceability and may be used for guidance: NAVSEA drawings 803-6397313 - Cooling coils, air, Class I, duct-mounted, chilled water, Sizes 61 through 66 and 803-6397314 - Cooling coils, air, Class I, duct mounted, chilled water, Sizes 67 and 68.

3.13.2 Sizes. Sizes of cooling coils shall be limited to those listed in [table I](#).

MIL-PRF-2939G(SH)
w/AMENDMENT 2

TABLE I. Chilled water cooling coil capacities (nominal).

Coil Size	Airflow ft ³ /min Velocity (ft/min)	Leaving air temperatures in DB/WB	Capacity MBH
61	280 (491)	58.7/57.2	8.69
62	450 (500)	56.3/55.2	16.49
63	670 (496)	54.9/53.9	27.11
64	975 (488)	54.7/53.6	40.07
65	1450 (485)	52.4/52.0	65.68
66	2500 (500)	51.2/51.0	120.0
67	3800 (507)	52.0/51.6	181.9
68	5000 (500)	51.3/51.0	239.8

The cooling coils shall perform in the total range specified in appendix A. For test purposes, cooling coils are tested either in accordance with [table I](#) or for conditions from appendix A as specified by contracting activity (see 6.2).

3.13.3 Capacity. The capacity of the chilled water cooling coils shall be not less than the capacities listed in [table I](#) for the following conditions: entering water temperature equals 45 °F, leaving water temperature equals 51.67 °F, gallons per minute (gal/min) per ton of cooling equals 3.6, and entering air temperature equals 80 °F dry bulb (DB) 67 °F wet bulb (WB). Capacity shall be based on counter flow of water and air streams.

3.13.4 Performance range. The performance range of the cooling coil shall be in accordance with [table II](#). In lieu of the conditions specified in [table I](#), the contracting activity may substitute the conditions in appendix A (see 6.2). In the performance range stated in [table II](#) and the Nominal Capacity in [table I](#), the air pressure drop in inches of water for the air passing through the coil shall be in accordance with figures [1](#) and [2](#). The water pressure drop in feet of water of the cooling water passing through the coil shall be in accordance with figures [3](#) and [4](#).

3.13.5 Physical dimensions. Mounting dimensions, duct connection dimensions, width, and depth dimensions shall be in accordance with [table III](#).

3.13.6 Air tightness. The cooling coil, when connected to ductwork, shall be airtight when subjected to an air pressure of 4 inches water gauge within the duct system.

3.13.7 Water tightness. Cooling coils shall not leak water.

3.13.8 Air distribution. The outlet air flow of the cooling coil shall be uniform across the face of the coil shown on [table III](#).

3.13.9 Water flow. Water flow in tubes or other flow devices shall be turbulent throughout its performance range. Turbuspirals or other devices may be used to achieve this requirement. If turbuspirals are used they shall have a uniform pitch of at least 16 turns per linear foot of tube and shall fit securely against the inside surface of each tube.

MIL-PRF-2939G(SH)
w/AMENDMENT 2

4.6

MIL-PRF-2939G(SH)
w/AMENDMENT 2




FIGURE 3. Water pressure drop, 60 DW series (high range).

MIL-PRF-2939G(SH)
w/AMENDMENT 2




FIGURE 4. Water pressure drop, 60 DW series (low range).


TABLE II. 60 DW series performance range.

EDB (°F)		75	80	85	90	95	100	105
EWB Range (°F)		59-72	61-77	63-82	65-87	67-92	69-97	71-102
Coil Size	Airflow Range (CFM)	Range of Total Load (MBH)						
61	160-360	3.55-15.47	4.09-21.05	4.82-27.31	5.56-34.35	6.30-42.27	7.03-51.18	7.77-61.23
62	240-555	5.63-27.97	6.79-37.29	7.95-47.73	9.11-59.45	10.27-72.64	11.81-87.5	13.22-104.2
63	390-830	9.61-45.38	11.51-59.58	13.40-75.46	15.29-93.28	17.76-113.3	20.01-135.9	22.38-161.3
64	525-1125	13.03-62.90	15.57-82.27	18.11-103.9	20.64-128.3	24.10-155.6	27.16-186.4	30.40-221.2
65	850-1750	23.59-105.7	28.11-138.2	33.44-174.2	38.51-215.2	43.81-261.1	49.38-312.8	55.22-371.1
66	1300-2700	37.45-175.8	45.63-228.2	53.34-286.8	61.37-352.6	69.75-426.6	78.54-510.1	87.79-604.5
67	2200-4200	62.87-271.6	76.44-352.7	89.29-443.4	102.7-545.2	116.7-659.8	131.4-788.9	146.8-935.0
68	2500-5500	72.10-356.7	87.92-463.1	102.8-582.1	118.3-715.7	134.4-866.0	151.4-1035.5	169.2-1227.2

MIL-PRF-2939G(SH)
w/AMENDMENT 2
DRAFT DATED 29 September 2015

TABLE III. Physical dimensions.

Size	Face Area sq ft	Dry Wt Max Lbs.	A In.	B In.	C In.	D In.	E In.	F In.	G In.	H In.
61	.57	106	15	13.75	11.75	7.0	12.12	13.25	x	x
62	.90	118	15	13.75	14.00	9.25	14.38	15.50	x	x
63	1.35	169	15	13.75	21.00	9.25	14.38	22.50	x	x
64	2.00	212	15	13.75	25.00	11.5	16.62	26.50	x	x
65	3.00	280	15	13.75	31.5	13.75	18.88	33.0	16.5	x
66	5.00	404	15	13.75	39.5	18.25	23.38	41.0	13.68	13.62
67	7.50	766	17.63	16.	39.5	28.44	34.25	41.12	13.75	13.62
68	10.0	830	17.63	16.	39.5	37.44	43.25	41.12	13.75	13.62



Class 1 cooling coil interface dimensions

3.13.10 Headers. The cooling coils shall have a supply header and a return header. The headers shall be enclosed within the coil end cover but not in the air stream. The headers shall be secure to the coil end cover to relieve the header joints from stresses due to external pipe whip. The supply and return connections to the chilled water system shall be union connections or other connections meeting the flexibility and strength requirements of union type connections. Connections shall be rated for a service pressure of 300 lb/in². The complete union or other connection shall be supplied with the cooling coil.

3.13.11 Hangers. Hangers shall have a tensile strength of at least 85,000 lb/in² and a yield strength of at least 35,000 lb/in².

3.13.12 Cooling element support. Intermediate supports shall be provided for the cooling elements as necessary to prevent piping from sagging, and to satisfy vibration and shock requirements.

3.13.13 Coil baffle. Baffles or other means shall be built into the cooling coil to prevent condensate draining to the coil bottom from being blown into connecting ductwork.

3.13.14 Cooling element. The cooling element shall be of the extended surface type. Tubes shall be not less than .625-inch OD. The number of rows in direction of air flow shall not be less than six. Tubes when passing through supports shall be protected from wear due to shipboard vibration and thermal expansion and contraction of the tubes. In order to suit interface and replaceability considerations, guidance in determining circuiting of cooling element shall be obtained from drawings 803-6397313 and 803-6397314 for the sizes specified.

MIL-PRF-2939G(SH)
w/AMENDMENT 2

3.13.15 Fins. Fins, if used, shall be of the continuous plate type and shall be uniformly spaced with the number of fins per linear inch of tube not less than 8 or more than 8-1/2. The fins shall be in positive contact with the tubes.

3.13.16 Brazing. Piping connections shall be brazed.

3.13.17 Intermediate and bottom drain pans. When an intermediate drain pan is required, drain tubes shall be used to drain the intermediate drain pan into the bottom drain pan. Baffles are required as specified in 3.13.13. Drain pans shall be integral parts of the cooling coil. A one-inch ID drain connection, suitable for hose connections, shall be provided at each end of the bottom drain pan.

3.13.18 End covers and access panels. End covers and access covers, if required, shall meet the requirements of 3.13.6.

3.13.19 Bolt holes. In order to suit interface and replaceability considerations, bolt holes in casing flanges shall be spaced from the corner holes on 3-inch centers. Where space between the centerline and the adjacent bolt holes exceeds 2 inches, locate a hole on the centerline. Mounting holes shall be threaded 0.375 by 16 UNC-2B and the strength of the method selected shall be equal to or greater than the method shown on 803-6397313 and 803-6397314. Holes that are friction drilled or formed in austenitic stainless steel where the metal is heated shall meet the requirements of ASTM A262, Practice A, performed at an independent laboratory accredited to National Aerospace and Defense Contractors Accreditation Program (Nadcap) or American Association for Laboratory Accreditation (A2LA).

3.13.20 U-bends. If U-bends are used, bending of the tube material shall not reduce the wall thickness to less than 0.025 inch after fabrication. This is to minimize erosion.

3.13.21 Insulation. The duct type cooling coils shall be insulated. Unless otherwise specified (see 6.2), insulation shall meet the requirements of MIL-PRF-32514 and shall meet the thicknesses indicated on 803-6397313 and 803-6397314. For the 0.25-inch insulation, 0.5-inch insulation may be used; and for the 0.625-inch insulation, 0.75-inch insulation may be used.

3.13.22 Flanges. Joints of duct flanges shall be made airtight and smooth by welding and grinding to receive matching duct flanges.

3.14 Gravity coils.

3.14.1 General design. The gravity coils supplied under this specification shall use chilled water for the cooling and dehumidification of air. The gravity coils shall be built as a single unit consisting of supporting framework, drain pans, and cooling element. Each gravity coil shall be ready for installation and connection to the appropriate water supply and return lines and condensate drainage piping. NAVSEA drawing S3803-532636 defines gravity coil interfaces and principal dimensions for replaceability.

3.14.2 Sizes. To permit replacement, sizes of gravity coils shall be limited to those listed in [table IV](#).

TABLE IV. Gravity Coil Sizes.

Coil Size	Air Surface Sq Ft	Maximum Weight
1G	25	46
3G	77	107
5G	127	168

3.14.3 Capacity. The capacity of the gravity coils shall not be less than the capacities indicated in figures [5](#) and [6](#) for the following conditions: Entering water temperature equals 45 °F; ambient air at 85 °F dry bulb and 71 °F wet bulb. Chilled water pressure drop through the gravity coil shall not exceed the values shown in [figure 7](#). The coil shall be capable of this performance when the cooling element is 4 inches from an overhead obstruction or ceiling.

MIL-PRF-2939G(SH)
w/AMENDMENT 2

3.14.4 Physical dimensions. Mounting dimensions, width, and depth dimensions shall not exceed those listed in [table V](#).

TABLE V. Physical dimensions.

Coil Size	Width of Cooling Element (in)	Length of Cooling Element (in)	Depth of Assembly (in)
1G	11-5/8	22	9-1/2
3G	17-5/8	44	9-1/2
5G	23-5/8	54	9-1/2

3.14.5 Water tightness. Gravity coils shall not leak water.

3.14.6 Couplings. Couplings shall be attached to the drain pan on both sides of coil for connection to the appropriate shipboard drainage.

3.14.7 Supports. Supports for cooling element shall be no further apart than 19 inches.






FIGURE 5. Gravity coil performance.

MIL-PRF-2939G(SH)
w/AMENDMENT 2FIGURE 6. Gravity coil performance range.

MIL-PRF-2939G(SH)
w/AMENDMENT 2



Note: Pressure drop is for coil only; does not include pressure drop through controls.

FIGURE 7. Gravity coil chilled water pressure drop.

3.14.8 Drain pan. The drain pan shall be attached to the coil frame for easy access and removal and shall be manufactured from corrosion-resistant material.

3.14.9 Tubes. In order to suit water pressure drop requirements shown in [figure 7](#), tubes shall not be less than 5/8-inch OD. Where tubes pass through supports provision shall be made to prevent wear on tubes due to shipboard vibration and thermal expansion and contraction of the tubes.

3.14.10 Fins. Fins shall be of the continuous plate type. Fins shall be spaced not less than 3 nor more than 3-1/2 per inch per linear foot of tube. Tubes shall be in positive contact with the fins.

4. VERIFICATION

4.1 Classifications of inspections. The inspection requirements specified herein are classified as follows:

- a. Qualification inspection (see 4.2).
- b. Conformance inspection (see 4.3).
- c. DELETED.

MIL-PRF-2939G(SH)
w/AMENDMENT 2

4.2 Qualification inspection. Qualification inspection shall consist of the examinations of 4.6 and tests as specified in [table VI](#).

4.3 Conformance inspection. Conformance inspection shall consist of the examinations of 4.6 and tests as specified in [table VI](#).

TABLE VI. Test agenda.

Tests	Requirements	Verification	Qualification	Conformance
Visual and Dimensional	3.2, 3.13, 3.14	4.5	all	-----
Operating Life	3.7	4.6.1	^{1/}	-----
Maintainability	3.11	4.6.2	all	-----
Nonmagnetic	3.2.4	4.6.3	all, (NM)	all, (NM)
Air Tightness	3.13.6	4.6.4	^{2/}	-----
Capacity	3.13.3, 3.14.3	4.6.5	^{3/}	-----
Distribution	3.13.8	4.6.6	^{2/}	-----
Leakage	3.13.7, 3.14.5	4.6.7	all	all
Vibration	3.12.2	4.6.8	all ^{4/}	-----
Shock	3.12.1	4.6.9	all ^{4/}	-----

NOTES:

^{1/} Study will qualify all sizes of Class 1 and 3 cooling coils.

^{2/} First unit of each size of Class 1 cooling coil.

^{3/} First unit of each size of Class 1 and 3 cooling coils.

^{4/} First unit of each size of Class 1 and 3 cooling coils. Qualifying Size 64 also qualifies Sizes 61, 62, and 63; qualifying Size 66 also qualifies Size 65; and qualifying Size 68 also qualifies Size 67. Qualification of Size 5G also qualifies Sizes 1G and 3G.

4.4 Periodic conformance inspection. DELETED.

4.5 Examinations. Cooling coils in Class 1 and 3 shall be examined and measured to verify compliance with the requirements of this specification not involving tests. Examination shall be conducted as specified in 4.5.1, 4.5.2, and [table VII](#). Any unit in the sample containing one or more defects shall not be offered for delivery.

4.5.1 Lot. All cooling coils of the same size and type offered for delivery at one time shall be considered a lot.

4.5.2 Sampling for examination. A random sample of cooling coils shall be selected from each lot in accordance with [table VIII](#) for the examinations specified in 4.5.

MIL-PRF-2939G(SH)
w/AMENDMENT 2

TABLE VII. Classification of defects.

Categories	Defects	Related Requirements Paragraph
Critical	None defined.	-----
Major		
101	Size, class, and type not as specified.	3.13.2, 3.14.2
102	Physical dimensions not as specified or limiting dimensions exceeded.	3.13.5, 3.14.4
103	Material defective or not as specified.	3.2
104	Incomplete, component parts missing, or improperly assembled.	3.9
105	Corners of flanges not smooth and airtight.	3.13.22
106	Flange holes for duct not as specified.	3.13.19
107	Drain pan missing or not as specified.	3.13.17, 3.14.8
108	Connections on drain pan not as specified.	3.13.17, 3.14.6
109	Bolts, nuts, and screws not tight or missing (parts shall be properly fastened and secured).	3.9
110	Mounting dimensions for mounting hangers or support channels not as specified.	3.13.5, 3.14.1
111	Welding incomplete, not continuous, not free of cracks, non-fusion, heavy porosity, heavy undercut, slag inclusions, improper weld metal.	3.4
112	Tube construction not as specified.	3.13.14, 3.14.9
113	Headers not secured to coil end cover.	3.13.10
114	Fin collars (if applicable) and tube sheets not free of cracks and burrs.	3.9
115	Vent and drain lines not as specified.	3.11.d, 3.11.e
116	Brazing material not as specified or brazing of poor quality.	3.4
117	Thermal insulation missing or not as specified.	3.13.21
118	Marking, identification plate incomplete, missing, not permanent, illegible, or not as specified.	3.5
119	Workmanship not conforming to the specification.	3.9
Minor	None defined.	-----

4.6 Tests. Tests shall be conducted in accordance with 4.6.1 through 4.6.9 (see 6.2 and appendix D).

4.6.1 Operating life. Operating life shall be verified to determine that the equipment meets the requirements of 3.7 (see appendix C).

MIL-PRF-2939G(SH)
w/AMENDMENT 2

TABLE VIII. Sampling for examination.

Lot Size Number of Coils	Sample Size Number of Coils
1 to 6	All
7 to 15	7
16 to 25	10
26 to 40	13
41 to 65	17
66 to 110	22
111 to 180	28
181 to 300	35
301 to 500	45

4.6.2 Maintainability. The first production unit shall be examined after testing and the capability to maintain and be maintained shall be demonstrated. The demonstration shall be conducted utilizing the recommended tools and with other than expert mechanics. Evidence that maintainability of the cooling coil assembly cannot be accomplished by other than expert mechanics shall be cause for failure of the demonstration. The maintainability demonstration shall include the requirements of 3.11.

4.6.3 Nonmagnetic. A permeability test of nonmagnetic material used in construction of the Class 1 and 3 cooling coils shall be conducted in accordance with MIL-STD-2142, Test 501 (see 3.2.4) when nonmagnetic cooling coils are specified (see 6.2).

4.6.4 Air tightness. The cooling coil Class 1 shall have blanking plates and gaskets bolted to entering and leaving face of the cooling coil and drain connections sealed. An air connection shall be provided in one of the face blanking plates to pressurize the cooling coil to 4 inches of water. The cooling coil shall show no drop in pressure for 20 minutes.

TABLE VI. Test Agenda. DELETED.

4.6.5 Capacity. The capacity of each size cooling coil Class 1 shall be determined at the conditions specified in 3.13.3, or those conditions that may be substituted by the contracting activity using appendix A (see 6.2). The capacity tests of the Class 1 cooling coil shall be conducted in accordance with ASHRAE 33. The capacity of each size Class 3 cooling coil shall be determined at the conditions specified in 3.14.3. The capacity tests of the Class 3 cooling coil shall be conducted in accordance with ASHRAE 25.

4.6.6 Distribution. The distribution of the air leaving the class 1 cooling coil shall be tested to ensure uniform air distribution across the face of the coil. The air velocity across the face of the coil during this test shall not be less than 400 ft/min. Measurements shall be taken at 12 inches from the coil face. The average air velocity shall vary not more than 20 percent between any two points of the coil face. Measurement techniques shall be in accordance with NEBB Procedural Standards for Testing, Adjusting and Balancing of Environmental Systems.

4.6.7 Leakage. The Class 1 and 3 cooling coils shall be tested for leakage in accordance with ASME Boiler and Pressure Vessel Code, section VIII, division I for a working pressure of 200 lb/inch². Any coil element in which there is evidence of leakage when tested shall not be offered for delivery.

**MIL-PRF-2939G(SH)
w/AMENDMENT 2**

4.6.8 Vibration. Cooling coils shall be subjected to Type I environmental vibration tests as specified in MIL-STD-167-1. The exploratory vibration test specified in MIL-STD-167-1 shall include frequencies up to and including 33 hertz (Hz) at the table amplitude specified therein. The vibration test shall be conducted prior to the tests specified in 4.6.4 through 4.6.7. The cooling coil shall not be damaged or malfunction as a result of environmental vibration test.

4.6.9 Shock test. Cooling coils shall be shock tested on the medium weight machine as specified for Type A in accordance with MIL-S-901 if its weight with fixture and mounting bracket exceeds 550 pounds or if the mounting bracket extends beyond the anvil; otherwise, they shall be shock tested on the light weight machine as specified for Type A in accordance with MIL-S-901. A hydrostatic pressure of a least 100 lb/in² shall be maintained on the cooling element of the cooling coil during the shock tests. The shock test shall be conducted prior to the tests specified in 4.6.3 through 4.6.7 and after test in 4.6.8. Further testing shall not be performed until the cooling coil passes the shock test. Evidence of fragmentation or missile effects of parts, deformation of parts that will cause active interference between parts, or leakage of the cooling element, shall be cause for rejection.

4.6.10 Failures. Failure to pass all inspections specified in table VI shall be cause for rejection of units. The ability to rework failed units shall be at the discretion of the contracting activity.

5. PACKAGING

5.1 Packaging. For acquisition purposes, the packaging requirements shall be as specified in the contract or order (see 6.2). When packaging of materiel is to be performed by DoD or in-house contractor personnel, these personnel need to contact the responsible packaging activity to ascertain packaging requirements. Packaging requirements are maintained by the Inventory Control Point's packaging activities within the Military Service or Defense Agency, or within the military service's system commands. Packaging data retrieval is available from the managing Military Department's or Defense Agency's automated packaging files, CD-ROM products, or by contacting the responsible packaging activity.

6. NOTES

(This section contains information of a general or explanatory nature that may be helpful, but it is not mandatory).

6.1 Intended use. Duct type cooling coils are intended for use in heating, ventilation and air conditioning systems on board Navy ships. Gravity type cooling coils are intended for use in magazine spaces on board Navy ships.

6.2 Acquisition requirements. Acquisition documents must specify the following:

- a. Title, number, and date of this specification.
- b. Class and size required (see 1.2, 3.13.2, 3.14.2).
- c. DELETED.
- d. Whether non-magnetic cooling coils are required (see 3.2.4).
- e. DELETED.
- f. Shock grade (see 3.12.1).
- g. For class 1 cooling coils capacity test conditions if other than as specified in 3.13.3 (see 3.13.4 and appendix A).
- h. Insulation (see 3.13.21).
- i. Level of preservation and packaging (see 5.1)
- j. Drawing approval required (see 6.4)
- k. DELETED.

MIL-PRF-2939G(SH)
w/AMENDMENT 2

6.3 Qualification. With respect to products requiring qualification, awards will be made only for products which are, at the time of award of contract, qualified for inclusion in Qualified Products List QPL No. 2939 whether or not such products have actually been so listed by that date. The attention of the contractors is called to these requirements, and manufacturers are urged to arrange to have the products that they propose to offer to the Federal Government tested for qualification in order that they may be eligible to be awarded contracts or orders for the products covered by this specification. Information pertaining to qualification of products may be obtained from Commander, Naval Sea Systems Command, ATTN: SEA 05S, 1333 Isaac Hull Avenue, SE, Stop 5160, Washington Navy Yard DC 20376-5160 or emailed to CommandStandards@navy.mil. An online listing of products qualified to this specification may be found in the Qualified Products Database (QPD) at <https://assist.dla.mil>.

6.3.1 Waiving of requirement for qualification testing. The Government reserves the right to waive the requirement for qualification testing to those bidders offering a product that has been previously approved to this specification, and these units may be included in the QPL.

6.4 Approval. The contract should require (see 6.2) drawings of each size and class of each cooling coil assembly to be submitted for approval by the acquisition activity unless the drawings have been previously approved.

6.5 Final drawings. DELETED.

6.6 Technical manuals. DELETED.

6.7 Recommended practices. The following documents provide information for the design, manufacture, testing, and qualification of cooling coils and gravity coils previously supplied to the United States Navy, and may be used for guidance:

- a. MIL-C-2939 – Cooling Coils, Air, Duct Type and Gravity Type, Naval Shipboard Environmental Control Systems
- b. NAVSEA Drawing 803-6397313 – Cooling Coils, Air, Class I, Duct Mounted, Chilled Water, Sizes 61 through 66
- c. NAVSEA Drawing 803-6397314 – Cooling Coils, Air, Class I, Duct Mounted, Chilled Water, Sizes 67 through 68
- d. NAVSEA Drawing S3803-532636 – Gravity Coils, Sizes 1, 2, and 3
- e. MIL-STD-889 – Dissimilar Metals

6.8 Subject term (key word) listing.

Air Conditioning

Chilled water

Dehumidifying

Heating

HVAC

Ventilation

6.9 Amendment notations. The margins of this specification are marked with vertical lines to indicate modifications generated by this amendment. This was done as a convenience only and the Government assumes no liability whatsoever for any inaccuracies in these notations. Bidders and contractors are cautioned to evaluate the requirements of this document based on the entire content irrespective of the marginal notations.

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A
PERFORMANCE REQUIREMENTS FOR SERIES 60 COOLING COILS

Key for Reading Performance Tables

CFM	cubic feet per minute
FPM	feet per minute
EDB	entering dry bulb (°F)
EWB	entering wet bulb (°F)
MBH	BTU/hr (in thousands)
LDB	leaving dry bulb (°F)
LWB	leaving wet bulb (°F)
SHR	sensible heat ratio

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 61
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	AIRFLOW								AIR TEMP						
			160 CFM (FPM = 281)				180 CFM (FPM = 316)				200 CFM (FPM = 351)				(F)	EDB	EWB
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR			
75	59	3.35	55.9	51.3	1.000	3.74	56.0	51.4	1.000	4.13	56.1	51.4	1.000	75	59		
75	60	3.35	55.9	52.5	1.000	3.75	56.0	52.5	1.000	4.13	56.1	52.6	1.000	75	60		
75	61	3.35	55.9	53.6	1.000	3.75	56.0	53.7	1.000	4.14	56.1	53.7	1.000	75	61		
75	62	3.62	55.9	54.2	0.930	4.01	56.0	54.3	0.938	4.40	56.0	54.4	0.946	75	62		
75	63	3.87	56.3	54.8	0.849	4.28	56.5	55.0	0.857	4.68	56.6	55.1	0.865	75	63		
75	64	4.19	56.7	55.3	0.770	4.63	56.8	55.5	0.778	5.05	57.0	55.6	0.786	75	64		
75	65	4.59	56.8	55.6	0.698	5.06	57.0	55.8	0.704	5.51	57.2	56.0	0.711	75	65		
75	66	5.04	56.9	55.9	0.633	5.55	57.1	56.1	0.639	6.05	57.3	56.3	0.644	75	66		
75	67	5.50	57.0	56.1	0.579	6.07	57.2	56.4	0.583	6.61	57.5	56.6	0.586	75	67		
75	68	5.97	57.1	56.4	0.531	6.59	57.3	56.6	0.534	7.18	57.6	56.9	0.537	75	68		
75	69	6.46	57.1	56.6	0.490	7.12	57.4	56.9	0.492	7.77	57.7	57.1	0.494	75	69		
75	70	6.95	57.2	56.9	0.454	7.67	57.5	57.2	0.455	8.37	57.8	57.4	0.456	75	70		
75	71	7.45	57.3	57.1	0.422	8.23	57.6	57.4	0.422	8.99	57.9	57.7	0.423	75	71		
75	72	7.97	57.4	57.4	0.393	8.80	57.7	57.7	0.393	9.62	58.0	58.0	0.393	75	72		
80	61	4.09	56.7	51.9	1.000	4.57	56.8	51.9	1.000	5.05	56.9	52.0	1.000	80	61		
80	62	4.09	56.7	53.1	1.000	4.57	56.8	53.1	1.000	5.05	56.9	53.2	1.000	80	62		
80	63	4.09	56.7	54.3	1.000	4.58	56.8	54.3	1.000	5.06	57.0	54.4	1.000	80	63		
80	64	4.44	56.7	54.7	0.923	4.92	56.8	54.8	0.931	5.41	56.9	54.9	0.938	80	64		
80	65	4.72	57.1	55.3	0.852	5.22	57.3	55.5	0.860	5.72	57.4	55.6	0.868	80	65		
80	66	5.07	57.5	55.7	0.783	5.60	57.6	55.9	0.791	6.12	57.8	56.1	0.798	80	66		
80	67	5.49	57.6	56.1	0.719	6.05	57.9	56.3	0.726	6.61	58.1	56.5	0.732	80	67		
80	68	5.95	57.7	56.3	0.661	6.57	58.0	56.6	0.667	7.16	58.2	56.8	0.672	80	68		
80	69	6.44	57.8	56.6	0.610	7.10	58.1	56.9	0.614	7.75	58.3	57.1	0.619	80	69		
80	70	6.93	57.9	56.8	0.565	7.65	58.2	57.1	0.569	8.35	58.4	57.4	0.572	80	70		
80	71	7.43	58.0	57.1	0.526	8.21	58.3	57.4	0.528	8.96	58.5	57.7	0.531	80	71		
80	72	7.95	58.1	57.4	0.490	8.78	58.4	57.7	0.492	9.59	58.7	58.0	0.494	80	72		
80	73	8.47	58.2	57.7	0.459	9.37	58.5	58.0	0.460	10.24	58.8	58.3	0.461	80	73		
80	74	9.01	58.3	57.9	0.430	9.97	58.6	58.3	0.430	10.90	58.9	58.6	0.431	80	74		
80	75	9.56	58.3	58.2	0.404	10.58	58.7	58.6	0.404	11.57	59.0	58.9	0.404	80	75		
80	76	10.13	58.5	58.5	0.379	11.21	58.9	58.9	0.379	12.26	59.2	59.2	0.379	80	76		
80	77	10.71	58.8	58.8	0.354	11.85	59.2	59.2	0.354	12.97	59.5	59.5	0.353	80	77		
85	63	4.82	57.5	52.5	1.000	5.40	57.6	52.6	1.000	5.97	57.8	52.6	1.000	85	63		
85	64	4.83	57.5	53.7	1.000	5.40	57.6	53.8	1.000	5.97	57.8	53.8	1.000	85	64		
85	65	5.04	57.0	54.5	0.976	5.41	57.6	55.0	1.000	5.98	57.8	55.1	1.000	85	65		
85	66	5.28	57.6	55.2	0.913	5.86	57.7	55.4	0.921	6.44	57.8	55.5	0.928	85	66		
85	67	5.60	58.0	55.8	0.850	6.20	58.1	56.0	0.857	6.80	58.3	56.1	0.865	85	67		
85	68	5.98	58.3	56.2	0.788	6.61	58.5	56.4	0.795	7.23	58.7	56.6	0.802	85	68		
85	69	6.42	58.5	56.6	0.730	7.09	58.7	56.8	0.737	7.75	58.9	57.0	0.743	85	69		
85	70	6.91	58.5	56.8	0.677	7.63	58.8	57.1	0.683	8.32	59.1	57.4	0.688	85	70		
85	71	7.41	58.6	57.1	0.630	8.19	58.9	57.4	0.634	8.94	59.2	57.6	0.639	85	71		
85	72	7.92	58.7	57.4	0.588	8.76	59.0	57.7	0.591	9.57	59.3	57.9	0.595	85	72		
85	73	8.45	58.8	57.6	0.550	9.34	59.1	57.9	0.553	10.21	59.4	58.2	0.556	85	73		
85	74	8.99	58.9	57.9	0.516	9.94	59.2	58.2	0.518	10.87	59.6	58.5	0.520	85	74		
85	75	9.54	59.0	58.2	0.485	10.56	59.4	58.5	0.487	11.54	59.7	58.8	0.488	85	75		
85	76	10.11	59.1	58.5	0.457	11.18	59.5	58.8	0.458	12.23	59.8	59.2	0.459	85	76		
85	77	10.68	59.2	58.8	0.431	11.83	59.6	59.2	0.432	12.94	59.9	59.5	0.432	85	77		
85	78	11.27	59.3	59.1	0.408	12.48	59.7	59.5	0.408	13.66	60.1	59.8	0.408	85	78		
85	79	11.88	59.4	59.4	0.386	13.16	59.8	59.8	0.386	14.40	60.2	60.1	0.386	85	79		
85	80	12.50	59.7	59.7	0.363	13.84	60.1	60.1	0.363	15.16	60.5	60.5	0.363	85	80		
85	81	13.13	60.1	60.1	0.342	14.55	60.5	60.5	0.341	15.93	60.8	60.8	0.341	85	81		
85	82	13.78	60.4	60.4	0.322	15.27	60.8	60.8	0.321	16.73	61.2	61.2	0.321	85	82		

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 61
Leaving Water = 51.67

AIR TEMP (°F) EDB	EWB	AIRFLOW												AIR TEMP (°F) EDB		EWB	
		160 CFM (FPM = 281)				180 CFM (FPM = 316)				200 CFM (FPM = 351)				MBH	LDB	LWB	SHR
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR				
90	65	5 56	58 3	53 2	1 000	6 22	58 4	53 3	1 000	6 88	58 6	53 3	1 000	90	65		
90	66	5 56	58 3	54 5	1 000	6 23	58 4	54 6	1 000	6 89	58 6	54 6	1 000	90	66		
90	67	5 87	57 9	55 1	0 959	6 54	58 0	55 2	0 966	7 19	58 1	55 4	0 972	90	67		
90	68	6 15	58 5	55 8	0 901	6 84	58 6	55 9	0 909	7 51	58 7	56 1	0 915	90	68		
90	69	6 51	58 8	56 3	0 843	7 22	59 0	56 5	0 850	7 91	59 2	56 7	0 857	90	69		
90	70	6 92	59 1	56 7	0 787	7 66	59 3	57 0	0 794	8 39	59 5	57 2	0 801	90	70		
90	71	7 39	59 3	57 1	0 734	8 17	59 5	57 3	0 741	8 93	59 8	57 6	0 747	90	71		
90	72	7 90	59 4	57 3	0 685	8 73	59 7	57 6	0 691	9 54	59 9	57 9	0 697	90	72		
90	73	8 43	59 5	57 6	0 641	9 32	59 8	57 9	0 646	10 18	60 1	58 2	0 651	90	73		
90	74	8 97	59 6	57 9	0 602	9 92	59 9	58 2	0 606	10 84	60 2	58 5	0 610	90	74		
90	75	9 52	59 7	58 2	0 566	10 53	60 0	58 5	0 569	11 52	60 3	58 8	0 572	90	75		
90	76	10 08	59 8	58 5	0 534	11 16	60 1	58 8	0 536	12 20	60 5	59 1	0 539	90	76		
90	77	10 66	59 9	58 8	0 504	11 80	60 2	59 1	0 506	12 91	60 6	59 5	0 508	90	77		
90	78	11 25	60 0	59 1	0 476	12 46	60 4	59 4	0 478	13 63	60 7	59 8	0 479	90	78		
90	79	11 85	60 1	59 4	0 451	13 13	60 5	59 8	0 452	14 37	60 9	60 1	0 453	90	79		
90	80	12 47	60 2	59 7	0 428	13 82	60 6	60 1	0 429	15 13	61 0	60 5	0 429	90	80		
90	81	13 11	60 3	60 0	0 407	14 52	60 7	60 4	0 407	15 90	61 2	60 8	0 407	90	81		
90	82	13 76	60 4	60 4	0 387	15 24	60 9	60 8	0 386	16 70	61 3	61 2	0 386	90	82		
90	83	14 42	60 7	60 7	0 366	15 98	61 1	61 1	0 366	17 51	61 5	61 5	0 366	90	83		
90	84	15 10	61 1	61 1	0 346	16 74	61 5	61 5	0 346	18 34	61 9	61 9	0 346	90	84		
90	85	15 80	61 4	61 4	0 327	17 52	61 9	61 9	0 327	19 19	62 3	62 3	0 327	90	85		
90	86	16 51	61 8	61 8	0 310	18 31	62 2	62 2	0 309	20 06	62 7	62 7	0 309	90	86		
90	87	17 24	62 1	62 1	0 293	19 12	62 6	62 6	0 293	20 96	63 1	63 1	0 292	90	87		
95	67	6 30	59 1	54 1	1 000	7 05	59 2	54 1	1 000	7 80	59 4	54 2	1 000	95	67		
95	68	6 30	59 1	55 4	1 000	7 06	59 2	55 4	1 000	7 81	59 4	55 5	1 000	95	68		
95	69	6 74	58 9	55 7	0 941	7 50	59 0	55 9	0 948	8 25	59 1	56 0	0 954	95	69		
95	70	7 07	59 4	56 3	0 887	7 85	59 5	56 5	0 894	8 62	59 7	56 7	0 901	95	70		
95	71	7 46	59 7	56 8	0 834	8 27	59 9	57 1	0 841	9 07	60 1	57 3	0 847	95	71		
95	72	7 91	60 0	57 2	0 782	8 76	60 2	57 5	0 789	9 59	60 4	57 8	0 795	95	72		
95	73	8 41	60 1	57 6	0 733	9 30	60 4	57 9	0 740	10 17	60 7	58 2	0 746	95	73		
95	74	8 95	60 2	57 9	0 688	9 89	60 5	58 2	0 694	10 82	60 8	58 5	0 699	95	74		
95	75	9 50	60 3	58 1	0 648	10 51	60 7	58 5	0 652	11 49	61 0	58 8	0 657	95	75		
95	76	10 06	60 4	58 4	0 610	11 13	60 8	58 8	0 614	12 18	61 1	59 1	0 618	95	76		
95	77	10 64	60 5	58 7	0 576	11 77	60 9	59 1	0 580	12 88	61 2	59 4	0 583	95	77		
95	78	11 23	60 6	59 0	0 545	12 43	61 0	59 4	0 548	13 60	61 4	59 7	0 551	95	78		
95	79	11 83	60 7	59 3	0 517	13 10	61 1	59 7	0 519	14 34	61 5	60 1	0 521	95	79		
95	80	12 45	60 9	59 7	0 490	13 79	61 3	60 1	0 492	15 10	61 7	60 4	0 494	95	80		
95	81	13 08	61 0	60 0	0 466	14 50	61 4	60 4	0 467	15 87	61 8	60 8	0 468	95	81		
95	82	13 73	61 1	60 3	0 443	15 22	61 5	60 7	0 444	16 67	62 0	61 1	0 445	95	82		
95	83	14 40	61 2	60 7	0 422	15 96	61 7	61 1	0 422	17 48	62 1	61 5	0 423	95	83		
95	84	15 08	61 3	61 0	0 402	16 71	61 8	61 5	0 402	18 31	62 3	61 9	0 403	95	84		
95	85	15 77	61 5	61 4	0 384	17 49	62 0	61 8	0 384	19 16	62 4	62 2	0 383	95	85		
95	86	16 49	61 7	61 7	0 365	18 28	62 2	62 2	0 365	20 03	62 6	62 6	0 365	95	86		
95	87	17 22	62 1	62 1	0 346	19 09	62 6	62 6	0 346	20 93	63 0	63 0	0 346	95	87		
95	88	17 96	62 5	62 5	0 329	19 93	63 0	63 0	0 328	21 84	63 4	63 4	0 328	95	88		
95	89	18 73	62 9	62 9	0 312	20 78	63 4	63 4	0 312	22 78	63 8	63 8	0 311	95	89		
95	90	19 52	63 3	63 3	0 297	21 65	63 8	63 8	0 296	23 74	64 3	64 3	0 295	95	90		
95	91	20 32	63 7	63 7	0 282	22 55	64 2	64 2	0 281	24 72	64 7	64 7	0 280	95	91		
95	92	21 15	64 1	64 1	0 268	23 46	64 6	64 6	0 267	25 73	65 1	65 1	0 266	95	92		

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 61
Leaving Water = 51.67

AIR TEMP (°F)		AIRFLOW						AIR TEMP (°F)							
EDB	EWB	160 CFM (FPM = 281)			180 CFM (FPM = 316)			200 CFM (FPM = 351)			EDB	EWB			
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR		
100	69	7 03	59 9	55 0	1 000	7 88	60 0	55 0	1 000	8 73	60 2	55 1	1 000	100	69
100	70	7 34	59 3	55 7	0 973	8 19	59 4	55 8	0 979	8 73	60 2	56 4	1 000	100	70
100	71	7 65	59 9	56 4	0 923	8 51	60 0	56 5	0 929	9 36	60 2	56 7	0 936	100	71
100	72	8 02	60 3	56 9	0 872	8 91	60 5	57 2	0 879	9 78	60 7	57 4	0 885	100	72
100	73	8 45	60 6	57 4	0 822	9 38	60 8	57 7	0 829	10 28	61 1	57 9	0 835	100	73
100	74	8 94	60 8	57 8	0 774	9 90	61 1	58 1	0 781	10 85	61 4	58 4	0 787	100	74
100	75	9 47	61 0	58 1	0 729	10 48	61 3	58 4	0 735	11 47	61 6	58 7	0 741	100	75
100	76	10 04	61 1	58 4	0 687	11 11	61 4	58 8	0 693	12 15	61 7	59 1	0 698	100	76
100	77	10 61	61 2	58 7	0 649	11 75	61 5	59 1	0 654	12 85	61 9	59 4	0 658	100	77
100	78	11 20	61 3	59 0	0 614	12 40	61 7	59 4	0 618	13 58	62 0	59 7	0 622	100	78
100	79	11 81	61 4	59 3	0 582	13 08	61 8	59 7	0 586	14 31	62 1	60 0	0 589	100	79
100	80	12 43	61 5	59 6	0 553	13 76	61 9	60 0	0 555	15 07	62 3	60 4	0 558	100	80
100	81	13 06	61 6	60 0	0 525	14 47	62 1	60 4	0 527	15 84	62 4	60 7	0 530	100	81
100	82	13 71	61 8	60 3	0 500	15 19	62 2	60 7	0 501	16 64	62 6	61 1	0 503	100	82
100	83	14 37	61 9	60 6	0 476	15 93	62 3	61 1	0 477	17 45	62 8	61 4	0 479	100	83
100	84	15 05	62 0	61 0	0 454	16 68	62 5	61 4	0 455	18 28	62 9	61 8	0 456	100	84
100	85	15 75	62 1	61 3	0 433	17 46	62 6	61 8	0 434	19 13	63 1	62 2	0 434	100	85
100	86	16 46	62 3	61 7	0 414	18 25	62 8	62 2	0 414	20 00	63 3	62 6	0 414	100	86
100	87	17 19	62 4	62 1	0 396	19 06	62 9	62 5	0 396	20 89	63 4	63 0	0 396	100	87
100	88	17 94	62 5	62 4	0 379	19 90	63 1	62 9	0 378	21 81	63 6	63 4	0 378	100	88
100	89	18 71	62 8	62 8	0 361	20 75	63 3	63 3	0 361	22 75	63 8	63 8	0 361	100	89
100	90	19 49	63 2	63 2	0 343	21 62	63 7	63 7	0 343	23 70	64 2	64 2	0 343	100	90
100	91	20 29	63 6	63 6	0 327	22 52	64 2	64 2	0 327	24 69	64 6	64 6	0 327	100	91
100	92	21 12	64 0	64 0	0 311	23 43	64 6	64 6	0 311	25 69	65 1	65 1	0 311	100	92
100	93	21 96	64 5	64 5	0 296	24 37	65 0	65 0	0 296	26 72	65 5	65 5	0 295	100	93
100	94	22 83	64 9	64 9	0 282	25 33	65 5	65 5	0 282	27 78	66 0	66 0	0 281	100	94
100	95	23 71	65 3	65 3	0 269	26 32	65 9	65 9	0 268	28 86	66 5	66 5	0 268	100	95
100	96	24 62	65 8	65 8	0 256	27 33	66 4	66 4	0 255	29 97	66 9	66 9	0 255	100	96
100	97	25 55	66 3	66 3	0 244	28 36	66 9	66 9	0 243	31 11	67 4	67 4	0 242	100	97
105	71	7 77	60 7	56 0	1 000	8 72	60 9	56 1	1 000	9 65	61 0	56 1	1 000	105	71
105	72	8 25	60 4	56 4	0 951	9 19	60 5	56 5	0 958	10 12	60 6	56 7	0 963	105	72
105	73	8 60	60 9	57 0	0 903	9 57	61 0	57 2	0 910	10 52	61 2	57 4	0 916	105	73
105	74	9 02	61 2	57 5	0 855	10 02	61 4	57 8	0 862	11 00	61 6	58 0	0 869	105	74
105	75	9 50	61 5	58 0	0 809	10 53	61 8	58 3	0 815	11 55	62 0	58 5	0 822	105	75
105	76	10 02	61 7	58 4	0 764	11 10	62 0	58 7	0 770	12 16	62 3	59 0	0 777	105	76
105	77	10 59	61 8	58 7	0 722	11 72	62 2	59 0	0 728	12 83	62 5	59 4	0 734	105	77
105	78	11 18	61 9	59 0	0 683	12 38	62 3	59 3	0 689	13 55	62 6	59 7	0 694	105	78
105	79	11 78	62 1	59 3	0 648	13 05	62 4	59 7	0 652	14 29	62 8	60 0	0 657	105	79
105	80	12 40	62 2	59 6	0 615	13 74	62 6	60 0	0 619	15 04	62 9	60 4	0 623	105	80
105	81	13 04	62 3	59 9	0 584	14 44	62 7	60 3	0 588	15 81	63 1	60 7	0 591	105	81
105	82	13 68	62 4	60 3	0 556	15 16	62 8	60 7	0 559	16 61	63 2	61 1	0 562	105	82
105	83	14 35	62 5	60 6	0 530	15 90	63 0	61 0	0 532	17 42	63 4	61 4	0 535	105	83
105	84	15 03	62 7	60 9	0 505	16 66	63 1	61 4	0 507	18 25	63 6	61 8	0 509	105	84
105	85	15 72	62 8	61 3	0 482	17 43	63 3	61 7	0 484	19 10	63 7	62 2	0 485	105	85
105	86	16 43	62 9	61 7	0 461	18 22	63 4	62 1	0 462	19 97	63 9	62 5	0 463	105	86
105	87	17 16	63 1	62 0	0 441	19 04	63 6	62 5	0 442	20 86	64 1	62 9	0 442	105	87
105	88	17 91	63 2	62 4	0 422	19 87	63 7	62 9	0 422	21 78	64 3	63 3	0 423	105	88
105	89	18 68	63 3	62 8	0 404	20 72	63 9	63 3	0 404	22 71	64 4	63 7	0 405	105	89
105	90	19 46	63 5	63 2	0 387	21 59	64 1	63 7	0 387	23 67	64 6	64 2	0 387	105	90
105	91	20 27	63 6	63 6	0 372	22 49	64 2	64 1	0 371	24 65	64 8	64 6	0 371	105	91
105	92	21 09	64 0	64 0	0 355	23 40	64 5	64 5	0 355	25 66	65 0	65 0	0 355	105	92
105	93	21 94	64 4	64 4	0 338	24 34	65 0	65 0	0 338	26 69	65 5	65 5	0 338	105	93
105	94	22 80	64 9	64 9	0 323	25 30	65 4	65 4	0 323	27 75	65 9	65 9	0 323	105	94
105	95	23 69	65 3	65 3	0 308	26 29	65 9	65 9	0 308	28 83	66 4	66 4	0 307	105	95
105	96	24 59	65 7	65 7	0 294	27 30	66 3	66 3	0 294	29 94	66 9	66 9	0 293	105	96
105	97	25 52	66 2	66 2	0 281	28 33	66 8	66 8	0 280	31 07	67 4	67 4	0 280	105	97
105	98	26 48	66 7	66 7	0 268	29 39	67 3	67 3	0 267	32 24	67 9	67 9	0 267	105	98
105	99	27 46	67 2	67 2	0 256	30 48	67 8	67 8	0 255	33 43	68 4	68 4	0 254	105	99
105	100	28 46	67 7	67 7	0 244	31 59	68 3	68 3	0 243	34 65	68 9	68 9	0 242	105	100
105	101	29 48	68 2	68 2	0 233	32 73	68 8	68 8	0 232	35 91	69 4	69 4	0 231	105	101
105	102	30 54	68 7	68 7	0 223	33 90	69 4	69 4	0 222	37 21	70 0	70 0	0 220	105	102

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 61
Leaving Water = 51.67

AIR TEMP. (F)		AIRFLOW								AIR TEMP. (F)					
EDB	EWB	220 CFM (FPM = 386)				240 CFM (FPM = 421)				260 CFM (FPM = 456)				EDB	EWB
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR		
90	65	7.54	58.7	53.8	1.000	8.19	58.8	53.5	1.000	8.83	59.0	53.5	1.000	90	65
90	66	7.55	58.7	54.7	1.000	8.20	58.9	54.7	1.000	8.84	59.0	54.8	1.000	90	66
90	67	7.84	58.2	55.5	0.978	8.20	58.9	56.0	1.000	8.85	59.0	56.0	1.000	90	67
90	68	8.17	58.9	56.2	0.922	8.82	59.0	56.4	0.928	9.47	59.1	56.5	0.934	90	68
90	69	8.59	59.3	56.9	0.864	9.26	59.5	57.0	0.870	9.93	59.6	57.2	0.876	90	69
90	70	9.10	59.7	57.4	0.807	9.80	59.9	57.6	0.813	10.48	60.1	57.7	0.819	90	70
90	71	9.68	60.0	57.8	0.753	10.41	60.2	58.0	0.758	11.12	60.4	58.2	0.764	90	71
90	72	10.33	60.2	58.2	0.702	11.10	60.4	58.4	0.707	11.85	60.6	58.6	0.712	90	72
90	73	11.03	60.3	58.5	0.655	11.85	60.6	58.7	0.660	12.65	60.8	59.0	0.664	90	73
90	74	11.74	60.5	58.8	0.613	12.62	60.7	59.0	0.617	13.48	61.0	59.3	0.621	90	74
90	75	12.48	60.6	59.1	0.575	13.41	60.9	59.4	0.578	14.33	61.1	59.6	0.581	90	75
90	76	13.23	60.8	59.4	0.541	14.22	61.0	59.7	0.543	15.20	61.3	60.0	0.546	90	76
90	77	13.99	60.9	59.8	0.510	15.05	61.2	60.1	0.511	16.09	61.5	60.3	0.513	90	77
90	78	14.78	61.1	60.1	0.481	15.90	61.4	60.4	0.482	17.00	61.7	60.7	0.484	90	78
90	79	15.59	61.2	60.4	0.454	16.77	61.5	60.8	0.455	17.93	61.9	61.0	0.456	90	79
90	80	16.41	61.4	60.8	0.430	17.66	61.7	61.1	0.430	18.88	62.0	61.4	0.431	90	80
90	81	17.25	61.5	61.2	0.407	18.57	61.9	61.5	0.408	19.86	62.2	61.8	0.408	90	81
90	82	18.12	61.7	61.5	0.386	19.50	62.1	61.9	0.386	20.86	62.4	62.2	0.386	90	82
90	83	19.00	61.9	61.9	0.366	20.46	62.3	62.2	0.367	21.88	62.6	62.6	0.366	90	83
90	84	19.90	62.3	62.3	0.346	21.43	62.6	62.6	0.346	22.93	63.0	63.0	0.346	90	84
90	85	20.83	62.7	62.7	0.326	22.44	63.0	63.0	0.326	24.01	63.4	63.4	0.326	90	85
90	86	21.78	63.1	63.1	0.308	23.46	63.4	63.4	0.308	25.10	63.8	63.8	0.307	90	86
90	87	22.75	63.5	63.5	0.291	24.51	63.9	63.9	0.290	26.23	64.2	64.2	0.290	90	87
95	67	8.55	59.5	54.2	1.000	9.29	59.7	54.3	1.000	10.02	59.8	54.4	1.000	95	67
95	68	8.56	59.5	55.5	1.000	9.30	59.7	55.6	1.000	10.03	59.8	55.7	1.000	95	68
95	69	9.00	59.2	56.2	0.960	9.73	59.3	56.3	0.966	10.46	59.4	56.4	0.971	95	69
95	70	9.38	59.8	56.9	0.907	10.13	60.0	57.0	0.913	10.87	60.1	57.2	0.919	95	70
95	71	9.85	60.3	57.5	0.854	10.63	60.4	57.7	0.860	11.39	60.6	57.8	0.866	95	71
95	72	10.41	60.6	58.0	0.801	11.21	60.8	58.2	0.807	11.99	61.0	58.4	0.813	95	72
95	73	11.03	60.9	58.4	0.751	11.86	61.1	58.6	0.757	12.69	61.3	58.9	0.762	95	73
95	74	11.71	61.1	58.8	0.705	12.59	61.3	59.0	0.710	13.45	61.6	59.3	0.715	95	74
95	75	12.45	61.2	59.1	0.661	13.38	61.5	59.3	0.666	14.30	61.8	59.6	0.670	95	75
95	76	13.20	61.4	59.4	0.622	14.19	61.7	59.7	0.626	15.16	61.9	59.9	0.629	95	76
95	77	13.96	61.5	59.7	0.586	15.02	61.8	60.0	0.589	16.05	62.1	60.3	0.592	95	77
95	78	14.75	61.7	60.1	0.553	15.87	62.0	60.4	0.556	16.96	62.3	60.6	0.558	95	78
95	79	15.55	61.9	60.4	0.523	16.74	62.2	60.7	0.525	17.89	62.5	61.0	0.527	95	79
95	80	16.38	62.0	60.8	0.495	17.63	62.3	61.1	0.497	18.85	62.7	61.4	0.499	95	80
95	81	17.22	62.2	61.1	0.469	18.54	62.5	61.4	0.471	19.82	62.9	61.8	0.472	95	81
95	82	18.08	62.3	61.5	0.446	19.47	62.7	61.8	0.447	20.82	63.1	62.1	0.447	95	82
95	83	18.97	62.5	61.9	0.423	20.42	62.9	62.2	0.424	21.85	63.2	62.5	0.425	95	83
95	84	19.87	62.7	62.2	0.403	21.40	63.1	62.6	0.403	22.89	63.5	62.9	0.403	95	84
95	85	20.80	62.9	62.6	0.383	22.40	63.3	63.0	0.383	23.97	63.7	63.3	0.383	95	85
95	86	21.75	63.0	63.0	0.365	23.42	63.5	63.4	0.365	25.07	63.9	63.8	0.365	95	86
95	87	22.72	63.4	63.4	0.346	24.47	63.8	63.8	0.346	26.19	64.2	64.2	0.346	95	87
95	88	23.71	63.8	63.8	0.328	25.55	64.2	64.2	0.328	27.34	64.6	64.6	0.328	95	88
95	89	24.73	64.3	64.3	0.311	26.65	64.7	64.7	0.311	28.52	65.1	65.1	0.310	95	89
95	90	25.78	64.7	64.7	0.295	27.77	65.1	65.1	0.294	29.73	65.5	65.5	0.294	95	90
95	91	26.85	65.1	65.1	0.279	28.93	65.6	65.6	0.279	30.97	66.0	66.0	0.278	95	91
95	92	27.94	65.6	65.6	0.265	30.11	66.0	66.0	0.264	32.23	66.5	66.5	0.264	95	92

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 61
Leaving Water = 51.67

AIR TEMP (°F)	EDB	EWB	AIRFLOW								AIR TEMP (°F)								EDB				EWB								
			220 CFM (FPM = 386)				240 CFM (FPM = 421)				260 CFM (FPM = 456)					MBH	LDB	LWB	SHR		MBH	LDB	LWB	SHR		EDB	EWB				
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR		MBH	LDB	LWB	SHR		MBH	LDB	LWB	SHR		EDB	EWB				
100	69	9 56	60 3	55 2	1 000	10 39	60 5	55 2	1 000	11 22	60 6	55 3	1 000	100	69	9 57	60 4	56 5	1 000	10 40	60 5	56 6	1 000	11 23	60 7	56 6	1 000	100	70		
100	70	9 57	60 4	56 5	1 000	10 40	60 5	56 6	1 000	11 23	60 7	56 6	1 000	100	70	100	71	10 20	60 3	56 9	0 942	11 03	60 4	57 0	0 947	11 85	60 5	57 1	0 952	100	71
100	72	10 64	60 8	57 5	0 891	11 49	61 0	57 7	0 897	12 33	61 1	57 9	0 903	100	72	100	73	11 17	61 2	58 1	0 842	12 05	61 4	58 3	0 847	12 91	61 6	58 5	0 853	100	73
100	74	11 77	61 6	58 6	0 793	12 68	61 8	58 8	0 799	13 57	62 0	59 0	0 804	100	74	100	75	12 44	61 8	59 0	0 747	13 39	62 1	59 3	0 752	14 32	62 3	59 5	0 757	100	75
100	76	13 17	62 0	59 4	0 703	14 16	62 3	59 6	0 708	15 13	62 5	59 9	0 713	100	76	100	77	13 93	62 2	59 7	0 663	14 99	62 5	60 0	0 667	16 02	62 7	60 3	0 671	100	77
100	78	14 72	62 3	60 0	0 626	15 83	62 6	60 3	0 630	16 93	62 9	60 6	0 633	100	78	100	79	15 52	62 5	60 4	0 592	16 70	62 8	60 7	0 595	17 86	63 1	61 0	0 598	100	79
100	80	16 35	62 6	60 7	0 561	17 59	63 0	61 0	0 563	18 81	63 3	61 3	0 566	100	80	100	81	17 19	62 8	61 1	0 532	18 50	63 2	61 4	0 534	19 79	63 5	61 7	0 536	100	81
100	82	18 05	63 0	61 4	0 505	19 43	63 3	61 8	0 507	20 79	63 7	62 1	0 509	100	82	100	83	18 93	63 2	61 8	0 480	20 39	63 5	62 2	0 481	21 81	63 9	62 5	0 483	100	83
100	84	19 84	63 3	62 2	0 457	21 36	63 7	62 6	0 458	22 86	64 1	62 9	0 459	100	84	100	85	20 76	63 5	62 6	0 435	22 36	63 9	63 0	0 436	23 93	64 3	63 3	0 437	100	85
100	86	21 71	63 7	63 0	0 415	23 39	64 1	63 4	0 415	25 03	64 5	63 7	0 416	100	86	100	87	22 68	63 9	63 4	0 396	24 44	64 3	63 8	0 396	26 15	64 7	64 2	0 396	100	87
100	88	23 68	64 1	63 8	0 378	25 51	64 5	64 2	0 378	27 30	65 0	64 6	0 378	100	88	100	89	24 70	64 3	64 2	0 361	26 61	64 7	64 6	0 361	28 48	65 2	65 0	0 361	100	89
100	90	25 74	64 7	64 7	0 344	27 74	65 1	65 1	0 344	29 69	65 5	65 5	0 344	100	90	100	91	26 81	65 1	65 1	0 326	28 89	65 5	65 5	0 326	30 93	65 9	65 9	0 326	100	91
100	92	27 91	65 6	65 6	0 310	30 07	66 0	66 0	0 310	32 19	66 4	66 4	0 310	100	92	100	93	29 03	66 0	66 0	0 295	31 28	66 5	66 5	0 295	33 49	66 9	66 9	0 294	100	93
100	94	30 18	66 5	66 5	0 281	32 52	66 9	66 9	0 280	34 82	67 4	67 4	0 280	100	94	100	95	31 35	67 0	67 0	0 267	33 79	67 4	67 4	0 266	36 18	67 9	67 9	0 266	100	95
100	96	32 56	67 5	67 5	0 254	35 09	67 9	67 9	0 253	37 58	68 4	68 4	0 252	100	96	100	97	33 80	68 0	68 0	0 241	36 43	68 5	68 5	0 240	39 00	68 9	68 9	0 240	100	97
105	71	10 58	61 2	56 2	1 000	11 50	61 3	56 3	1 000	12 41	61 5	56 3	1 000	105	71	105	72	11 05	60 7	56 8	0 969	11 96	60 8	57 0	0 974	12 86	60 9	57 1	0 979	105	72
105	73	11 46	61 3	57 6	0 922	12 39	61 5	57 8	0 928	13 31	61 6	57 9	0 933	105	73	105	74	11 97	61 8	58 2	0 875	12 92	62 0	58 4	0 880	13 86	62 2	58 6	0 886	105	74
105	75	12 55	62 2	58 8	0 828	13 53	62 4	59 0	0 834	14 50	62 6	59 2	0 839	105	75	105	76	13 20	62 5	59 2	0 782	14 22	62 8	59 5	0 788	15 22	63 0	59 7	0 793	105	76
105	77	13 91	62 8	59 6	0 739	14 98	63 0	59 9	0 745	16 02	63 3	60 2	0 750	105	77	105	78	14 69	62 9	60 0	0 699	15 80	63 2	60 3	0 703	16 89	63 5	60 6	0 708	105	78
105	79	15 49	63 1	60 3	0 661	16 67	63 4	60 7	0 665	17 82	63 7	60 9	0 669	105	79	105	80	16 31	63 3	60 7	0 626	17 56	63 6	61 0	0 630	18 77	63 9	61 3	0 634	105	80
105	81	17 16	63 4	61 0	0 594	18 47	63 8	61 4	0 597	19 75	64 1	61 7	0 600	105	81	105	82	18 02	63 6	61 4	0 564	19 40	64 0	61 7	0 567	20 75	64 3	62 1	0 570	105	82
105	83	18 90	63 8	61 8	0 537	20 35	64 2	62 1	0 539	21 77	64 5	62 5	0 541	105	83	105	84	19 80	64 0	62 2	0 511	21 33	64 3	62 5	0 513	22 82	64 7	62 9	0 515	105	84
105	85	20 73	64 1	62 5	0 487	22 33	64 5	62 9	0 488	23 89	64 9	63 3	0 490	105	85	105	86	21 68	64 3	62 9	0 464	23 35	64 7	63 3	0 466	24 99	65 1	63 7	0 467	105	86
105	87	22 65	64 5	63 3	0 443	24 40	65 0	63 7	0 444	26 11	65 4	64 1	0 445	105	87	105	88	23 64	64 7	63 8	0 424	25 47	65 2	64 2	0 424	27 26	65 6	64 5	0 425	105	88
105	89	24 66	64 9	64 2	0 405	26 57	65 4	64 6	0 405	28 44	65 8	65 0	0 406	105	89	105	90	25 71	65 1	64 6	0 387	27 70	65 6	65 0	0 387	29 65	66 1	65 4	0 388	105	90
105	91	26 78	65 3	65 1	0 371	28 85	65 8	65 5	0 371	30 88	66 3	65 9	0 371	105	91	105	92	27 87	65 6	65 5	0 355	30 03	66 1	65 9	0 355	32 15	66 5	66 4	0 355	105	92
105	93	28 99	66 0	66 0	0 339	31 24	66 4	66 4	0 339	33 45	66 8	66 8	0 339	105	93	105	94	30 14	66 4	66 4	0 323	32 48	66 9	66 9	0 323	34 78	67 3	67 3	0 323	105	94
105	95	31 32	66 9	66 9	0 307	33 75	67 4	67 4	0 307	36 14	67 8	67 8	0 307	105	95	105	96	32 52	67 4	67 4	0 293	35 05	67 9	67 9	0 293	37 53	68 4	68 4	0 292	105	96
105	97	33 76	67 9	67 9	0 279	36 39	68 4	68 4	0 279	38 96	68 9	68 9	0 278	105	97	105	98	35 02	68 4	68 4	0 266	37 75	68 9	68 9	0 265	40 43	69 4	69 4	0 265	105	98
105	99	36 32	68 9	68 9	0 254	39 15	69 5	69 5	0 253	41 92	70 0	70 0	0 252	105	99	105	100	37 65	69 5	69 5	0 242	40 59	70 0	70 0	0 241	43 46	70 5	70 5	0 240	105	100
105	101	39 01	70 0	70 0	0 230	42 05	70 6	70 6	0 229	45 03	71 1	71 1	0 228	105	101	105	102	40 41	70 6	70 6	0 219	43 56	71 1	71 1	0 218	46 65	71 7	71 7	0 218	105	102

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART Coil Size: DW 61
Entering Water = 45 Leaving Water = 51.67

AIR TEMP. (F)		AIRFLOW												AIR TEMP (F)	
EDB	EWB	280 CFM (FPM = 491)				300 CFM (FPM = 526)				320 CFM (FPM = 596)				EDB	EWB
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR		
75	59	5.64	56.6	51.6	1.000	6.01	56.7	51.7	1.000	6.38	56.8	51.7	1.000	75	59
75	60	5.65	56.6	52.8	1.000	6.02	56.7	52.8	1.000	6.38	56.8	52.9	1.000	75	60
75	61	5.65	56.6	53.9	1.000	6.02	56.7	54.0	1.000	6.38	56.8	54.0	1.000	75	61
75	62	5.90	56.3	54.8	0.973	6.26	56.4	54.8	0.979	6.61	56.5	54.9	0.985	75	62
75	63	6.21	57.0	55.5	0.893	6.58	57.1	55.6	0.899	6.94	57.1	55.7	0.905	75	63
75	64	6.65	57.5	56.2	0.812	7.03	57.6	56.3	0.818	7.41	57.7	56.4	0.824	75	64
75	65	7.21	57.8	56.7	0.735	7.61	58.0	56.8	0.740	8.01	58.1	56.9	0.746	75	65
75	66	7.89	58.1	57.0	0.664	8.32	58.2	57.2	0.668	8.74	58.3	57.3	0.673	75	66
75	67	8.64	58.2	57.3	0.601	9.11	58.4	57.5	0.605	9.58	58.5	57.7	0.608	75	67
75	68	9.41	58.4	57.7	0.547	9.93	58.5	57.8	0.550	10.44	58.7	58.0	0.552	75	68
75	69	10.20	58.5	58.0	0.501	10.77	58.7	58.1	0.503	11.33	58.9	58.3	0.504	75	69
75	70	11.01	58.7	58.3	0.460	11.63	58.9	58.5	0.461	12.23	59.1	58.7	0.463	75	70
75	71	11.83	58.9	58.6	0.424	12.50	59.1	58.8	0.425	13.16	59.2	59.0	0.426	75	71
75	72	12.68	59.0	58.9	0.393	13.40	59.2	59.1	0.393	14.11	59.4	59.3	0.393	75	72
80	61	6.92	57.4	52.2	1.000	7.38	57.5	52.2	1.000	7.83	57.6	52.3	1.000	80	61
80	62	6.92	57.4	53.4	1.000	7.38	57.5	53.4	1.000	7.83	57.7	53.5	1.000	80	62
80	63	6.93	57.4	54.6	1.000	7.38	57.6	54.6	1.000	7.84	57.7	54.7	1.000	80	63
80	64	7.26	57.2	55.3	0.964	7.72	57.3	55.4	0.969	8.16	57.4	55.5	0.975	80	64
80	65	7.63	57.9	56.1	0.894	8.09	57.9	56.2	0.900	8.54	58.0	56.3	0.905	80	65
80	66	8.10	58.3	56.7	0.824	8.58	58.5	56.8	0.830	9.04	58.6	56.9	0.835	80	66
80	67	8.69	58.7	57.2	0.756	9.19	58.9	57.4	0.761	9.68	59.0	57.5	0.766	80	67
80	68	9.38	59.0	57.6	0.693	9.91	59.1	57.8	0.697	10.43	59.3	57.9	0.702	80	68
80	69	10.17	59.1	57.9	0.635	10.73	59.3	58.1	0.639	11.29	59.5	58.3	0.643	80	69
80	70	10.97	59.3	58.3	0.585	11.59	59.5	58.4	0.588	12.19	59.7	58.6	0.591	80	70
80	71	11.80	59.5	58.6	0.540	12.47	59.7	58.8	0.542	13.12	59.9	59.0	0.545	80	71
80	72	12.64	59.6	58.9	0.501	13.36	59.8	59.1	0.502	14.07	60.0	59.3	0.504	80	72
80	73	13.51	59.8	59.2	0.465	14.28	60.0	59.5	0.467	15.04	60.2	59.7	0.468	80	73
80	74	14.39	60.0	59.6	0.434	15.22	60.2	59.8	0.434	16.03	60.4	60.0	0.435	80	74
80	75	15.30	60.2	59.9	0.405	16.18	60.4	60.2	0.405	17.05	60.6	60.4	0.406	80	75
80	76	16.23	60.3	60.3	0.379	17.17	60.6	60.5	0.379	18.09	60.8	60.8	0.379	80	76
80	77	17.18	60.6	60.6	0.353	18.17	60.9	60.9	0.353	19.15	61.1	61.1	0.353	80	77
85	63	8.19	58.3	52.8	1.000	8.74	58.4	52.9	1.000	9.28	58.5	52.9	1.000	85	63
85	64	8.20	58.3	54.1	1.000	8.75	58.4	54.1	1.000	9.29	58.5	54.2	1.000	85	64
85	65	8.21	58.3	55.3	1.000	8.75	58.4	55.3	1.000	9.29	58.5	55.4	1.000	85	65
85	66	8.66	58.2	55.9	0.952	9.20	58.3	56.0	0.958	9.73	58.3	56.1	0.963	85	66
85	67	9.08	58.8	56.7	0.890	9.63	58.9	56.8	0.895	10.18	59.0	56.9	0.900	85	67
85	68	9.60	59.3	57.3	0.827	10.17	59.4	57.4	0.832	10.73	59.5	57.6	0.838	85	68
85	69	10.23	59.6	57.8	0.766	10.82	59.8	58.0	0.771	11.40	59.9	58.1	0.776	85	69
85	70	10.95	59.9	58.2	0.709	11.58	60.1	58.4	0.714	12.19	60.2	58.6	0.718	85	70
85	71	11.76	60.1	58.6	0.656	12.43	60.3	58.8	0.660	13.08	60.5	58.9	0.664	85	71
85	72	12.61	60.3	58.9	0.609	13.33	60.5	59.1	0.612	14.03	60.6	59.3	0.616	85	72
85	73	13.47	60.4	59.2	0.567	14.24	60.6	59.4	0.569	15.00	60.8	59.6	0.572	85	73
85	74	14.36	60.6	59.6	0.529	15.18	60.8	59.8	0.531	15.99	61.0	60.0	0.533	85	74
85	75	15.26	60.8	59.9	0.495	16.14	61.0	60.1	0.496	17.00	61.2	60.4	0.498	85	75
85	76	16.19	61.0	60.3	0.463	17.13	61.2	60.5	0.465	18.04	61.4	60.7	0.466	85	76
85	77	17.14	61.1	60.6	0.435	18.13	61.4	60.9	0.436	19.11	61.6	61.1	0.437	85	77
85	78	18.11	61.3	61.0	0.409	19.16	61.6	61.2	0.410	20.20	61.9	61.5	0.410	85	78
85	79	19.11	61.5	61.4	0.385	20.22	61.8	61.6	0.386	21.31	62.1	61.9	0.386	85	79
85	80	20.12	61.7	61.7	0.363	21.30	62.0	62.0	0.363	22.45	62.3	62.3	0.363	85	80
85	81	21.16	62.1	62.1	0.340	22.41	62.4	62.4	0.340	23.62	62.7	62.7	0.340	85	81
85	82	22.23	62.5	62.5	0.319	23.54	62.8	62.8	0.319	24.82	63.1	63.1	0.318	85	82

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART Coil Size: DW 61
Entering Water = 45 Leaving Water = 51.67

AIR TEMP. (F)		AIRFLOW												AIR TEMP. (F)	
EDB	EWB	280 CFM (FPM = 491)				300 CFM (FPM = 526)				320 CFM (FPM = 596)				EDB	EWB
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR		
90	65	9.47	59.1	53.6	1.000	10.11	59.2	53.6	1.000	10.74	59.4	53.7	1.000	90	65
90	66	9.48	59.1	54.8	1.000	10.11	59.2	54.9	1.000	10.74	59.4	54.9	1.000	90	66
90	67	9.49	59.1	56.1	1.000	10.12	59.3	56.1	1.000	10.75	59.4	56.2	1.000	90	67
90	68	10.11	59.2	56.6	0.939	10.74	59.3	56.7	0.944	11.36	59.3	56.8	0.949	90	68
90	69	10.58	59.7	57.3	0.882	11.22	59.9	57.4	0.887	11.85	60.0	57.6	0.892	90	69
90	70	11.15	60.2	57.9	0.825	11.82	60.3	58.1	0.830	12.47	60.5	58.2	0.835	90	70
90	71	11.83	60.6	58.4	0.769	12.52	60.7	58.6	0.774	13.20	60.9	58.7	0.779	90	71
90	72	12.59	60.8	58.8	0.717	13.32	61.0	59.0	0.722	14.03	61.2	59.2	0.726	90	72
90	73	13.44	61.0	59.2	0.668	14.20	61.2	59.4	0.672	14.96	61.4	59.6	0.677	90	73
90	74	14.32	61.2	59.5	0.624	15.14	61.4	59.7	0.628	15.95	61.6	60.0	0.631	90	74
90	75	15.23	61.4	59.9	0.584	16.10	61.6	60.1	0.587	16.96	61.8	60.3	0.590	90	75
90	76	16.15	61.6	60.2	0.548	17.09	61.8	60.5	0.550	18.00	62.0	60.7	0.553	90	76
90	77	17.10	61.8	60.6	0.515	18.09	62.0	60.8	0.517	19.07	62.3	61.1	0.519	90	77
90	78	18.07	62.0	60.9	0.485	19.12	62.2	61.2	0.486	20.15	62.5	61.4	0.488	90	78
90	79	19.07	62.1	61.3	0.457	20.18	62.4	61.6	0.458	21.27	62.7	61.8	0.459	90	79
90	80	20.08	62.3	61.7	0.432	21.26	62.6	62.0	0.433	22.41	62.9	62.2	0.433	90	80
90	81	21.12	62.5	62.1	0.408	22.36	62.8	62.4	0.409	23.58	63.1	62.6	0.409	90	81
90	82	22.19	62.8	62.5	0.386	23.49	63.1	62.8	0.387	24.77	63.4	63.1	0.387	90	82
90	83	23.28	63.0	62.9	0.366	24.65	63.3	63.2	0.366	26.00	63.6	63.5	0.366	90	83
90	84	24.40	63.3	63.3	0.346	25.84	63.6	63.6	0.346	27.25	63.9	63.9	0.346	90	84
90	85	25.54	63.7	63.7	0.326	27.05	64.0	64.0	0.325	28.53	64.3	64.3	0.325	90	85
90	86	26.72	64.1	64.1	0.307	28.30	64.5	64.5	0.307	29.85	64.8	64.8	0.306	90	86
90	87	27.92	64.6	64.6	0.289	29.57	64.9	64.9	0.289	31.19	65.2	65.2	0.288	90	87
95	67	10.75	59.9	54.4	1.000	11.48	60.1	54.5	1.000	12.19	60.2	54.5	1.000	95	67
95	68	10.76	60.0	55.7	1.000	11.49	60.1	55.8	1.000	12.20	60.2	55.8	1.000	95	68
95	69	11.18	59.5	56.5	0.976	11.90	59.6	56.6	0.981	12.21	60.3	57.1	1.000	95	69
95	70	11.60	60.2	57.3	0.924	12.33	60.3	57.4	0.929	13.04	60.4	57.5	0.934	95	70
95	71	12.13	60.7	58.0	0.871	12.87	60.9	58.1	0.876	13.60	61.0	58.3	0.882	95	71
95	72	12.77	61.2	58.6	0.818	13.53	61.3	58.7	0.824	14.28	61.5	58.9	0.829	95	72
95	73	13.49	61.5	59.1	0.768	14.29	61.7	59.2	0.773	15.07	61.9	59.4	0.777	95	73
95	74	14.30	61.8	59.5	0.719	15.13	62.0	59.7	0.724	15.94	62.2	59.9	0.729	95	74
95	75	15.19	62.0	59.8	0.674	16.06	62.2	60.1	0.678	16.92	62.4	60.3	0.682	95	75
95	76	16.12	62.2	60.2	0.633	17.05	62.4	60.4	0.636	17.96	62.6	60.7	0.640	95	76
95	77	17.06	62.4	60.6	0.595	18.05	62.6	60.8	0.598	19.02	62.9	61.0	0.601	95	77
95	78	18.03	62.6	60.9	0.561	19.08	62.8	61.2	0.563	20.11	63.1	61.4	0.566	95	78
95	79	19.03	62.8	61.3	0.529	20.14	63.0	61.6	0.531	21.22	63.3	61.8	0.533	95	79
95	80	20.04	63.0	61.7	0.500	21.22	63.2	61.9	0.502	22.36	63.5	62.2	0.503	95	80
95	81	21.08	63.2	62.1	0.473	22.32	63.5	62.3	0.475	23.53	63.7	62.6	0.476	95	81
95	82	22.15	63.4	62.4	0.448	23.45	63.7	62.7	0.449	24.73	64.0	63.0	0.450	95	82
95	83	23.24	63.6	62.9	0.425	24.61	63.9	63.1	0.426	25.95	64.2	63.4	0.427	95	83
95	84	24.36	63.8	63.3	0.404	25.79	64.1	63.6	0.404	27.20	64.5	63.9	0.405	95	84
95	85	25.50	64.0	63.7	0.384	27.01	64.4	64.0	0.384	28.49	64.7	64.3	0.384	95	85
95	86	26.67	64.3	64.1	0.365	28.25	64.6	64.4	0.365	29.80	65.0	64.7	0.365	95	86
95	87	27.87	64.5	64.5	0.347	29.52	64.9	64.9	0.347	31.14	65.2	65.2	0.347	95	87
95	88	29.10	65.0	65.0	0.328	30.83	65.3	65.3	0.328	32.52	65.7	65.7	0.328	95	88
95	89	30.36	65.4	65.4	0.310	32.16	65.8	65.8	0.310	33.93	66.1	66.1	0.310	95	89
95	90	31.65	65.9	65.9	0.293	33.53	66.3	66.3	0.293	35.37	66.6	66.6	0.293	95	90
95	91	32.97	66.4	66.4	0.278	34.93	66.8	66.8	0.277	36.85	67.1	67.1	0.277	95	91
95	92	34.32	66.9	66.9	0.263	36.36	67.2	67.2	0.262	38.36	67.6	67.6	0.262	95	92

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 61
Leaving Water = 51.67

AIR TEMP (°F) EDB	EWB	280 CFM (FPM = 491)				300 CFM (FPM = 526)				320 CFM (FPM = 596)				AIR TEMP (°F) EDB		EWB
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	
100	69	12.04	60.8	55.3	1.000	12.85	60.9	55.4	1.000	13.65	61.1	55.5	1.000	100	69	
100	70	12.05	60.8	56.7	1.000	12.86	61.0	56.7	1.000	13.67	61.1	56.8	1.000	100	70	
100	71	12.66	60.6	57.3	0.958	13.47	60.7	57.4	0.962	14.26	60.8	57.5	0.967	100	71	
100	72	13.16	61.2	58.0	0.908	13.97	61.4	58.2	0.913	14.79	61.5	58.3	0.918	100	72	
100	73	13.76	61.7	58.7	0.859	14.59	61.9	58.8	0.864	15.42	62.0	59.0	0.869	100	73	
100	74	14.45	62.2	59.2	0.810	15.31	62.3	59.4	0.815	16.17	62.5	59.6	0.820	100	74	
100	75	15.23	62.5	59.7	0.762	16.13	62.7	59.9	0.767	17.01	62.9	60.1	0.772	100	75	
100	76	16.09	62.8	60.2	0.718	17.03	63.0	60.4	0.722	17.95	63.2	60.6	0.727	100	76	
100	77	17.03	63.0	60.5	0.676	18.01	63.2	60.8	0.680	18.98	63.5	61.0	0.684	100	77	
100	78	18.00	63.2	60.9	0.637	19.04	63.4	61.1	0.640	20.07	63.7	61.4	0.644	100	78	
100	79	18.99	63.4	61.3	0.601	20.10	63.6	61.5	0.604	21.18	63.9	61.8	0.607	100	79	
100	80	20.00	63.6	61.6	0.569	21.17	63.9	61.9	0.571	22.32	64.1	62.2	0.574	100	80	
100	81	21.04	63.8	62.0	0.538	22.28	64.1	62.3	0.541	23.49	64.3	62.6	0.543	100	81	
100	82	22.11	64.0	62.4	0.510	23.41	64.3	62.7	0.512	24.68	64.6	63.0	0.514	100	82	
100	83	23.20	64.2	62.8	0.484	24.57	64.5	63.1	0.486	25.90	64.8	63.4	0.487	100	83	
100	84	24.32	64.4	63.2	0.460	25.75	64.8	63.5	0.461	27.16	65.1	63.8	0.463	100	84	
100	85	25.46	64.6	63.6	0.438	26.96	65.0	64.0	0.438	28.44	65.3	64.3	0.439	100	85	
100	86	26.63	64.9	64.1	0.416	28.21	65.2	64.4	0.417	29.75	65.6	64.7	0.418	100	86	
100	87	27.83	65.1	64.5	0.397	29.48	65.5	64.8	0.397	31.10	65.8	65.2	0.397	100	87	
100	88	29.06	65.4	64.9	0.378	30.78	65.7	65.3	0.378	32.47	66.1	65.6	0.378	100	88	
100	89	30.32	65.6	65.4	0.361	32.11	66.0	65.8	0.361	33.88	66.4	66.1	0.361	100	89	
100	90	31.60	65.9	65.9	0.344	33.48	66.3	66.2	0.344	35.32	66.6	66.6	0.344	100	90	
100	91	32.92	66.3	66.3	0.326	34.88	66.7	66.7	0.326	36.80	67.1	67.1	0.327	100	91	
100	92	34.27	66.8	66.8	0.310	36.31	67.2	67.2	0.310	38.31	67.6	67.6	0.310	100	92	
100	93	35.66	67.3	67.3	0.294	37.78	67.7	67.7	0.294	39.86	68.1	68.1	0.294	100	93	
100	94	37.07	67.8	67.8	0.279	39.28	68.2	68.2	0.279	41.45	68.6	68.6	0.278	100	94	
100	95	38.52	68.3	68.3	0.265	40.82	68.7	68.7	0.265	43.08	69.1	69.1	0.264	100	95	
100	96	40.01	68.8	68.8	0.252	42.40	69.3	69.3	0.251	44.74	69.7	69.7	0.250	100	96	
100	97	41.53	69.4	69.4	0.239	44.01	69.8	69.8	0.238	46.44	70.2	70.2	0.237	100	97	
105	71	13.32	61.6	56.4	1.000	14.22	61.8	56.4	1.000	15.12	61.9	56.5	1.000	105	71	
105	72	13.76	61.0	57.2	0.984	14.23	61.8	57.8	1.000	15.13	62.0	57.8	1.000	105	72	
105	73	14.21	61.7	58.0	0.938	15.11	61.8	58.2	0.943	16.00	61.9	58.3	0.948	105	73	
105	74	14.78	62.3	58.8	0.891	15.70	62.4	58.9	0.896	16.60	62.6	59.1	0.901	105	74	
105	75	15.45	62.8	59.4	0.844	16.39	62.9	59.6	0.850	17.32	63.1	59.7	0.855	105	75	
105	76	16.21	63.2	59.9	0.799	17.18	63.4	60.1	0.804	18.13	63.6	60.3	0.809	105	76	
105	77	17.04	63.5	60.4	0.755	18.05	63.7	60.6	0.759	19.04	63.9	60.9	0.764	105	77	
105	78	17.96	63.8	60.8	0.713	19.01	64.0	61.1	0.717	20.04	64.2	61.3	0.722	105	78	
105	79	18.95	64.0	61.2	0.673	20.05	64.2	61.5	0.677	21.14	64.5	61.7	0.681	105	79	
105	80	19.97	64.2	61.6	0.637	21.13	64.5	61.9	0.641	22.28	64.7	62.1	0.644	105	80	
105	81	21.01	64.4	62.0	0.604	22.24	64.7	62.3	0.607	23.44	64.9	62.5	0.610	105	81	
105	82	22.07	64.6	62.4	0.572	23.37	64.9	62.7	0.575	24.64	65.2	62.9	0.578	105	82	
105	83	23.16	64.8	62.8	0.544	24.52	65.1	63.1	0.546	25.86	65.4	63.4	0.548	105	83	
105	84	24.28	65.0	63.2	0.517	25.71	65.4	63.5	0.519	27.11	65.7	63.8	0.520	105	84	
105	85	25.42	65.3	63.6	0.492	26.92	65.6	63.9	0.493	28.39	65.9	64.2	0.495	105	85	
105	86	26.59	65.5	64.0	0.468	28.16	65.8	64.3	0.469	29.70	66.2	64.7	0.471	105	86	
105	87	27.79	65.7	64.5	0.446	29.43	66.1	64.8	0.447	31.05	66.4	65.1	0.448	105	87	
105	88	29.02	66.0	64.9	0.426	30.74	66.4	65.2	0.426	32.42	66.7	65.6	0.427	105	88	
105	89	30.27	66.2	65.4	0.406	32.07	66.6	65.7	0.407	33.83	67.0	66.0	0.407	105	89	
105	90	31.56	66.5	65.8	0.388	33.43	66.9	66.2	0.388	35.27	67.3	66.5	0.389	105	90	
105	91	32.88	66.7	66.3	0.371	34.83	67.2	66.7	0.371	36.75	67.5	67.0	0.371	105	91	
105	92	34.23	67.0	66.8	0.354	36.27	67.4	67.1	0.354	38.26	67.8	67.5	0.354	105	92	
105	93	35.61	67.3	67.3	0.339	37.73	67.7	67.6	0.339	39.81	68.1	68.0	0.339	105	93	
105	94	37.03	67.8	67.8	0.323	39.23	68.2	68.2	0.323	41.40	68.5	68.5	0.323	105	94	
105	95	38.48	68.3	68.3	0.307	40.77	68.7	68.7	0.307	43.03	69.1	69.1	0.307	105	95	
105	96	39.96	68.8	68.8	0.292	42.35	69.2	69.2	0.292	44.69	69.6	69.6	0.292	105	96	
105	97	41.49	69.3	69.3	0.278	43.96	69.8	69.8	0.278	46.39	70.2	70.2	0.277	105	97	
105	98	43.05	69.9	69.9	0.265	45.62	70.3	70.3	0.264	48.14	70.7	70.7	0.264	105	98	
105	99	44.64	70.4	70.4	0.252	47.31	70.9	70.9	0.251	49.93	71.3	71.3	0.251	105	99	
105	100	46.28	71.0	71.0	0.239	49.04	71.4	71.4	0.239	51.76	71.9	71.9	0.238	105	100	
105	101	47.96	71.6	71.6	0.228	50.82	72.0	72.0	0.227	53.63	72.5	72.5	0.226	105	101	
105	102	49.67	72.2	72.2	0.217	52.64	72.6	72.6	0.216	55.55	73.1	73.1	0.215	105	102	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45 °C Coil Size: DW 61
Leaving Water = 51.67 °C

AIR TEMP. (°F)		AIRFLOW						AIR TEMP. (°F)			
EDB	EWB	340 CFM (FPM = 596)			SHR	360 CFM (FPM = 632)			EDB	EWB	
		MBH	LDB	LWB		MBH	LDB	LWB			
75	59	6.74	56.9	51.7	1.000	7.10	57.0	51.8	1.000	75	59
75	60	6.74	56.9	52.9	1.000	7.10	57.0	52.9	1.000	75	60
75	61	6.74	56.9	54.1	1.000	7.10	57.0	54.1	1.000	75	61
75	62	6.75	56.9	55.2	1.000	7.11	57.0	55.3	1.000	75	62
75	63	7.30	57.2	55.8	0.911	7.65	57.3	55.9	0.917	75	63
75	64	7.77	57.8	56.5	0.830	8.15	57.8	56.6	0.835	75	64
75	65	8.39	58.2	57.0	0.751	8.77	58.3	57.1	0.756	75	65
75	66	9.15	58.5	57.5	0.677	9.56	58.6	57.6	0.681	75	66
75	67	10.03	58.7	57.8	0.611	10.48	58.8	57.9	0.615	75	67
75	68	10.94	58.9	58.1	0.555	11.43	59.0	58.3	0.557	75	68
75	69	11.87	59.0	58.5	0.506	12.40	59.2	58.6	0.508	75	69
75	70	12.82	59.2	58.8	0.464	13.40	59.4	59.0	0.465	75	70
75	71	13.80	59.4	59.2	0.426	14.43	59.6	59.3	0.427	75	71
75	72	14.80	59.6	59.5	0.393	15.47	59.8	59.7	0.393	75	72
80	61	8.27	57.8	52.3	1.000	8.72	57.9	52.4	1.000	80	61
80	62	8.28	57.8	53.5	1.000	8.73	57.9	53.6	1.000	80	62
80	63	8.29	57.8	54.7	1.000	8.73	57.9	54.7	1.000	80	63
80	64	8.60	57.4	55.6	0.980	9.03	57.5	55.6	0.985	80	64
80	65	8.98	58.1	56.4	0.911	9.42	58.2	56.5	0.916	80	65
80	66	9.50	58.7	57.1	0.841	9.95	58.8	57.2	0.846	80	66
80	67	10.15	59.1	57.6	0.772	10.62	59.2	57.7	0.776	80	67
80	68	10.93	59.4	58.1	0.706	11.43	59.6	58.2	0.711	80	68
80	69	11.83	59.6	58.5	0.647	12.36	59.8	58.6	0.650	80	69
80	70	12.78	59.8	58.8	0.594	13.36	60.0	59.0	0.597	80	70
80	71	13.76	60.0	59.1	0.547	14.38	60.2	59.3	0.549	80	71
80	72	14.76	60.2	59.5	0.506	15.43	60.4	59.7	0.507	80	72
80	73	15.78	60.4	59.9	0.469	16.50	60.6	60.0	0.470	80	73
80	74	16.82	60.6	60.2	0.436	17.60	60.8	60.4	0.437	80	74
80	75	17.89	60.8	60.6	0.406	18.72	61.1	60.8	0.406	80	75
80	76	18.99	61.1	61.0	0.379	19.87	61.3	61.2	0.379	80	76
80	77	20.11	61.4	61.4	0.353	21.05	61.6	61.6	0.353	80	77
85	63	9.82	58.6	53.0	1.000	10.35	58.7	53.0	1.000	85	63
85	64	9.82	58.6	54.2	1.000	10.36	58.8	54.2	1.000	85	64
85	65	9.83	58.7	55.4	1.000	10.36	58.8	55.5	1.000	85	65
85	66	10.27	58.4	56.2	0.968	10.79	58.5	56.3	0.972	85	66
85	67	10.71	59.1	57.0	0.906	11.24	59.2	57.1	0.911	85	67
85	68	11.28	59.6	57.7	0.843	11.82	59.7	57.8	0.848	85	68
85	69	11.98	60.0	58.2	0.781	12.54	60.2	58.4	0.786	85	69
85	70	12.79	60.4	58.7	0.723	13.38	60.5	58.9	0.727	85	70
85	71	13.72	60.6	59.1	0.668	14.34	60.8	59.3	0.672	85	71
85	72	14.71	60.8	59.5	0.619	15.39	61.0	59.6	0.622	85	72
85	73	15.73	61.0	59.8	0.575	16.46	61.2	60.0	0.577	85	73
85	74	16.78	61.2	60.2	0.535	17.55	61.4	60.4	0.537	85	74
85	75	17.85	61.4	60.6	0.499	18.68	61.7	60.8	0.501	85	75
85	76	18.94	61.7	60.9	0.467	19.82	61.9	61.1	0.468	85	76
85	77	20.06	61.9	61.3	0.437	21.00	62.1	61.5	0.438	85	77
85	78	21.21	62.1	61.7	0.411	22.20	62.3	61.9	0.411	85	78
85	79	22.38	62.3	62.1	0.386	23.44	62.6	62.3	0.386	85	79
85	80	23.59	62.6	62.5	0.363	24.70	62.8	62.8	0.363	85	80
85	81	24.82	62.9	62.9	0.340	25.99	63.2	63.2	0.340	85	81
85	82	26.07	63.4	63.4	0.318	27.31	63.6	63.6	0.318	85	82

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART Coil Size: DW 61
Entering Water = 45 Leaving Water = 51.67

AIR TEMP. (F)				AIRFLOW								AIR TEMP. (F)			
EDB	EWB	340 CFM (FPM = 596)			360 CFM (FPM = 632)			EDB	EWB	340 CFM (FPM = 596)			360 CFM (FPM = 632)		
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB
90	65	11.36	59.5	53.7	1.000	11.98	59.6	53.8	1.000	90	65				
90	66	11.37	59.5	55.0	1.000	11.99	59.6	55.0	1.000	90	66				
90	67	11.38	59.5	56.2	1.000	12.00	59.6	56.3	1.000	90	67				
90	68	11.97	59.4	56.9	0.954	12.58	59.5	57.0	0.959	90	68				
90	69	12.49	60.1	57.7	0.897	13.11	60.2	57.8	0.902	90	69				
90	70	13.12	60.6	58.3	0.840	13.75	60.7	58.5	0.845	90	70				
90	71	13.87	61.0	58.9	0.784	14.53	61.2	59.0	0.789	90	71				
90	72	14.73	61.4	59.4	0.731	15.42	61.5	59.5	0.735	90	72				
90	73	15.69	61.6	59.8	0.681	16.41	61.8	60.0	0.685	90	73				
90	74	16.74	61.8	60.2	0.634	17.51	62.0	60.3	0.638	90	74				
90	75	17.80	62.0	60.5	0.593	18.63	62.2	60.7	0.596	90	75				
90	76	18.90	62.3	60.9	0.555	19.78	62.5	61.1	0.557	90	76				
90	77	20.02	62.5	61.3	0.521	20.95	62.7	61.5	0.523	90	77				
90	78	21.16	62.7	61.7	0.489	22.16	62.9	61.9	0.491	90	78				
90	79	22.34	62.9	62.1	0.461	23.39	63.2	62.3	0.462	90	79				
90	80	23.54	63.2	62.5	0.434	24.65	63.4	62.7	0.435	90	80				
90	81	24.77	63.4	62.9	0.410	25.94	63.7	63.1	0.410	90	81				
90	82	26.03	63.6	63.3	0.387	27.26	63.9	63.6	0.387	90	82				
90	83	27.32	63.9	63.7	0.366	28.61	64.2	64.0	0.366	90	83				
90	84	28.63	64.2	64.2	0.346	29.99	64.4	64.4	0.346	90	84				
90	85	29.98	64.6	64.6	0.325	31.41	64.9	64.9	0.325	90	85				
90	86	31.37	65.1	65.1	0.306	32.86	65.4	65.4	0.306	90	86				
90	87	32.78	65.5	65.5	0.288	34.35	65.8	65.8	0.287	90	87				
95	67	12.91	60.4	54.6	1.000	13.61	60.5	54.6	1.000	95	67				
95	68	12.92	60.4	55.9	1.000	13.62	60.5	55.9	1.000	95	68				
95	69	12.93	60.4	57.2	1.000	13.63	60.5	57.2	1.000	95	69				
95	70	13.74	60.5	57.6	0.939	14.44	60.6	57.7	0.944	95	70				
95	71	14.32	61.1	58.4	0.887	15.03	61.2	58.5	0.891	95	71				
95	72	15.02	61.6	59.0	0.834	15.75	61.7	59.2	0.838	95	72				
95	73	15.83	62.0	59.6	0.782	16.59	62.2	59.7	0.787	95	73				
95	74	16.75	62.4	60.1	0.733	17.54	62.5	60.3	0.737	95	74				
95	75	17.76	62.6	60.5	0.687	18.58	62.8	60.7	0.691	95	75				
95	76	18.85	62.9	60.9	0.643	19.73	63.1	61.1	0.647	95	76				
95	77	19.97	63.1	61.3	0.604	20.91	63.3	61.5	0.607	95	77				
95	78	21.12	63.3	61.6	0.568	22.11	63.5	61.9	0.571	95	78				
95	79	22.29	63.5	62.0	0.535	23.34	63.8	62.3	0.537	95	79				
95	80	23.49	63.8	62.4	0.505	24.60	64.0	62.7	0.507	95	80				
95	81	24.72	64.0	62.9	0.477	25.89	64.3	63.1	0.479	95	81				
95	82	25.98	64.3	63.3	0.451	27.21	64.5	63.5	0.452	95	82				
95	83	27.27	64.5	63.7	0.427	28.56	64.8	64.0	0.428	95	83				
95	84	28.59	64.8	64.1	0.405	29.94	65.0	64.4	0.406	95	84				
95	85	29.94	65.0	64.6	0.384	31.36	65.3	64.9	0.384	95	85				
95	86	31.32	65.3	65.0	0.365	32.81	65.6	65.3	0.365	95	86				
95	87	32.73	65.5	65.5	0.347	34.29	65.9	65.8	0.346	95	87				
95	88	34.18	66.0	66.0	0.328	35.81	66.3	66.3	0.328	95	88				
95	89	35.67	66.5	66.5	0.310	37.37	66.8	66.8	0.309	95	89				
95	90	37.18	66.9	66.9	0.292	38.96	67.3	67.3	0.292	95	90				
95	91	38.74	67.4	67.4	0.276	40.60	67.8	67.8	0.276	95	91				
95	92	40.33	68.0	68.0	0.261	42.27	68.3	68.3	0.261	95	92				

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 61
Leaving Water = 51.67

		AIRFLOW									
		340 CFM (FPM = 596)			360 CFM (FPM = 632)						
EDB	EWB	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
100	69	14 46	61 2	55 5	1 000	15 25	61 4	55 6	1 000	100	69
100	70	14 47	61 2	56 8	1 000	15 26	61 4	56 9	1 000	100	70
100	71	15 05	60 9	57 6	0 972	15 83	61 0	57 7	0 976	100	71
100	72	15 59	61 6	58 4	0 923	16 38	61 7	58 5	0 928	100	72
100	73	16 24	62 2	59 1	0 874	17 04	62 3	59 3	0 878	100	73
100	74	17 01	62 7	59 8	0 825	17 84	62 8	59 9	0 829	100	74
100	75	17 88	63 1	60 3	0 777	18 74	63 2	60 5	0 781	100	75
100	76	18 85	63 4	60 8	0 731	19 75	63 6	61 0	0 735	100	76
100	77	19 93	63 7	61 2	0 688	20 86	63 9	61 4	0 692	100	77
100	78	21 07	63 9	61 6	0 647	22 06	64 1	61 8	0 651	100	78
100	79	22 25	64 1	62 0	0 610	23 29	64 4	62 2	0 613	100	79
100	80	23 45	64 4	62 4	0 576	24 55	64 6	62 6	0 579	100	80
100	81	24 67	64 6	62 8	0 545	25 84	64 9	63 1	0 547	100	81
100	82	25 93	64 9	63 2	0 516	27 16	65 1	63 5	0 518	100	82
100	83	27 22	65 1	63 7	0 489	28 51	65 4	63 9	0 490	100	83
100	84	28 54	65 4	64 1	0 464	29 89	65 6	64 4	0 465	100	84
100	85	29 89	65 6	64 5	0 440	31 31	65 9	64 8	0 441	100	85
100	86	31 27	65 9	65 0	0 418	32 76	66 2	65 3	0 419	100	86
100	87	32 68	66 2	65 5	0 398	34 24	66 5	65 7	0 398	100	87
100	88	34 13	66 4	65 9	0 379	35 76	66 8	66 2	0 379	100	88
100	89	35 61	66 7	66 4	0 361	37 32	67 1	66 7	0 361	100	89
100	90	37 13	67 0	66 9	0 344	38 91	67 4	67 2	0 344	100	90
100	91	38 69	67 4	67 4	0 327	40 54	67 7	67 7	0 327	100	91
100	92	40 28	67 9	67 9	0 310	42 21	68 2	68 2	0 310	100	92
100	93	41 91	68 4	68 4	0 293	43 92	68 8	68 8	0 293	100	93
100	94	43 58	69 0	69 0	0 278	45 67	69 3	69 3	0 278	100	94
100	95	45 29	69 5	69 5	0 264	47 47	69 8	69 8	0 263	100	95
100	96	47 04	70 0	70 0	0 250	49 30	70 4	70 4	0 249	100	96
100	97	48 83	70 6	70 6	0 237	51 18	71 0	71 0	0 236	100	97
105	71	16 01	62 1	56 5	1 000	16 89	62 2	56 6	1 000	105	71
105	72	16 02	62 1	57 9	1 000	16 90	62 3	58 0	1 000	105	72
105	73	16 88	62 0	58 4	0 952	17 75	62 1	58 5	0 957	105	73
105	74	17 49	62 7	59 2	0 906	18 39	62 8	59 3	0 910	105	74
105	75	18 23	63 2	59 9	0 859	19 13	63 4	60 1	0 864	105	75
105	76	19 08	63 7	60 5	0 813	20 01	63 9	60 7	0 818	105	76
105	77	20 02	64 1	61 1	0 769	20 98	64 3	61 2	0 773	105	77
105	78	21 06	64 5	61 5	0 726	22 06	64 7	61 8	0 730	105	78
105	79	22 20	64 7	62 0	0 685	23 24	64 9	62 2	0 689	105	79
105	80	23 40	65 0	62 4	0 648	24 50	65 2	62 6	0 651	105	80
105	81	24 63	65 2	62 8	0 613	25 79	65 4	63 0	0 616	105	81
105	82	25 88	65 4	63 2	0 580	27 11	65 7	63 5	0 583	105	82
105	83	27 17	65 7	63 6	0 550	28 46	66 0	63 9	0 552	105	83
105	84	28 49	66 0	64 1	0 522	29 84	66 2	64 3	0 524	105	84
105	85	29 84	66 2	64 5	0 496	31 26	66 5	64 8	0 498	105	85
105	86	31 22	66 5	65 0	0 472	32 70	66 8	65 2	0 473	105	86
105	87	32 63	66 8	65 4	0 449	34 19	67 1	65 7	0 450	105	87
105	88	34 08	67 0	65 9	0 428	35 71	67 4	66 2	0 429	105	88
105	89	35 56	67 3	66 4	0 408	37 26	67 7	66 7	0 408	105	89
105	90	37 08	67 6	66 9	0 389	38 86	68 0	67 2	0 389	105	90
105	91	38 64	67 9	67 3	0 371	40 49	68 3	67 7	0 371	105	91
105	92	40 23	68 2	67 9	0 354	42 16	68 6	68 2	0 354	105	92
105	93	41 86	68 5	68 4	0 338	43 87	68 9	68 7	0 338	105	93
105	94	43 53	68 9	68 9	0 323	45 62	69 3	69 3	0 323	105	94
105	95	45 24	69 4	69 4	0 307	47 41	69 8	69 8	0 307	105	95
105	96	46 99	70 0	70 0	0 292	49 25	70 4	70 4	0 292	105	96
105	97	48 78	70 6	70 6	0 277	51 13	70 9	70 9	0 277	105	97
105	98	50 62	71 1	71 1	0 263	53 05	71 5	71 5	0 263	105	98
105	99	52 50	71 7	71 7	0 250	55 02	72 1	72 1	0 250	105	99
105	100	54 42	72 3	72 3	0 238	57 04	72 7	72 7	0 237	105	100
105	101	56 40	72 9	72 9	0 226	59 11	73 3	73 3	0 225	105	101
105	102	58 42	73 5	73 5	0 214	61 23	73 9	73 9	0 214	105	102

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 62
Leaving Water = 51.67

AIR TEMP. (F)		AIRFLOW												AIR TEMP. (F)	
EDB	EWB	240 CFM (FPM = 267)				275 CFM (FPM = 306)				310 CFM (FPM = 344)				EDB	EWB
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR		
75	59	5.63	53.6	50.3	1.000	6.41	53.7	50.4	1.000	7.19	53.8	50.4	1.000	75	59
75	60	5.63	53.6	51.5	1.000	6.42	53.7	51.6	1.000	7.19	53.8	51.6	1.000	75	60
75	61	6.00	53.5	52.1	0.946	6.79	53.5	52.2	0.953	7.57	53.6	52.3	0.960	75	61
75	62	6.39	53.9	52.7	0.868	7.22	54.1	52.9	0.876	8.02	54.2	53.0	0.883	75	62
75	63	6.91	54.2	53.1	0.793	7.78	54.4	53.3	0.800	8.63	54.6	53.5	0.807	75	63
75	64	7.52	54.4	53.4	0.723	8.46	54.6	53.6	0.729	9.37	54.8	53.8	0.736	75	64
75	65	8.23	54.5	53.6	0.660	9.24	54.7	53.8	0.666	10.22	54.9	54.1	0.671	75	65
75	66	8.95	54.5	53.8	0.606	10.06	54.8	54.0	0.610	11.14	55.0	54.3	0.614	75	66
75	67	9.70	54.5	53.9	0.559	10.91	54.8	54.2	0.562	12.08	55.1	54.5	0.565	75	67
75	68	10.45	54.6	54.1	0.518	11.77	54.9	54.4	0.520	13.04	55.1	54.7	0.522	75	68
75	69	11.23	54.6	54.3	0.482	12.64	54.9	54.6	0.483	14.02	55.2	54.9	0.485	75	69
75	70	12.02	54.7	54.5	0.450	13.54	55.0	54.8	0.450	15.02	55.3	55.1	0.451	75	70
75	71	12.83	54.7	54.7	0.421	14.46	55.1	55.0	0.421	16.05	55.4	55.3	0.421	75	71
75	72	13.65	54.9	54.9	0.393	15.39	55.2	55.2	0.393	17.09	55.5	55.5	0.393	75	72
80	61	6.79	54.1	50.8	1.000	7.74	54.3	50.8	1.000	8.69	54.4	50.9	1.000	80	61
80	62	6.80	54.2	52.0	1.000	7.75	54.3	52.1	1.000	8.69	54.4	52.1	1.000	80	62
80	63	7.28	54.1	52.5	0.937	8.25	54.2	52.6	0.944	9.20	54.3	52.7	0.950	80	63
80	64	7.73	54.5	53.0	0.869	8.74	54.7	53.2	0.876	9.72	54.8	53.3	0.883	80	64
80	65	8.29	54.8	53.4	0.802	9.35	55.0	53.6	0.809	10.38	55.2	53.8	0.816	80	65
80	66	8.94	55.0	53.7	0.740	10.06	55.2	54.0	0.746	11.16	55.4	54.2	0.752	80	66
80	67	9.66	55.0	53.9	0.683	10.87	55.3	54.2	0.689	12.05	55.5	54.4	0.694	80	67
80	68	10.42	55.1	54.1	0.633	11.73	55.4	54.4	0.638	13.00	55.6	54.6	0.642	80	68
80	69	11.20	55.1	54.3	0.589	12.61	55.4	54.6	0.593	13.98	55.7	54.9	0.596	80	69
80	70	11.99	55.2	54.5	0.550	13.50	55.5	54.8	0.552	14.98	55.8	55.1	0.555	80	70
80	71	12.79	55.2	54.7	0.515	14.42	55.6	55.0	0.517	16.00	55.9	55.3	0.518	80	71
80	72	13.62	55.3	54.9	0.483	15.36	55.6	55.2	0.484	17.05	56.0	55.5	0.485	80	72
80	73	14.46	55.4	55.1	0.455	16.31	55.7	55.4	0.455	18.12	56.0	55.7	0.456	80	73
80	74	15.33	55.4	55.3	0.429	17.29	55.8	55.7	0.429	19.21	56.1	56.0	0.429	80	74
80	75	16.21	55.5	55.5	0.404	18.29	55.9	55.9	0.404	20.33	56.2	56.2	0.404	80	75
80	76	17.11	55.8	55.8	0.380	19.32	56.1	56.1	0.380	21.47	56.5	56.5	0.379	80	76
80	77	18.04	56.0	56.0	0.357	20.36	56.4	56.4	0.357	22.64	56.7	56.7	0.356	80	77
85	63	7.95	54.7	51.3	1.000	9.07	54.9	51.4	1.000	10.18	55.0	51.5	1.000	85	63
85	64	7.96	54.7	52.6	1.000	9.08	54.9	52.7	1.000	10.19	55.0	52.7	1.000	85	64
85	65	8.60	54.7	52.9	0.926	9.75	54.9	53.0	0.933	10.88	55.0	53.2	0.939	85	65
85	66	9.11	55.1	53.4	0.864	10.30	55.3	53.6	0.871	11.47	55.4	53.7	0.878	85	66
85	67	9.72	55.4	53.8	0.805	10.96	55.6	54.0	0.811	12.19	55.8	54.2	0.817	85	67
85	68	10.40	55.6	54.1	0.748	11.73	55.8	54.3	0.754	13.02	56.0	54.6	0.760	85	68
85	69	11.16	55.6	54.3	0.697	12.57	55.9	54.6	0.702	13.94	56.2	54.8	0.707	85	69
85	70	11.95	55.7	54.5	0.650	13.47	56.0	54.8	0.655	14.94	56.3	55.0	0.659	85	70
85	71	12.76	55.7	54.7	0.609	14.38	56.1	55.0	0.612	15.96	56.3	55.3	0.616	85	71
85	72	13.59	55.8	54.9	0.572	15.32	56.1	55.2	0.574	17.00	56.4	55.5	0.577	85	72
85	73	14.43	55.9	55.1	0.538	16.27	56.2	55.4	0.540	18.07	56.5	55.7	0.542	85	73
85	74	15.29	55.9	55.3	0.507	17.25	56.3	55.6	0.509	19.16	56.6	56.0	0.510	85	74
85	75	16.17	56.0	55.5	0.479	18.25	56.4	55.9	0.480	20.28	56.7	56.2	0.481	85	75
85	76	17.08	56.1	55.7	0.453	19.27	56.5	56.1	0.454	21.42	56.8	56.5	0.455	85	76
85	77	18.00	56.1	56.0	0.430	20.32	56.5	56.4	0.430	22.59	56.9	56.7	0.430	85	77
85	78	18.94	56.2	56.2	0.408	21.39	56.6	56.6	0.408	23.79	57.0	57.0	0.408	85	78
85	79	19.91	56.5	56.5	0.386	22.49	56.9	56.9	0.385	25.01	57.2	57.2	0.385	85	79
85	80	20.90	56.7	56.7	0.365	23.61	57.1	57.1	0.364	26.26	57.5	57.5	0.364	85	80
85	81	21.91	57.0	57.0	0.345	24.76	57.4	57.4	0.345	27.54	57.8	57.8	0.344	85	81
85	82	22.95	57.2	57.2	0.327	25.93	57.7	57.7	0.326	28.85	58.1	58.1	0.326	85	82

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 62
Leaving Water = 51.67

AIR TEMP. (F)		AIRFLOW								AIR TEMP. (F)					
EDB	EWB	240 CFM (FPM = 267)				275 CFM (FPM = 306)			310 CFM (FPM = 344)			EDB	EWB		
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR		
90	65	9.11	55.3	52.0	1.000	10.40	55.5	52.1	1.000	11.68	55.6	52.1	1.000	90	65
90	66	9.52	54.9	52.7	0.970	10.81	55.0	52.8	0.976	12.09	55.1	52.9	0.981	90	66
90	67	9.97	55.4	53.3	0.914	11.30	55.6	53.5	0.920	12.61	55.7	53.6	0.926	90	67
90	68	10.54	55.8	53.8	0.857	11.92	56.0	54.0	0.863	13.28	56.1	54.2	0.869	90	68
90	69	11.20	56.0	54.1	0.802	12.64	56.2	54.4	0.808	14.06	56.4	54.6	0.814	90	69
90	70	11.93	56.2	54.4	0.751	13.46	56.4	54.7	0.756	14.95	56.7	55.0	0.762	90	70
90	71	12.73	56.2	54.6	0.703	14.34	56.5	54.9	0.708	15.92	56.8	55.2	0.713	90	71
90	72	13.55	56.3	54.8	0.660	15.28	56.6	55.2	0.664	16.96	56.9	55.5	0.669	90	72
90	73	14.39	56.4	55.0	0.621	16.23	56.7	55.4	0.625	18.03	57.0	55.7	0.628	90	73
90	74	15.26	56.4	55.3	0.586	17.21	56.8	55.6	0.589	19.12	57.1	55.9	0.592	90	74
90	75	16.14	56.5	55.5	0.554	18.21	56.9	55.8	0.556	20.23	57.2	56.2	0.558	90	75
90	76	17.04	56.6	55.7	0.524	19.23	56.9	56.1	0.526	21.38	57.3	56.4	0.528	90	76
90	77	17.96	56.6	55.9	0.497	20.28	57.0	56.3	0.498	22.54	57.4	56.7	0.499	90	77
90	78	18.90	56.7	56.2	0.472	21.35	57.1	56.6	0.473	23.74	57.5	56.9	0.473	90	78
90	79	19.87	56.8	56.4	0.449	22.44	57.2	56.8	0.449	24.96	57.6	57.2	0.450	90	79
90	80	20.86	56.9	56.7	0.427	23.57	57.3	57.1	0.427	26.21	57.7	57.5	0.427	90	80
90	81	21.87	56.9	56.9	0.407	24.71	57.4	57.4	0.407	27.49	57.9	57.8	0.407	90	81
90	82	22.91	57.2	57.2	0.386	25.89	57.6	57.6	0.386	28.80	58.1	58.1	0.386	90	82
90	83	23.97	57.5	57.5	0.367	27.09	57.9	57.9	0.367	30.15	58.4	58.4	0.366	90	83
90	84	25.05	57.8	57.8	0.349	28.32	58.2	58.2	0.348	31.52	58.7	58.7	0.348	90	84
90	85	26.16	58.0	58.0	0.331	29.58	58.5	58.5	0.331	32.93	59.0	59.0	0.330	90	85
90	86	27.30	58.3	58.3	0.315	30.87	58.8	58.8	0.314	34.37	59.3	59.3	0.314	90	86
90	87	28.47	58.6	58.6	0.300	32.20	59.2	59.2	0.299	35.84	59.6	59.6	0.298	90	87
95	67	10.27	55.9	52.8	1.000	11.73	56.1	52.8	1.000	13.18	56.2	52.9	1.000	95	67
95	68	10.87	55.7	53.2	0.952	12.35	55.8	53.3	0.958	13.80	55.9	53.5	0.964	95	68
95	69	11.40	56.1	53.8	0.899	12.92	56.3	54.0	0.905	14.42	56.4	54.1	0.911	95	69
95	70	12.03	56.4	54.2	0.846	13.61	56.6	54.4	0.853	15.16	56.8	54.6	0.859	95	70
95	71	12.74	56.6	54.5	0.796	14.39	56.9	54.8	0.802	16.01	57.1	55.1	0.808	95	71
95	72	13.52	56.8	54.8	0.749	15.26	57.1	55.1	0.754	16.96	57.3	55.4	0.760	95	72
95	73	14.36	56.8	55.0	0.705	16.19	57.2	55.4	0.710	17.98	57.5	55.7	0.715	95	73
95	74	15.22	56.9	55.2	0.665	17.17	57.3	55.6	0.669	19.07	57.6	55.9	0.673	95	74
95	75	16.10	57.0	55.5	0.628	18.17	57.3	55.8	0.632	20.19	57.7	56.1	0.635	95	75
95	76	17.00	57.1	55.7	0.595	19.19	57.4	56.1	0.598	21.33	57.8	56.4	0.601	95	76
95	77	17.92	57.1	55.9	0.564	20.24	57.5	56.3	0.566	22.50	57.9	56.7	0.569	95	77
95	78	18.87	57.2	56.1	0.535	21.31	57.6	56.5	0.537	23.69	58.0	56.9	0.539	95	78
95	79	19.83	57.3	56.4	0.509	22.40	57.7	56.8	0.511	24.91	58.1	57.2	0.512	95	79
95	80	20.82	57.4	56.6	0.485	23.52	57.8	57.1	0.486	26.16	58.2	57.5	0.487	95	80
95	81	21.83	57.4	56.9	0.462	24.67	57.9	57.3	0.463	27.44	58.3	57.7	0.464	95	81
95	82	22.87	57.5	57.2	0.441	25.84	58.0	57.6	0.441	28.75	58.5	58.0	0.442	95	82
95	83	23.93	57.6	57.4	0.421	27.04	58.1	57.9	0.421	30.09	58.6	58.3	0.421	95	83
95	84	25.01	57.7	57.7	0.403	28.27	58.2	58.2	0.403	31.47	58.7	58.6	0.402	95	84
95	85	26.12	58.0	58.0	0.383	29.54	58.5	58.5	0.383	32.87	58.9	58.9	0.384	95	85
95	86	27.26	58.3	58.3	0.365	30.83	58.8	58.8	0.365	34.31	59.3	59.3	0.365	95	86
95	87	28.43	58.6	58.6	0.348	32.15	59.1	59.1	0.348	35.79	59.6	59.6	0.347	95	87
95	88	29.62	58.9	58.9	0.332	33.50	59.4	59.4	0.331	37.30	59.9	59.9	0.331	95	88
95	89	30.84	59.2	59.2	0.317	34.89	59.8	59.8	0.316	38.85	60.3	60.3	0.315	95	89
95	90	32.10	59.6	59.6	0.302	36.31	60.1	60.1	0.301	40.43	60.6	60.6	0.300	95	90
95	91	33.38	59.9	59.9	0.288	37.76	60.5	60.5	0.287	42.05	61.0	61.0	0.286	95	91
95	92	34.70	60.2	60.2	0.275	39.25	60.8	60.8	0.274	43.72	61.4	61.4	0.273	95	92

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 62
Leaving Water = 51.67

AIR TEMP. (F)		AIRFLOW								AIR TEMP. (F)					
EDB	EWB	345 CFM (FPM = 383)				380 CFM (FPM = 422)				415 CFM (FPM = 461)				EDB	EWB
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR		
75	59	7.96	53.9	50.5	1.000	8.72	54.0	50.5	1.000	9.47	54.1	50.6	1.000	75	59
75	60	7.96	53.9	51.7	1.000	8.73	54.0	51.7	1.000	9.48	54.1	51.7	1.000	75	60
75	61	8.34	53.7	52.4	0.966	9.10	53.8	52.5	0.972	9.85	53.9	52.6	0.977	75	61
75	62	8.82	54.3	53.1	0.890	9.60	54.4	53.2	0.896	10.37	54.5	53.3	0.902	75	62
75	63	9.46	54.7	53.6	0.813	10.28	54.8	53.8	0.819	11.08	55.0	53.9	0.825	75	63
75	64	10.26	55.0	54.0	0.741	11.13	55.1	54.2	0.747	11.98	55.3	54.3	0.752	75	64
75	65	11.18	55.1	54.3	0.676	12.12	55.3	54.5	0.680	13.03	55.5	54.7	0.685	75	65
75	66	12.19	55.2	54.5	0.618	13.22	55.4	54.7	0.621	14.21	55.6	54.9	0.625	75	66
75	67	13.23	55.3	54.7	0.568	14.35	55.5	54.9	0.570	15.43	55.7	55.1	0.573	75	67
75	68	14.29	55.4	54.9	0.524	15.50	55.6	55.1	0.526	16.68	55.8	55.3	0.528	75	68
75	69	15.36	55.5	55.1	0.486	16.68	55.7	55.4	0.487	17.96	55.9	55.6	0.488	75	69
75	70	16.47	55.6	55.4	0.452	17.88	55.8	55.6	0.452	19.26	56.1	55.8	0.453	75	70
75	71	17.60	55.7	55.6	0.421	19.11	55.9	55.8	0.421	20.59	56.2	56.1	0.421	75	71
75	72	18.75	55.8	55.8	0.393	20.37	56.1	56.1	0.393	21.95	56.3	56.3	0.393	75	72
80	61	9.62	54.5	50.9	1.000	10.55	54.6	51.0	1.000	11.47	54.7	51.0	1.000	80	61
80	62	9.63	54.5	52.2	1.000	10.56	54.6	52.2	1.000	11.48	54.7	52.3	1.000	80	62
80	63	10.14	54.4	52.8	0.956	11.07	54.5	52.9	0.962	11.99	54.5	53.0	0.967	80	63
80	64	10.69	54.9	53.5	0.889	11.65	55.0	53.6	0.895	12.59	55.1	53.7	0.900	80	64
80	65	11.40	55.3	54.0	0.822	12.39	55.5	54.1	0.828	13.37	55.6	54.3	0.833	80	65
80	66	12.24	55.6	54.4	0.758	13.29	55.8	54.6	0.763	14.32	55.9	54.7	0.768	80	66
80	67	13.19	55.8	54.7	0.699	14.31	56.0	54.9	0.704	15.41	56.1	55.1	0.708	80	67
80	68	14.24	55.9	54.9	0.646	15.45	56.1	55.1	0.650	16.63	56.3	55.3	0.653	80	68
80	69	15.32	55.9	55.1	0.599	16.63	56.2	55.3	0.602	17.90	56.4	55.6	0.605	80	69
80	70	16.42	56.0	55.3	0.557	17.83	56.3	55.6	0.560	19.20	56.5	55.8	0.562	80	70
80	71	17.55	56.1	55.6	0.520	19.06	56.4	55.8	0.522	20.53	56.6	56.1	0.523	80	71
80	72	18.70	56.2	55.8	0.487	20.31	56.5	56.1	0.488	21.89	56.8	56.3	0.489	80	72
80	73	19.88	56.3	56.0	0.456	21.60	56.6	56.3	0.457	23.28	56.9	56.6	0.458	80	73
80	74	21.08	56.5	56.3	0.429	22.91	56.8	56.6	0.429	24.70	57.0	56.8	0.430	80	74
80	75	22.31	56.6	56.5	0.404	24.26	56.9	56.8	0.404	26.16	57.2	57.1	0.404	80	75
80	76	23.57	56.8	56.8	0.379	25.63	57.1	57.1	0.379	27.65	57.4	57.4	0.379	80	76
80	77	24.86	57.1	57.1	0.356	27.04	57.4	57.4	0.356	29.17	57.7	57.7	0.355	80	77
85	63	11.29	55.1	51.5	1.000	12.38	55.2	51.6	1.000	13.47	55.3	51.6	1.000	85	63
85	64	11.30	55.1	52.8	1.000	12.39	55.2	52.8	1.000	13.48	55.4	52.9	1.000	85	64
85	65	11.99	55.1	53.3	0.945	13.09	55.2	53.4	0.950	14.18	55.3	53.5	0.955	85	65
85	66	12.62	55.6	53.9	0.884	13.75	55.7	54.0	0.889	14.87	55.8	54.2	0.895	85	66
85	67	13.39	56.0	54.4	0.823	14.57	56.1	54.6	0.829	15.73	56.3	54.7	0.834	85	67
85	68	14.28	56.2	54.8	0.766	15.52	56.4	55.0	0.771	16.74	56.6	55.2	0.776	85	68
85	69	15.28	56.4	55.1	0.712	16.60	56.6	55.3	0.717	17.88	56.8	55.5	0.721	85	69
85	70	16.38	56.5	55.3	0.663	17.78	56.7	55.6	0.667	19.15	57.0	55.8	0.671	85	70
85	71	17.50	56.6	55.5	0.619	19.01	56.9	55.8	0.622	20.48	57.1	56.0	0.626	85	71
85	72	18.65	56.7	55.8	0.580	20.26	57.0	56.0	0.582	21.84	57.2	56.3	0.585	85	72
85	73	19.83	56.8	56.0	0.544	21.55	57.1	56.3	0.546	23.22	57.4	56.5	0.548	85	73
85	74	21.03	56.9	56.3	0.512	22.86	57.2	56.5	0.513	24.65	57.5	56.8	0.515	85	74
85	75	22.26	57.0	56.5	0.482	24.20	57.3	56.8	0.483	26.10	57.6	57.1	0.484	85	75
85	76	23.52	57.2	56.8	0.455	25.57	57.5	57.1	0.456	27.58	57.8	57.4	0.457	85	76
85	77	24.81	57.3	57.0	0.430	26.98	57.6	57.4	0.431	29.10	57.9	57.7	0.431	85	77
85	78	26.13	57.4	57.3	0.408	28.42	57.7	57.6	0.408	30.66	58.1	58.0	0.408	85	78
85	79	27.47	57.6	57.6	0.385	29.89	57.9	57.9	0.385	32.25	58.3	58.3	0.386	85	79
85	80	28.85	57.9	57.9	0.364	31.39	58.2	58.2	0.364	33.88	58.6	58.6	0.363	85	80
85	81	30.27	58.2	58.2	0.344	32.93	58.5	58.5	0.343	35.55	58.9	58.9	0.343	85	81
85	82	31.71	58.5	58.5	0.325	34.51	58.9	58.9	0.324	37.25	59.2	59.2	0.324	85	82

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 62
Leaving Water = 51.67

AIR TEMP. (F)		AIRFLOW								AIR TEMP (F)					
		345 CFM (FPM = 383)				380 CFM (FPM = 422)				415 CFM (FPM = 461)					
EDB	EWB	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
90	65	12.95	55.7	52.2	1.000	14.21	55.8	52.2	1.000	15.47	56.0	52.3	1.000	90	65
90	66	12.96	55.7	53.5	1.000	14.22	55.9	53.5	1.000	15.48	56.0	53.6	1.000	90	66
90	67	13.90	55.8	53.8	0.932	15.18	55.9	53.9	0.937	16.44	56.0	54.0	0.942	90	67
90	68	14.61	56.3	54.4	0.875	15.93	56.4	54.5	0.881	17.22	56.6	54.7	0.886	90	68
90	69	15.45	56.6	54.8	0.820	16.82	56.8	55.0	0.825	18.17	57.0	55.2	0.831	90	69
90	70	16.41	56.9	55.2	0.767	17.84	57.1	55.4	0.773	19.25	57.3	55.6	0.777	90	70
90	71	17.46	57.1	55.5	0.718	18.97	57.3	55.7	0.723	20.46	57.5	56.0	0.727	90	71
90	72	18.60	57.2	55.7	0.673	20.21	57.4	56.0	0.677	21.78	57.7	56.3	0.681	90	72
90	73	19.78	57.3	56.0	0.632	21.49	57.6	56.3	0.635	23.17	57.8	56.5	0.638	90	73
90	74	20.98	57.4	56.2	0.594	22.80	57.7	56.5	0.597	24.59	58.0	56.8	0.600	90	74
90	75	22.21	57.5	56.5	0.560	24.15	57.8	56.8	0.563	26.04	58.1	57.1	0.565	90	75
90	76	23.47	57.6	56.7	0.529	25.52	57.9	57.1	0.531	27.52	58.2	57.3	0.533	90	76
90	77	24.76	57.8	57.0	0.501	26.92	58.1	57.3	0.502	29.04	58.4	57.6	0.503	90	77
90	78	26.07	57.9	57.3	0.474	28.36	58.2	57.6	0.475	30.60	58.5	57.9	0.476	90	78
90	79	27.42	58.0	57.6	0.450	29.83	58.4	57.9	0.451	32.19	58.7	58.2	0.451	90	79
90	80	28.80	58.1	57.9	0.428	31.33	58.5	58.2	0.428	33.82	58.8	58.5	0.428	90	80
90	81	30.21	58.3	58.2	0.407	32.87	58.6	58.5	0.407	35.48	59.0	58.8	0.407	90	81
90	82	31.66	58.5	58.5	0.386	34.45	58.8	58.8	0.386	37.19	59.2	59.2	0.387	90	82
90	83	33.13	58.8	58.8	0.366	36.06	59.1	59.1	0.366	38.93	59.5	59.5	0.366	90	83
90	84	34.65	59.1	59.1	0.347	37.72	59.5	59.5	0.347	40.72	59.8	59.8	0.347	90	84
90	85	36.20	59.4	59.4	0.330	39.41	59.8	59.8	0.329	42.55	60.2	60.2	0.329	90	85
90	86	37.79	59.7	59.7	0.313	41.14	60.2	60.2	0.312	44.42	60.6	60.6	0.312	90	86
90	87	39.41	60.1	60.1	0.297	42.91	60.5	60.5	0.296	46.34	60.9	60.9	0.296	90	87
95	67	14.62	56.3	52.9	1.000	16.04	56.5	53.0	1.000	17.46	56.6	53.0	1.000	95	67
95	68	15.24	56.0	53.6	0.969	16.67	56.1	53.7	0.973	18.08	56.2	53.8	0.978	95	68
95	69	15.89	56.6	54.3	0.917	17.34	56.7	54.4	0.922	18.78	56.8	54.6	0.927	95	69
95	70	16.68	57.0	54.8	0.864	18.19	57.2	55.0	0.870	19.67	57.3	55.2	0.875	95	70
95	71	17.60	57.3	55.3	0.813	19.16	57.5	55.5	0.819	20.70	57.7	55.7	0.824	95	71
95	72	18.62	57.6	55.7	0.765	20.26	57.8	55.9	0.770	21.86	58.0	56.1	0.775	95	72
95	73	19.74	57.7	56.0	0.720	21.45	58.0	56.2	0.724	23.14	58.2	56.5	0.728	95	73
95	74	20.93	57.9	56.2	0.677	22.75	58.1	56.5	0.681	24.53	58.4	56.8	0.685	95	74
95	75	22.16	58.0	56.5	0.639	24.09	58.3	56.8	0.642	25.98	58.5	57.0	0.645	95	75
95	76	23.42	58.1	56.7	0.603	25.46	58.4	57.0	0.606	27.46	58.7	57.3	0.609	95	76
95	77	24.70	58.2	57.0	0.571	26.87	58.5	57.3	0.573	28.98	58.8	57.6	0.576	95	77
95	78	26.02	58.3	57.3	0.541	28.30	58.7	57.6	0.543	30.54	59.0	57.9	0.545	95	78
95	79	27.37	58.5	57.5	0.514	29.77	58.8	57.9	0.515	32.13	59.1	58.2	0.517	95	79
95	80	28.74	58.6	57.8	0.488	31.27	59.0	58.2	0.489	33.75	59.3	58.5	0.490	95	80
95	81	30.16	58.7	58.1	0.464	32.81	59.1	58.5	0.465	35.42	59.5	58.8	0.466	95	81
95	82	31.60	58.9	58.4	0.442	34.39	59.3	58.8	0.443	37.12	59.6	59.1	0.443	95	82
95	83	33.08	59.0	58.7	0.422	36.00	59.4	59.1	0.422	38.87	59.8	59.5	0.422	95	83
95	84	34.59	59.2	59.0	0.402	37.65	59.6	59.4	0.402	40.65	60.0	59.8	0.402	95	84
95	85	36.14	59.4	59.4	0.384	39.34	59.8	59.8	0.384	42.48	60.2	60.2	0.384	95	85
95	86	37.73	59.7	59.7	0.365	41.07	60.1	60.1	0.365	44.35	60.5	60.5	0.365	95	86
95	87	39.35	60.0	60.0	0.347	42.85	60.5	60.5	0.347	46.27	60.9	60.9	0.347	95	87
95	88	41.02	60.4	60.4	0.330	44.66	60.8	60.8	0.330	48.24	61.2	61.2	0.330	95	88
95	89	42.72	60.8	60.8	0.315	46.52	61.2	61.2	0.314	50.25	61.6	61.6	0.313	95	89
95	90	44.47	61.1	61.1	0.300	48.42	61.6	61.6	0.299	52.30	62.0	62.0	0.298	95	90
95	91	46.26	61.5	61.5	0.285	50.37	62.0	62.0	0.285	54.41	62.4	62.4	0.284	95	91
95	92	48.09	61.9	61.9	0.272	52.37	62.4	62.4	0.271	56.57	62.8	62.8	0.270	95	92

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 62
Leaving Water = 51.67

AIR TEMP (°F) EDB	EWB	AIRFLOW								AIR TEMP (°F) EDB					
		345 CFM (FPM = 383)				380 CFM (FPM = 422)				415 CFM (FPM = 461)					
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR		
100	69	16 28	57 0	53 8	1 000	17 88	57 1	53 9	1 000	19 46	57 2	53 9	1 000	100	69
100	70	17 21	56 8	54 2	0 950	18 81	56 9	54 4	0 955	20 40	57 0	54 5	0 959	100	70
100	71	17 96	57 3	54 8	0 901	19 60	57 5	55 0	0 906	21 22	57 6	55 2	0 911	100	71
100	72	18 84	57 7	55 4	0 852	20 54	57 9	55 6	0 857	22 21	58 1	55 7	0 862	100	72
100	73	19 84	58 0	55 8	0 804	21 60	58 3	56 0	0 810	23 34	58 5	56 2	0 814	100	73
100	74	20 93	58 3	56 1	0 759	22 77	58 5	56 4	0 764	24 58	58 8	56 6	0 769	100	74
100	75	22 11	58 4	56 4	0 717	24 04	58 7	56 7	0 722	25 94	59 0	57 0	0 726	100	75
100	76	23 37	58 6	56 7	0 678	25 41	58 9	57 0	0 682	27 40	59 1	57 3	0 685	100	76
100	77	24 65	58 7	57 0	0 641	26 81	59 0	57 3	0 645	28 92	59 3	57 6	0 648	100	77
100	78	25 97	58 8	57 2	0 608	28 24	59 1	57 6	0 611	30 47	59 4	57 9	0 614	100	78
100	79	27 31	58 9	57 5	0 577	29 71	59 3	57 8	0 580	32 06	59 6	58 2	0 582	100	79
100	80	28 69	59 1	57 8	0 549	31 21	59 4	58 1	0 551	33 69	59 8	58 5	0 553	100	80
100	81	30 10	59 2	58 1	0 522	32 75	59 6	58 4	0 524	35 35	59 9	58 8	0 525	100	81
100	82	31 54	59 4	58 4	0 497	34 33	59 7	58 8	0 499	37 06	60 1	59 1	0 500	100	82
100	83	33 02	59 5	58 7	0 474	35 94	59 9	59 1	0 475	38 80	60 3	59 4	0 476	100	83
100	84	34 53	59 7	59 0	0 453	37 59	60 1	59 4	0 453	40 59	60 5	59 8	0 454	100	84
100	85	36 08	59 8	59 3	0 433	39 28	60 2	59 7	0 433	42 41	60 6	60 1	0 433	100	85
100	86	37 67	60 0	59 7	0 414	41 01	60 4	60 1	0 414	44 29	60 8	60 5	0 414	100	86
100	87	39 29	60 1	60 0	0 396	42 78	60 6	60 4	0 396	46 20	61 0	60 8	0 396	100	87
100	88	40 96	60 4	60 4	0 378	44 60	60 8	60 8	0 378	48 16	61 2	61 2	0 378	100	88
100	89	42 66	60 7	60 7	0 361	46 45	61 2	61 2	0 361	50 17	61 6	61 6	0 361	100	89
100	90	44 41	61 1	61 1	0 344	48 36	61 5	61 5	0 344	52 23	62 0	62 0	0 344	100	90
100	91	46 19	61 5	61 5	0 328	50 31	61 9	61 9	0 328	54 34	62 4	62 4	0 328	100	91
100	92	48 02	61 8	61 8	0 313	52 30	62 3	62 3	0 313	56 50	62 8	62 8	0 312	100	92
100	93	49 90	62 2	62 2	0 299	54 35	62 7	62 7	0 298	58 71	63 2	63 2	0 298	100	93
100	94	51 82	62 6	62 6	0 286	56 44	63 2	63 2	0 285	60 98	63 6	63 6	0 284	100	94
100	95	53 79	63 1	63 1	0 273	58 59	63 6	63 6	0 272	63 30	64 1	64 1	0 271	100	95
100	96	55 81	63 5	63 5	0 261	60 79	64 0	64 0	0 260	65 68	64 5	64 5	0 259	100	96
100	97	57 88	63 9	63 9	0 249	63 04	64 5	64 5	0 248	68 11	65 0	65 0	0 247	100	97
105	71	18 58	57 1	54 1	0 977	20 33	57 2	54 2	0 981	22 07	57 2	54 4	0 985	105	71
105	72	19 28	57 7	54 8	0 931	21 06	57 8	55 0	0 935	22 83	57 9	55 1	0 940	105	72
105	73	20 13	58 1	55 4	0 884	21 96	58 3	55 6	0 889	23 77	58 5	55 8	0 894	105	73
105	74	21 10	58 5	55 9	0 838	23 00	58 7	56 1	0 843	24 87	58 9	56 3	0 848	105	74
105	75	22 18	58 8	56 3	0 794	24 15	59 0	56 5	0 799	26 09	59 2	56 8	0 803	105	75
105	76	23 35	59 0	56 6	0 752	25 40	59 3	56 9	0 756	27 43	59 5	57 2	0 761	105	76
105	77	24 60	59 1	56 9	0 712	26 75	59 5	57 2	0 716	28 86	59 7	57 5	0 721	105	77
105	78	25 91	59 3	57 2	0 675	28 19	59 6	57 5	0 679	30 41	59 9	57 8	0 683	105	78
105	79	27 26	59 4	57 5	0 641	29 65	59 7	57 8	0 644	32 00	60 1	58 1	0 648	105	79
105	80	28 64	59 5	57 8	0 609	31 16	59 9	58 1	0 612	33 62	60 2	58 4	0 615	105	80
105	81	30 05	59 7	58 1	0 580	32 69	60 0	58 4	0 582	35 29	60 4	58 7	0 585	105	81
105	82	31 49	59 8	58 4	0 553	34 27	60 2	58 7	0 555	36 99	60 6	59 1	0 557	105	82
105	83	32 96	60 0	58 7	0 527	35 88	60 4	59 0	0 529	38 73	60 7	59 4	0 531	105	83
105	84	34 48	60 1	59 0	0 503	37 53	60 5	59 4	0 505	40 52	60 9	59 7	0 506	105	84
105	85	36 02	60 3	59 3	0 481	39 22	60 7	59 7	0 482	42 34	61 1	60 1	0 483	105	85
105	86	37 61	60 4	59 6	0 460	40 95	60 9	60 0	0 461	44 22	61 3	60 4	0 462	105	86
105	87	39 23	60 6	60 0	0 440	42 72	61 1	60 4	0 441	46 13	61 5	60 8	0 441	105	87
105	88	40 90	60 8	60 3	0 422	44 53	61 2	60 8	0 422	48 09	61 7	61 2	0 422	105	88
105	89	42 60	60 9	60 7	0 404	46 39	61 4	61 1	0 404	50 10	61 9	61 5	0 404	105	89
105	90	44 34	61 1	61 0	0 388	48 29	61 6	61 5	0 387	52 16	62 1	61 9	0 387	105	90
105	91	46 13	61 4	61 4	0 371	50 24	61 9	61 9	0 371	54 27	62 3	62 3	0 371	105	91
105	92	47 96	61 8	61 8	0 354	52 23	62 3	62 3	0 354	56 43	62 7	62 7	0 354	105	92
105	93	49 84	62 2	62 2	0 339	54 28	62 7	62 7	0 339	58 64	63 2	63 2	0 338	105	93
105	94	51 76	62 6	62 6	0 324	56 37	63 1	63 1	0 324	60 90	63 6	63 6	0 323	105	94
105	95	53 73	63 0	63 0	0 310	58 52	63 5	63 5	0 309	63 22	64 0	64 0	0 309	105	95
105	96	55 74	63 4	63 4	0 296	60 72	64 0	64 0	0 296	65 60	64 5	64 5	0 295	105	96
105	97	57 81	63 9	63 9	0 283	62 97	64 4	64 4	0 283	68 04	64 9	64 9	0 282	105	97
105	98	59 93	64 3	64 3	0 271	65 28	64 9	64 9	0 270	70 53	65 4	65 4	0 270	105	98
105	99	62 10	64 8	64 8	0 259	67 65	65 3	65 3	0 259	73 09	65 9	65 9	0 258	105	99
105	100	64 32	65 2	65 2	0 248	70 07	65 8	65 8	0 247	75 71	66 4	66 4	0 246	105	100
105	101	66 60	65 7	65 7	0 238	72 55	66 3	66 3	0 236	78 39	66 9	66 9	0 235	105	101
105	102	68 94	66 2	66 2	0 227	75 10	66 8	66 8	0 226	81 14	67 4	67 4	0 225	105	102

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 62
Leaving Water = 51.67

AIR TEMP. (F)		AIRFLOW								AIR TEMP. (F)					
EDB	EWB	450 CFM (FPM = 500)				485 CFM (FPM = 539)				520 CFM (FPM = 578)				EDB	EWB
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR		
75	59	10.22	54.2	50.6	1.000	10.96	54.3	50.7	1.000	11.70	54.4	50.7	1.000	75	59
75	60	10.23	54.2	51.8	1.000	10.97	54.3	51.8	1.000	11.71	54.4	51.9	1.000	75	60
75	61	10.59	53.9	52.7	0.982	10.98	54.4	53.0	1.000	11.72	54.5	53.1	1.000	75	61
75	62	11.13	54.6	53.4	0.907	11.87	54.6	53.5	0.913	12.61	54.7	53.6	0.918	75	62
75	63	11.87	55.1	54.0	0.831	12.65	55.2	54.1	0.836	13.41	55.3	54.2	0.841	75	63
75	64	12.81	55.4	54.5	0.757	13.63	55.5	54.6	0.762	14.44	55.7	54.7	0.767	75	64
75	65	13.92	55.6	54.8	0.689	14.80	55.8	55.0	0.693	15.66	55.9	55.1	0.697	75	65
75	66	15.19	55.8	55.1	0.628	16.14	55.9	55.2	0.632	17.07	56.1	55.4	0.635	75	66
75	67	16.50	55.9	55.3	0.576	17.54	56.1	55.5	0.578	18.56	56.2	55.7	0.580	75	67
75	68	17.84	56.0	55.5	0.530	18.97	56.2	55.7	0.531	20.08	56.4	55.9	0.533	75	68
75	69	19.21	56.1	55.8	0.489	20.43	56.3	56.0	0.490	21.63	56.5	56.2	0.492	75	69
75	70	20.61	56.3	56.0	0.454	21.93	56.5	56.2	0.454	23.22	56.7	56.4	0.455	75	70
75	71	22.04	56.4	56.3	0.422	23.46	56.6	56.5	0.422	24.85	56.8	56.7	0.422	75	71
75	72	23.50	56.6	56.6	0.393	25.02	56.8	56.8	0.393	26.51	57.0	57.0	0.393	75	72
80	61	12.39	54.8	51.1	1.000	13.29	55.0	51.1	1.000	14.19	55.1	51.2	1.000	80	61
80	62	12.40	54.9	52.3	1.000	13.30	55.0	52.3	1.000	14.20	55.1	52.4	1.000	80	62
80	63	12.89	54.6	53.1	0.972	13.79	54.7	53.2	0.977	14.69	54.7	53.3	0.981	80	63
80	64	13.52	55.2	53.8	0.906	14.43	55.3	53.9	0.911	15.34	55.4	54.0	0.916	80	64
80	65	14.34	55.7	54.4	0.838	15.29	55.8	54.5	0.843	16.22	55.9	54.7	0.848	80	65
80	66	15.33	56.1	54.9	0.773	16.33	56.2	55.0	0.778	17.31	56.3	55.2	0.783	80	66
80	67	16.49	56.3	55.2	0.713	17.54	56.5	55.4	0.717	18.58	56.6	55.6	0.721	80	67
80	68	17.78	56.5	55.5	0.657	18.91	56.7	55.7	0.661	20.01	56.8	55.9	0.664	80	68
80	69	19.15	56.6	55.8	0.608	20.37	56.8	56.0	0.611	21.57	57.0	56.2	0.613	80	69
80	70	20.55	56.7	56.0	0.564	21.86	56.9	56.2	0.566	23.15	57.1	56.4	0.568	80	70
80	71	21.98	56.9	56.3	0.525	23.39	57.1	56.5	0.527	24.78	57.3	56.7	0.528	80	71
80	72	23.44	57.0	56.5	0.490	24.95	57.2	56.8	0.491	26.44	57.5	57.0	0.492	80	72
80	73	24.93	57.1	56.8	0.459	26.55	57.4	57.0	0.459	28.13	57.6	57.3	0.460	80	73
80	74	26.46	57.3	57.1	0.430	28.18	57.5	57.3	0.430	29.87	57.8	57.6	0.431	80	74
80	75	28.02	57.4	57.4	0.404	29.85	57.7	57.6	0.404	31.64	58.0	57.9	0.404	80	75
80	76	29.62	57.7	57.7	0.379	31.56	57.9	57.9	0.379	33.46	58.2	58.2	0.379	80	76
80	77	31.25	58.0	58.0	0.355	33.30	58.2	58.2	0.355	35.31	58.5	58.5	0.354	80	77
85	63	14.55	55.5	51.7	1.000	15.62	55.6	51.7	1.000	16.68	55.7	51.8	1.000	85	63
85	64	14.56	55.5	52.9	1.000	15.63	55.6	53.0	1.000	16.69	55.7	53.0	1.000	85	64
85	65	15.25	55.3	53.6	0.960	16.32	55.4	53.7	0.965	17.37	55.5	53.8	0.969	85	65
85	66	15.97	55.9	54.3	0.900	17.06	56.0	54.4	0.905	18.13	56.1	54.5	0.909	85	66
85	67	16.87	56.4	54.9	0.839	18.00	56.5	55.0	0.844	19.11	56.6	55.1	0.849	85	67
85	68	17.94	56.8	55.3	0.781	19.11	56.9	55.5	0.785	20.27	57.0	55.6	0.790	85	68
85	69	19.15	57.0	55.7	0.726	20.39	57.2	55.9	0.730	21.60	57.4	56.1	0.734	85	69
85	70	20.49	57.2	56.0	0.675	21.80	57.4	56.2	0.679	23.09	57.6	56.4	0.682	85	70
85	71	21.92	57.3	56.3	0.629	23.33	57.5	56.5	0.632	24.71	57.7	56.7	0.635	85	71
85	72	23.38	57.5	56.5	0.587	24.89	57.7	56.7	0.590	26.37	57.9	57.0	0.592	85	72
85	73	24.87	57.6	56.8	0.550	26.48	57.8	57.0	0.552	28.06	58.1	57.2	0.554	85	73
85	74	26.40	57.8	57.1	0.516	28.11	58.0	57.3	0.518	29.79	58.2	57.5	0.519	85	74
85	75	27.96	57.9	57.4	0.485	29.78	58.2	57.6	0.487	31.57	58.4	57.8	0.488	85	75
85	76	29.55	58.1	57.6	0.457	31.49	58.3	57.9	0.458	33.38	58.6	58.1	0.459	85	76
85	77	31.19	58.2	57.9	0.432	33.23	58.5	58.2	0.432	35.24	58.8	58.5	0.432	85	77
85	78	32.86	58.4	58.2	0.408	35.02	58.7	58.5	0.408	37.14	58.9	58.8	0.408	85	78
85	79	34.57	58.6	58.6	0.386	36.84	58.8	58.8	0.386	39.08	59.1	59.1	0.386	85	79
85	80	36.32	58.9	58.9	0.363	38.71	59.2	59.2	0.363	41.06	59.5	59.5	0.363	85	80
85	81	38.11	59.2	59.2	0.342	40.63	59.5	59.5	0.342	43.10	59.8	59.8	0.342	85	81
85	82	39.95	59.5	59.5	0.323	42.59	59.9	59.9	0.323	45.18	60.2	60.2	0.322	85	82

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 62
Leaving Water = 51.67

AIR TEMP. (F)		AIRFLOW								AIR TEMP. (F)					
EDB	EWB	450 CFM (FPM = 500)				485 CFM (FPM = 539)				520 CFM (FPM = 578)				EDB	EWB
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR		
90	65	16.71	56.1	52.3	1.000	17.94	56.2	52.4	1.000	19.17	56.3	52.4	1.000	90	65
90	66	16.72	56.1	53.6	1.000	17.96	56.2	53.7	1.000	19.18	56.4	53.7	1.000	90	66
90	67	17.68	56.1	54.1	0.947	18.92	56.2	54.3	0.951	20.14	56.3	54.4	0.955	90	67
90	68	18.50	56.7	54.8	0.891	19.76	56.8	54.9	0.896	21.01	56.9	55.1	0.900	90	68
90	69	19.49	57.1	55.4	0.835	20.80	57.3	55.5	0.840	22.09	57.4	55.7	0.845	90	69
90	70	20.64	57.5	55.8	0.782	22.00	57.6	56.0	0.787	23.34	57.8	56.2	0.791	90	70
90	71	21.91	57.7	56.2	0.732	23.34	57.9	56.4	0.736	24.75	58.1	56.6	0.740	90	71
90	72	23.32	57.9	56.5	0.685	24.82	58.1	56.7	0.688	26.30	58.3	56.9	0.692	90	72
90	73	24.81	58.1	56.8	0.642	26.41	58.3	57.0	0.645	27.99	58.5	57.2	0.648	90	73
90	74	26.33	58.2	57.0	0.603	28.04	58.4	57.3	0.605	29.72	58.7	57.5	0.608	90	74
90	75	27.89	58.4	57.3	0.567	29.71	58.6	57.6	0.569	31.50	58.8	57.8	0.571	90	75
90	76	29.49	58.5	57.6	0.535	31.42	58.8	57.9	0.536	33.31	59.0	58.1	0.538	90	76
90	77	31.12	58.7	57.9	0.505	33.16	58.9	58.2	0.506	35.16	59.2	58.4	0.507	90	77
90	78	32.79	58.8	58.2	0.477	34.95	59.1	58.5	0.478	37.06	59.4	58.8	0.479	90	78
90	79	34.50	59.0	58.5	0.452	36.77	59.3	58.8	0.453	39.00	59.6	59.1	0.453	90	79
90	80	36.25	59.2	58.8	0.428	38.64	59.5	59.1	0.429	40.99	59.8	59.4	0.429	90	80
90	81	38.04	59.4	59.2	0.407	40.55	59.7	59.5	0.407	43.02	60.0	59.8	0.407	90	81
90	82	39.87	59.5	59.5	0.386	42.51	59.9	59.8	0.386	45.10	60.2	60.1	0.386	90	82
90	83	41.75	59.8	59.8	0.366	44.51	60.2	60.2	0.366	47.23	60.5	60.5	0.366	90	83
90	84	43.67	60.2	60.2	0.346	46.57	60.5	60.5	0.346	49.41	60.9	60.9	0.346	90	84
90	85	45.64	60.6	60.6	0.328	48.66	60.9	60.9	0.328	51.64	61.2	61.2	0.328	90	85
90	86	47.65	60.9	60.9	0.311	50.81	61.3	61.3	0.311	53.92	61.6	61.6	0.310	90	86
90	87	49.71	61.3	61.3	0.295	53.01	61.7	61.7	0.294	56.26	62.0	62.0	0.294	90	87
95	67	18.87	56.7	53.1	1.000	20.27	56.9	53.2	1.000	21.66	57.0	53.2	1.000	95	67
95	68	19.47	56.3	54.0	0.982	20.86	56.3	54.1	0.986	21.68	57.0	54.5	1.000	95	68
95	69	20.20	56.9	54.7	0.932	21.61	57.0	54.8	0.936	23.00	57.1	55.0	0.940	95	69
95	70	21.13	57.5	55.4	0.880	22.57	57.6	55.5	0.884	23.99	57.7	55.6	0.889	95	70
95	71	22.21	57.9	55.9	0.829	23.71	58.0	56.0	0.833	25.18	58.2	56.2	0.838	95	71
95	72	23.44	58.2	56.3	0.779	25.00	58.4	56.5	0.784	26.53	58.6	56.7	0.788	95	72
95	73	24.79	58.5	56.7	0.733	26.42	58.7	56.9	0.737	28.02	58.9	57.1	0.741	95	73
95	74	26.27	58.7	57.0	0.689	27.98	58.9	57.3	0.693	29.65	59.1	57.5	0.696	95	74
95	75	27.83	58.8	57.3	0.649	29.64	59.1	57.5	0.652	31.42	59.3	57.8	0.655	95	75
95	76	29.42	59.0	57.6	0.612	31.35	59.2	57.8	0.614	33.23	59.5	58.1	0.617	95	76
95	77	31.06	59.1	57.9	0.578	33.09	59.4	58.1	0.580	35.09	59.7	58.4	0.582	95	77
95	78	32.73	59.3	58.2	0.547	34.87	59.6	58.5	0.549	36.98	59.8	58.7	0.551	95	78
95	79	34.43	59.5	58.5	0.518	36.70	59.8	58.8	0.520	38.92	60.0	59.0	0.521	95	79
95	80	36.18	59.6	58.8	0.492	38.57	59.9	59.1	0.493	40.91	60.2	59.4	0.494	95	80
95	81	37.97	59.8	59.1	0.467	40.48	60.1	59.4	0.468	42.94	60.4	59.7	0.469	95	81
95	82	39.80	60.0	59.5	0.444	42.43	60.3	59.8	0.444	45.02	60.6	60.1	0.445	95	82
95	83	41.68	60.2	59.8	0.422	44.44	60.5	60.1	0.423	47.15	60.9	60.4	0.423	95	83
95	84	43.60	60.4	60.2	0.402	46.49	60.7	60.5	0.402	49.33	61.1	60.8	0.403	95	84
95	85	45.56	60.6	60.5	0.384	48.59	60.9	60.9	0.383	51.56	61.3	61.2	0.383	95	85
95	86	47.57	60.9	60.9	0.365	50.73	61.2	61.2	0.365	53.84	61.6	61.6	0.365	95	86
95	87	49.63	61.3	61.3	0.346	52.93	61.6	61.6	0.346	56.18	62.0	62.0	0.346	95	87
95	88	51.74	61.6	61.6	0.329	55.19	62.0	62.0	0.329	58.57	62.4	62.4	0.329	95	88
95	89	53.90	62.0	62.0	0.313	57.49	62.4	62.4	0.313	61.02	62.8	62.8	0.312	95	89
95	90	56.11	62.4	62.4	0.298	59.85	62.8	62.8	0.297	63.53	63.2	63.2	0.297	95	90
95	91	58.38	62.8	62.8	0.283	62.27	63.3	63.3	0.282	66.10	63.6	63.6	0.282	95	91
95	92	60.70	63.3	63.3	0.269	64.75	63.7	63.7	0.269	68.73	64.1	64.1	0.268	95	92

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART Coil Size: DW 62
Entering Water = 45 Leaving Water = 51.67

AIR TEMP. (F)		AIRFLOW 555 CFM (FPM = 617)			AIR TEMP. (F)		
EDB	EWB	MBH	LDB	LWB	SHR	EDB	EWB
75	59	12.43	54.5	50.7	1.000	75	59
75	60	12.44	54.5	51.9	1.000	75	60
75	61	12.44	54.6	53.1	1.000	75	61
75	62	13.34	54.8	53.7	0.923	75	62
75	63	14.17	55.4	54.3	0.846	75	63
75	64	15.23	55.8	54.9	0.771	75	64
75	65	16.50	56.1	55.3	0.701	75	65
75	66	17.98	56.3	55.6	0.638	75	66
75	67	19.55	56.4	55.8	0.583	75	67
75	68	21.16	56.6	56.1	0.535	75	68
75	69	22.81	56.7	56.4	0.493	75	69
75	70	24.49	56.9	56.6	0.456	75	70
75	71	26.21	57.0	56.9	0.422	75	71
75	72	27.97	57.2	57.2	0.393	75	72
80	61	15.08	55.2	51.2	1.000	80	61
80	62	15.09	55.2	52.4	1.000	80	62
80	63	15.57	54.8	53.3	0.986	80	63
80	64	16.23	55.5	54.1	0.920	80	64
80	65	17.14	56.0	54.8	0.853	80	65
80	66	18.27	56.5	55.3	0.787	80	66
80	67	19.59	56.8	55.7	0.725	80	67
80	68	21.10	57.0	56.1	0.668	80	68
80	69	22.74	57.2	56.3	0.616	80	69
80	70	24.42	57.3	56.6	0.571	80	70
80	71	26.14	57.5	56.9	0.530	80	71
80	72	27.89	57.7	57.2	0.494	80	72
80	73	29.69	57.8	57.5	0.461	80	73
80	74	31.52	58.0	57.8	0.431	80	74
80	75	33.40	58.2	58.1	0.404	80	75
80	76	35.32	58.4	58.4	0.379	80	76
80	77	37.29	58.7	58.7	0.354	80	77
85	63	17.73	55.8	51.8	1.000	85	63
85	64	17.75	55.8	53.1	1.000	85	64
85	65	18.41	55.6	53.9	0.973	85	65
85	66	19.19	56.2	54.6	0.914	85	66
85	67	20.20	56.8	55.3	0.853	85	67
85	68	21.41	57.2	55.8	0.794	85	68
85	69	22.80	57.5	56.2	0.738	85	69
85	70	24.35	57.8	56.6	0.686	85	70
85	71	26.06	57.9	56.9	0.638	85	71
85	72	27.82	58.1	57.2	0.595	85	72
85	73	29.61	58.3	57.5	0.556	85	73
85	74	31.45	58.5	57.8	0.521	85	74
85	75	33.32	58.6	58.1	0.489	85	75
85	76	35.24	58.8	58.4	0.460	85	76
85	77	37.21	59.0	58.7	0.433	85	77
85	78	39.22	59.2	59.0	0.408	85	78
85	79	41.27	59.4	59.4	0.385	85	79
85	80	43.37	59.7	59.7	0.363	85	80
85	81	45.53	60.1	60.1	0.342	85	81
85	82	47.73	60.4	60.4	0.322	85	82

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART Coil Size: DW 62
 Entering Water = 45 Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	AIRFLOW 555 CFM (FPM = 617)			AIR TEMP. (F)	
			MBH	LDB	LWB	SHR	EDB
90	65	20.39	56.5	52.5	1.000	90	65
90	66	20.40	56.5	53.8	1.000	90	66
90	67	21.35	56.4	54.5	0.960	90	67
90	68	22.25	57.0	55.2	0.905	90	68
90	69	23.36	57.5	55.8	0.849	90	69
90	70	24.66	57.9	56.3	0.795	90	70
90	71	26.13	58.3	56.8	0.744	90	71
90	72	27.75	58.5	57.1	0.696	90	72
90	73	29.54	58.7	57.4	0.651	90	73
90	74	31.37	58.9	57.7	0.610	90	74
90	75	33.25	59.1	58.0	0.573	90	75
90	76	35.16	59.3	58.4	0.540	90	76
90	77	37.13	59.5	58.7	0.509	90	77
90	78	39.13	59.7	59.0	0.480	90	78
90	79	41.19	59.9	59.3	0.454	90	79
90	80	43.29	60.1	59.7	0.430	90	80
90	81	45.44	60.3	60.0	0.407	90	81
90	82	47.64	60.5	60.4	0.386	90	82
90	83	49.90	60.8	60.8	0.366	90	83
90	84	52.20	61.2	61.2	0.346	90	84
90	85	54.56	61.5	61.5	0.327	90	85
90	86	56.98	61.9	61.9	0.310	90	86
90	87	59.45	62.3	62.3	0.293	90	87
95	67	23.04	57.1	53.3	1.000	95	67
95	68	23.06	57.1	54.6	1.000	95	68
95	69	24.38	57.2	55.1	0.945	95	69
95	70	25.40	57.8	55.8	0.893	95	70
95	71	26.63	58.3	56.4	0.842	95	71
95	72	28.04	58.7	56.9	0.792	95	72
95	73	29.60	59.1	57.3	0.745	95	73
95	74	31.30	59.3	57.7	0.700	95	74
95	75	33.17	59.5	58.0	0.658	95	75
95	76	35.09	59.7	58.3	0.620	95	76
95	77	37.05	59.9	58.6	0.585	95	77
95	78	39.05	60.1	59.0	0.552	95	78
95	79	41.11	60.3	59.3	0.523	95	79
95	80	43.21	60.5	59.7	0.495	95	80
95	81	45.36	60.7	60.0	0.470	95	81
95	82	47.56	60.9	60.4	0.446	95	82
95	83	49.81	61.2	60.7	0.424	95	83
95	84	52.12	61.4	61.1	0.403	95	84
95	85	54.47	61.6	61.5	0.383	95	85
95	86	56.89	61.9	61.9	0.365	95	86
95	87	59.36	62.3	62.3	0.346	95	87
95	88	61.89	62.7	62.7	0.329	95	88
95	89	64.49	63.1	63.1	0.312	95	89
95	90	67.14	63.6	63.6	0.296	95	90
95	91	69.86	64.0	64.0	0.281	95	91
95	92	72.64	64.5	64.5	0.267	95	92

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART Coil Size: DW 62
Entering Water = 45 Leaving Water = 51.67

AIR TEMP (°F)		AIRFLOW 555 CFM (FPM = 617)			AIR TEMP (°F)		
EDB	EWB	MBH	LDB	LWB	SHR	EDB	EWB
100	69	25 69	57 8	54 1	1 000	100	69
100	70	26 59	57 4	54 9	0 976	100	70
100	71	27 52	58 1	55 7	0 929	100	71
100	72	28 68	58 7	56 4	0 880	100	72
100	73	30 03	59 2	57 0	0 832	100	73
100	74	31 54	59 5	57 5	0 786	100	74
100	75	33 21	59 9	57 9	0 742	100	75
100	76	35 01	60 1	58 3	0 700	100	76
100	77	36 97	60 3	58 6	0 661	100	77
100	78	38 97	60 5	58 9	0 625	100	78
100	79	41 03	60 7	59 3	0 591	100	79
100	80	43 12	60 9	59 6	0 560	100	80
100	81	45 27	61 2	60 0	0 532	100	81
100	82	47 47	61 4	60 3	0 505	100	82
100	83	49 72	61 6	60 7	0 480	100	83
100	84	52 03	61 8	61 1	0 457	100	84
100	85	54 39	62 1	61 5	0 436	100	85
100	86	56 80	62 3	61 9	0 415	100	86
100	87	59 27	62 6	62 3	0 396	100	87
100	88	61 80	62 8	62 7	0 378	100	88
100	89	64 39	63 1	63 1	0 361	100	89
100	90	67 05	63 5	63 5	0 343	100	90
100	91	69 76	64 0	64 0	0 327	100	91
100	92	72 55	64 4	64 4	0 311	100	92
100	93	75 40	64 9	64 9	0 296	100	93
100	94	78 31	65 4	65 4	0 282	100	94
100	95	81 30	65 8	65 8	0 268	100	95
100	96	84 36	66 3	66 3	0 256	100	96
100	97	87 50	66 8	66 8	0 243	100	97
105	71	28 35	58 4	55 1	1 000	105	71
105	72	29 71	58 4	55 7	0 957	105	72
105	73	30 81	59 0	56 4	0 911	105	73
105	74	32 10	59 6	57 0	0 866	105	74
105	75	33 58	60 0	57 6	0 821	105	75
105	76	35 20	60 4	58 1	0 778	105	76
105	77	36 97	60 7	58 5	0 736	105	77
105	78	38 89	61 0	58 9	0 697	105	78
105	79	40 94	61 2	59 2	0 660	105	79
105	80	43 04	61 4	59 6	0 626	105	80
105	81	45 19	61 6	59 9	0 594	105	81
105	82	47 39	61 8	60 3	0 565	105	82
105	83	49 64	62 1	60 7	0 537	105	83
105	84	51 94	62 3	61 0	0 512	105	84
105	85	54 30	62 5	61 4	0 488	105	85
105	86	56 71	62 8	61 8	0 465	105	86
105	87	59 18	63 0	62 2	0 444	105	87
105	88	61 71	63 3	62 6	0 424	105	88
105	89	64 30	63 5	63 1	0 405	105	89
105	90	66 96	63 8	63 5	0 387	105	90
105	91	69 67	64 1	63 9	0 371	105	91
105	92	72 45	64 4	64 4	0 355	105	92
105	93	75 30	64 8	64 8	0 338	105	93
105	94	78 22	65 3	65 3	0 323	105	94
105	95	81 20	65 8	65 8	0 308	105	95
105	96	84 26	66 3	66 3	0 294	105	96
105	97	87 40	66 8	66 8	0 280	105	97
105	98	90 61	67 3	67 3	0 267	105	98
105	99	93 89	67 8	67 8	0 255	105	99
105	100	97 26	68 4	68 4	0 243	105	100
105	101	100 7	68 9	68 9	0 232	105	101
105	102	104 2	69 5	69 5	0 221	105	102

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 63
Leaving Water = 51.67

AIR TEMP. (F)		390 CFM (FPM = 289)				430 CFM (FPM = 319)				470 CFM (FPM = 348)				AIR TEMP (F)	
EDB	EWB	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
75	59	9.61	52.5	49.8	1.000	10.57	52.5	49.9	1.000	11.51	52.6	49.9	1.000	75	59
75	60	9.97	52.1	50.7	0.982	10.92	52.1	50.7	0.986	11.52	52.6	51.1	1.000	75	60
75	61	10.56	52.6	51.3	0.907	11.54	52.7	51.4	0.912	12.52	52.7	51.5	0.916	75	61
75	62	11.35	52.9	51.8	0.832	12.39	53.0	51.9	0.837	13.41	53.1	52.0	0.841	75	62
75	63	12.31	53.1	52.1	0.762	13.42	53.3	52.2	0.766	14.51	53.4	52.3	0.770	75	63
75	64	13.41	53.2	52.3	0.698	14.61	53.4	52.4	0.701	15.78	53.5	52.6	0.705	75	64
75	65	14.58	53.2	52.4	0.642	15.89	53.4	52.6	0.644	17.17	53.6	52.8	0.647	75	65
75	66	15.77	53.3	52.6	0.593	17.19	53.4	52.8	0.595	18.58	53.6	52.9	0.597	75	66
75	67	16.99	53.3	52.8	0.550	18.52	53.5	52.9	0.552	20.03	53.7	53.1	0.553	75	67
75	68	18.23	53.3	52.9	0.512	19.88	53.5	53.1	0.513	21.50	53.7	53.3	0.514	75	68
75	69	19.50	53.4	53.1	0.479	21.27	53.6	53.3	0.479	23.01	53.8	53.5	0.480	75	69
75	70	20.79	53.4	53.3	0.449	22.69	53.7	53.5	0.449	24.55	53.9	53.7	0.449	75	70
75	71	22.11	53.5	53.5	0.421	24.13	53.7	53.7	0.421	26.12	53.9	53.9	0.421	75	71
75	72	23.46	53.7	53.7	0.394	25.61	53.9	53.9	0.394	27.72	54.1	54.1	0.393	75	72
80	61	11.51	53.0	50.3	1.000	12.66	53.1	50.3	1.000	13.80	53.2	50.4	1.000	80	61
80	62	12.01	52.7	51.0	0.971	13.16	52.7	51.1	0.975	14.31	52.8	51.2	0.979	80	62
80	63	12.69	53.2	51.6	0.904	13.88	53.3	51.7	0.909	15.06	53.3	51.8	0.913	80	63
80	64	13.56	53.5	52.1	0.838	14.81	53.6	52.2	0.842	16.04	53.7	52.3	0.846	80	64
80	65	14.58	53.7	52.4	0.775	15.90	53.8	52.5	0.779	17.21	53.9	52.7	0.783	80	65
80	66	15.72	53.7	52.6	0.717	17.14	53.9	52.7	0.721	18.53	54.1	52.9	0.724	80	66
80	67	16.94	53.8	52.7	0.665	18.47	54.0	52.9	0.668	19.97	54.1	53.1	0.671	80	67
80	68	18.18	53.8	52.9	0.620	19.83	54.0	53.1	0.622	21.44	54.2	53.3	0.624	80	68
80	69	19.45	53.9	53.1	0.579	21.21	54.1	53.3	0.581	22.95	54.3	53.5	0.583	80	69
80	70	20.74	53.9	53.3	0.543	22.63	54.1	53.5	0.544	24.48	54.3	53.7	0.545	80	70
80	71	22.06	54.0	53.5	0.510	24.07	54.2	53.7	0.511	26.05	54.4	53.9	0.512	80	71
80	72	23.41	54.0	53.7	0.480	25.55	54.3	53.9	0.481	27.66	54.5	54.1	0.481	80	72
80	73	24.79	54.1	53.9	0.453	27.06	54.3	54.1	0.454	29.30	54.6	54.3	0.454	80	73
80	74	26.20	54.1	54.1	0.429	28.60	54.4	54.3	0.428	30.97	54.6	54.6	0.428	80	74
80	75	27.64	54.3	54.3	0.404	30.18	54.6	54.6	0.404	32.69	54.8	54.8	0.404	80	75
80	76	29.12	54.6	54.6	0.381	31.80	54.8	54.8	0.381	34.44	55.1	55.1	0.380	80	76
80	77	30.62	54.8	54.8	0.359	33.45	55.0	55.0	0.359	36.23	55.3	55.3	0.358	80	77
85	63	13.40	53.6	50.9	1.000	14.74	53.7	50.9	1.000	16.08	53.7	50.9	1.000	85	63
85	64	14.11	53.3	51.4	0.959	15.47	53.4	51.5	0.963	16.81	53.5	51.6	0.966	85	64
85	65	14.89	53.8	52.0	0.897	16.29	53.9	52.1	0.902	17.67	54.0	52.2	0.906	85	65
85	66	15.84	54.1	52.4	0.837	17.30	54.2	52.5	0.841	18.75	54.3	52.7	0.845	85	66
85	67	16.93	54.2	52.7	0.780	18.47	54.4	52.8	0.784	20.00	54.5	53.0	0.788	85	67
85	68	18.13	54.3	52.9	0.727	19.77	54.5	53.1	0.731	21.39	54.7	53.3	0.735	85	68
85	69	19.39	54.4	53.1	0.680	21.15	54.5	53.3	0.683	22.88	54.7	53.5	0.686	85	69
85	70	20.68	54.4	53.3	0.637	22.57	54.6	53.5	0.640	24.42	54.8	53.7	0.642	85	70
85	71	22.00	54.5	53.5	0.599	24.01	54.7	53.7	0.601	25.99	54.9	53.9	0.603	85	71
85	72	23.35	54.5	53.7	0.564	25.49	54.7	53.9	0.566	27.59	55.0	54.1	0.567	85	72
85	73	24.73	54.6	53.9	0.532	27.00	54.8	54.1	0.533	29.23	55.0	54.3	0.535	85	73
85	74	26.14	54.6	54.1	0.503	28.54	54.9	54.3	0.504	30.90	55.1	54.5	0.505	85	74
85	75	27.58	54.7	54.3	0.477	30.12	55.0	54.5	0.477	32.62	55.2	54.8	0.478	85	75
85	76	29.06	54.8	54.5	0.452	31.73	55.0	54.8	0.453	34.37	55.3	55.0	0.453	85	76
85	77	30.56	54.8	54.8	0.430	33.38	55.1	55.0	0.430	36.16	55.4	55.3	0.430	85	77
85	78	32.11	55.0	55.0	0.408	35.07	55.3	55.3	0.408	37.99	55.5	55.5	0.408	85	78
85	79	33.68	55.2	55.2	0.386	36.80	55.5	55.5	0.386	39.87	55.8	55.8	0.386	85	79
85	80	35.30	55.5	55.5	0.366	38.57	55.8	55.8	0.366	41.79	56.1	56.1	0.365	85	80
85	81	36.95	55.8	55.8	0.347	40.38	56.1	56.1	0.347	43.75	56.3	56.3	0.346	85	81
85	82	38.64	56.0	56.0	0.329	42.23	56.3	56.3	0.329	45.76	56.6	56.6	0.328	85	82

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 63
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	390 CFM (FPM = 289)				430 CFM (FPM = 319)				470 CFM (FPM = 348)				AIR TEMP (F)	
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
90	65	15.29	54.2	51.5	1.000	16.83	54.3	51.6	1.000	18.36	54.3	51.6	1.000	90	65	
90	66	16.29	54.0	51.9	0.944	17.85	54.1	52.0	0.948	19.39	54.2	52.1	0.952	90	66	
90	67	17.17	54.4	52.4	0.888	18.78	54.5	52.5	0.892	20.38	54.6	52.6	0.896	90	67	
90	68	18.21	54.7	52.7	0.832	19.89	54.8	52.9	0.837	21.56	54.9	53.1	0.841	90	68	
90	69	19.37	54.8	53.0	0.780	21.14	55.0	53.2	0.784	22.90	55.1	53.4	0.788	90	69	
90	70	20.63	54.9	53.2	0.732	22.51	55.1	53.4	0.735	24.36	55.3	53.6	0.739	90	70	
90	71	21.95	54.9	53.4	0.688	23.95	55.1	53.6	0.691	25.92	55.3	53.9	0.694	90	71	
90	72	23.30	55.0	53.6	0.648	25.43	55.2	53.9	0.650	27.52	55.4	54.1	0.653	90	72	
90	73	24.67	55.1	53.8	0.612	26.94	55.3	54.1	0.614	29.16	55.5	54.3	0.616	90	73	
90	74	26.08	55.1	54.0	0.578	28.48	55.4	54.3	0.580	30.84	55.6	54.5	0.582	90	74	
90	75	27.52	55.2	54.3	0.548	30.05	55.4	54.5	0.549	32.55	55.7	54.8	0.550	90	75	
90	76	29.00	55.3	54.5	0.520	31.67	55.5	54.7	0.521	34.30	55.8	55.0	0.522	90	76	
90	77	30.50	55.3	54.7	0.494	33.32	55.6	55.0	0.495	36.09	55.9	55.2	0.495	90	77	
90	78	32.04	55.4	55.0	0.470	35.00	55.7	55.2	0.470	37.92	56.0	55.5	0.471	90	78	
90	79	33.62	55.5	55.2	0.448	36.73	55.8	55.5	0.448	39.79	56.1	55.8	0.448	90	79	
90	80	35.24	55.6	55.5	0.427	38.50	55.9	55.8	0.427	41.71	56.2	56.0	0.427	90	80	
90	81	36.89	55.7	55.7	0.407	40.31	56.0	56.0	0.407	43.68	56.3	56.3	0.407	90	81	
90	82	38.58	56.0	56.0	0.387	42.16	56.3	56.3	0.386	45.68	56.6	56.6	0.386	90	82	
90	83	40.31	56.3	56.3	0.368	44.05	56.6	56.6	0.367	47.74	56.9	56.9	0.367	90	83	
90	84	42.08	56.5	56.5	0.350	45.99	56.9	56.9	0.349	49.85	57.2	57.2	0.349	90	84	
90	85	43.90	56.8	56.8	0.333	47.98	57.2	57.2	0.333	52.00	57.5	57.5	0.332	90	85	
90	86	45.76	57.1	57.1	0.317	50.01	57.5	57.5	0.317	54.21	57.8	57.8	0.316	90	86	
90	87	47.66	57.4	57.4	0.303	52.10	57.8	57.8	0.302	56.47	58.1	58.1	0.301	90	87	
95	67	17.76	54.2	51.7	0.981	19.48	54.3	51.8	0.985	20.63	54.9	52.4	1.000	95	67	
95	68	18.56	54.7	52.3	0.929	20.33	54.8	52.5	0.933	22.08	54.9	52.6	0.936	95	68	
95	69	19.54	55.0	52.8	0.876	21.38	55.2	52.9	0.880	23.20	55.3	53.1	0.884	95	69	
95	70	20.67	55.3	53.1	0.825	22.59	55.4	53.3	0.829	24.48	55.6	53.5	0.833	95	70	
95	71	21.91	55.4	53.4	0.777	23.92	55.6	53.6	0.780	25.91	55.8	53.8	0.784	95	71	
95	72	23.24	55.5	53.6	0.732	25.37	55.7	53.8	0.735	27.46	55.9	54.0	0.739	95	72	
95	73	24.62	55.5	53.8	0.691	26.87	55.8	54.0	0.694	29.09	56.0	54.3	0.697	95	73	
95	74	26.03	55.6	54.0	0.653	28.42	55.8	54.3	0.656	30.77	56.1	54.5	0.658	95	74	
95	75	27.46	55.7	54.2	0.619	29.99	55.9	54.5	0.621	32.48	56.1	54.7	0.623	95	75	
95	76	28.94	55.7	54.5	0.587	31.60	56.0	54.7	0.589	34.23	56.2	55.0	0.591	95	76	
95	77	30.44	55.8	54.7	0.558	33.25	56.1	55.0	0.560	36.02	56.3	55.2	0.561	95	77	
95	78	31.98	55.9	54.9	0.531	34.94	56.2	55.2	0.532	37.85	56.4	55.5	0.533	95	78	
95	79	33.56	56.0	55.2	0.506	36.66	56.3	55.5	0.507	39.72	56.5	55.7	0.508	95	79	
95	80	35.17	56.0	55.4	0.483	38.43	56.3	55.7	0.483	41.64	56.6	56.0	0.484	95	80	
95	81	36.82	56.1	55.7	0.461	40.24	56.4	56.0	0.461	43.60	56.8	56.3	0.462	95	81	
95	82	38.51	56.2	55.9	0.441	42.09	56.5	56.3	0.441	45.61	56.9	56.6	0.441	95	82	
95	83	40.24	56.3	56.2	0.421	43.98	56.6	56.5	0.421	47.66	57.0	56.8	0.421	95	83	
95	84	42.02	56.5	56.5	0.402	45.92	56.8	56.8	0.402	49.77	57.1	57.1	0.403	95	84	
95	85	43.83	56.8	56.8	0.384	47.91	57.1	57.1	0.383	51.92	57.4	57.4	0.383	95	85	
95	86	45.69	57.1	57.1	0.366	49.94	57.4	57.4	0.366	54.13	57.8	57.8	0.365	95	86	
95	87	47.59	57.4	57.4	0.349	52.02	57.7	57.7	0.349	56.39	58.1	58.1	0.348	95	87	
95	88	49.54	57.7	57.7	0.333	54.15	58.1	58.1	0.333	58.70	58.4	58.4	0.332	95	88	
95	89	51.53	58.0	58.0	0.318	56.34	58.4	58.4	0.318	61.07	58.8	58.8	0.317	95	89	
95	90	53.58	58.3	58.3	0.304	58.58	58.7	58.7	0.303	63.50	59.1	59.1	0.303	95	90	
95	91	55.67	58.7	58.7	0.291	60.87	59.1	59.1	0.290	65.99	59.5	59.5	0.289	95	91	
95	92	57.82	59.0	59.0	0.278	63.22	59.4	59.4	0.277	68.54	59.8	59.8	0.276	95	92	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 63
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	510 CFM (FPM = 378)				550 CFM (FPM = 407)				590 CFM (FPM = 437)				AIR TEMP (F)	
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
75	59	12.46	52.7	49.9	1.000	13.39	52.7	50.0	1.000	14.33	52.8	50.0	1.000	75	59	
75	60	12.47	52.7	51.1	1.000	13.40	52.7	51.2	1.000	14.34	52.8	51.2	1.000	75	60	
75	61	13.49	52.8	51.6	0.920	14.44	52.9	51.6	0.924	15.39	52.9	51.7	0.928	75	61	
75	62	14.42	53.2	52.1	0.845	15.42	53.3	52.2	0.849	16.41	53.4	52.3	0.853	75	62	
75	63	15.59	53.5	52.5	0.774	16.64	53.6	52.6	0.778	17.69	53.7	52.7	0.781	75	63	
75	64	16.94	53.6	52.7	0.708	18.07	53.8	52.8	0.711	19.19	53.9	53.0	0.715	75	64	
75	65	18.42	53.7	52.9	0.650	19.66	53.8	53.0	0.652	20.87	54.0	53.2	0.655	75	65	
75	66	19.95	53.8	53.1	0.599	21.29	53.9	53.2	0.601	22.62	54.1	53.4	0.603	75	66	
75	67	21.51	53.8	53.3	0.555	22.96	54.0	53.4	0.556	24.39	54.1	53.6	0.557	75	67	
75	68	23.10	53.9	53.5	0.515	24.67	54.1	53.6	0.516	26.21	54.2	53.8	0.517	75	68	
75	69	24.72	54.0	53.7	0.481	26.40	54.2	53.9	0.481	28.06	54.3	54.0	0.482	75	69	
75	70	26.38	54.1	53.9	0.449	28.18	54.2	54.1	0.450	29.95	54.4	54.2	0.450	75	70	
75	71	28.07	54.1	54.1	0.421	29.99	54.3	54.3	0.421	31.89	54.5	54.5	0.421	75	71	
75	72	29.80	54.3	54.3	0.393	31.85	54.5	54.5	0.393	33.86	54.7	54.7	0.393	75	72	
80	61	14.93	53.2	50.4	1.000	16.06	53.3	50.4	1.000	17.19	53.4	50.5	1.000	80	61	
80	62	15.44	52.8	51.3	0.983	16.57	52.9	51.3	0.986	17.20	53.4	51.7	1.000	80	62	
80	63	16.23	53.4	51.9	0.917	17.38	53.5	52.0	0.921	18.53	53.5	52.1	0.924	80	63	
80	64	17.26	53.8	52.4	0.850	18.46	53.9	52.5	0.854	19.65	54.0	52.6	0.858	80	64	
80	65	18.50	54.1	52.8	0.787	19.77	54.2	52.9	0.790	21.02	54.3	53.0	0.794	80	65	
80	66	19.90	54.2	53.1	0.728	21.25	54.4	53.2	0.731	22.58	54.5	53.3	0.734	80	66	
80	67	21.44	54.3	53.3	0.674	22.89	54.4	53.4	0.677	24.32	54.6	53.6	0.680	80	67	
80	68	23.03	54.4	53.5	0.627	24.59	54.5	53.6	0.629	26.13	54.7	53.8	0.631	80	68	
80	69	24.65	54.4	53.7	0.584	26.33	54.6	53.8	0.586	27.99	54.8	54.0	0.588	80	69	
80	70	26.31	54.5	53.9	0.547	28.11	54.7	54.1	0.548	29.88	54.9	54.2	0.549	80	70	
80	71	28.00	54.6	54.1	0.513	29.92	54.8	54.3	0.514	31.81	55.0	54.5	0.515	80	71	
80	72	29.73	54.7	54.3	0.482	31.77	54.9	54.5	0.483	33.78	55.1	54.7	0.483	80	72	
80	73	31.50	54.8	54.6	0.454	33.66	55.0	54.8	0.454	35.80	55.2	54.9	0.455	80	73	
80	74	33.30	54.9	54.8	0.428	35.60	55.1	55.0	0.429	37.86	55.3	55.2	0.429	80	74	
80	75	35.15	55.0	55.0	0.404	37.58	55.2	55.2	0.404	39.97	55.5	55.5	0.404	80	75	
80	76	37.04	55.3	55.3	0.380	39.60	55.5	55.5	0.380	42.13	55.7	55.7	0.380	80	76	
80	77	38.97	55.5	55.5	0.358	41.67	55.8	55.8	0.358	44.33	56.0	56.0	0.357	80	77	
85	63	17.40	53.8	51.0	1.000	18.73	53.9	51.0	1.000	20.04	54.0	51.0	1.000	85	63	
85	64	18.14	53.5	51.7	0.970	19.46	53.6	51.8	0.973	20.77	53.6	51.8	0.976	85	64	
85	65	19.05	54.0	52.3	0.910	20.40	54.1	52.4	0.913	21.75	54.2	52.5	0.917	85	65	
85	66	20.18	54.4	52.8	0.849	21.60	54.5	52.9	0.853	22.99	54.6	53.0	0.857	85	66	
85	67	21.50	54.7	53.1	0.792	22.99	54.8	53.3	0.795	24.46	54.9	53.4	0.799	85	67	
85	68	22.98	54.8	54.8	0.738	24.55	55.0	53.6	0.741	26.10	55.1	53.7	0.744	85	68	
85	69	24.59	54.9	53.6	0.689	26.26	55.1	53.8	0.692	27.91	55.2	54.0	0.694	85	69	
85	70	26.24	55.0	53.9	0.644	28.03	55.2	54.0	0.647	29.80	55.3	54.2	0.649	85	70	
85	71	27.93	55.1	54.1	0.605	29.84	55.3	54.3	0.606	31.73	55.4	54.4	0.608	85	71	
85	72	29.66	55.2	54.3	0.569	31.69	55.4	54.5	0.570	33.70	55.5	54.7	0.571	85	72	
85	73	31.42	55.2	54.5	0.536	33.59	55.5	54.7	0.537	35.72	55.6	54.9	0.538	85	73	
85	74	33.23	55.3	54.8	0.506	35.52	55.6	55.0	0.507	37.78	55.8	55.2	0.507	85	74	
85	75	35.08	55.4	55.0	0.478	37.50	55.7	55.2	0.479	39.89	55.9	55.4	0.479	85	75	
85	76	36.96	55.5	55.3	0.453	39.52	55.8	55.5	0.453	42.04	56.0	55.7	0.454	85	76	
85	77	38.89	55.6	55.5	0.430	41.59	55.9	55.7	0.430	44.25	56.1	56.0	0.430	85	77	
85	78	40.87	55.8	55.8	0.408	43.71	56.0	56.0	0.408	46.50	56.3	56.2	0.408	85	78	
85	79	42.89	56.0	56.0	0.386	45.87	56.3	56.3	0.386	48.81	56.5	56.5	0.386	85	79	
85	80	44.96	56.3	56.3	0.365	48.09	56.6	56.6	0.365	51.17	56.8	56.8	0.365	85	80	
85	81	47.08	56.6	56.6	0.346	50.35	56.9	56.9	0.345	53.59	57.1	57.1	0.345	85	81	
85	82	49.24	56.9	56.9	0.328	52.67	57.2	57.2	0.327	56.06	57.4	57.4	0.327	85	82	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 63
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	AIRFLOW								AIR TEMP.					
			510 CFM (FPM = 378)				550 CFM (FPM = 407)				590 CFM (FPM = 437)				(F)	
MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR				EDB	EWB
90	65	19.87	54.4	51.6	1.000	21.39	54.5	51.7	1.000	22.89	54.6	51.7	1.000	90	65	
90	66	20.92	54.2	52.2	0.956	22.45	54.3	52.2	0.959	23.95	54.4	52.3	0.962	90	66	
90	67	21.96	54.7	52.7	0.900	23.53	54.8	52.8	0.903	25.08	54.9	53.0	0.907	90	67	
90	68	23.21	55.0	53.2	0.844	24.84	55.2	53.3	0.848	26.45	55.3	53.4	0.852	90	68	
90	69	24.62	55.3	53.5	0.792	26.33	55.4	53.7	0.795	28.02	55.6	53.8	0.798	90	69	
90	70	26.18	55.4	53.8	0.742	27.98	55.6	54.0	0.745	29.75	55.8	54.2	0.749	90	70	
90	71	27.86	55.5	54.0	0.697	29.77	55.7	54.2	0.699	31.65	55.9	54.4	0.702	90	71	
90	72	29.59	55.6	54.3	0.655	31.62	55.8	54.5	0.658	33.62	56.0	54.6	0.660	90	72	
90	73	31.35	55.7	54.5	0.618	33.51	55.9	54.7	0.620	35.63	56.1	54.9	0.621	90	73	
90	74	33.16	55.8	54.7	0.583	35.44	56.0	54.9	0.585	37.69	56.2	55.1	0.586	90	74	
90	75	35.00	55.9	55.0	0.552	37.42	56.1	55.2	0.553	39.80	56.3	55.4	0.554	90	75	
90	76	36.89	56.0	55.2	0.523	39.44	56.2	55.4	0.524	41.95	56.5	55.7	0.525	90	76	
90	77	38.82	56.1	55.5	0.496	41.51	56.4	55.7	0.497	44.16	56.6	55.9	0.497	90	77	
90	78	40.79	56.2	55.7	0.471	43.62	56.5	56.0	0.472	46.41	56.7	56.2	0.472	90	78	
90	79	42.81	56.3	56.0	0.448	45.79	56.6	56.3	0.449	48.72	56.8	56.5	0.449	90	79	
90	80	44.88	56.5	56.3	0.427	48.00	56.7	56.5	0.427	51.08	57.0	56.8	0.427	90	80	
90	81	46.99	56.6	56.6	0.407	50.27	56.9	56.8	0.407	53.49	57.1	57.1	0.407	90	81	
90	82	49.16	56.9	56.9	0.386	52.58	57.1	57.1	0.386	55.96	57.4	57.4	0.386	90	82	
90	83	51.38	57.2	57.2	0.367	54.96	57.5	57.5	0.367	58.49	57.7	57.7	0.367	90	83	
90	84	53.64	57.5	57.5	0.349	57.39	57.8	57.8	0.349	61.08	58.0	58.0	0.348	90	84	
90	85	55.97	57.8	57.8	0.332	59.88	58.1	58.1	0.331	63.73	58.4	58.4	0.331	90	85	
90	86	58.35	58.1	58.1	0.316	62.42	58.4	58.4	0.315	66.45	58.7	58.7	0.315	90	86	
90	87	60.78	58.5	58.5	0.300	65.03	58.8	58.8	0.300	69.23	59.1	59.1	0.299	90	87	
95	67	22.34	55.0	52.4	1.000	24.05	55.1	52.4	1.000	25.74	55.2	52.5	1.000	95	67	
95	68	23.82	55.0	52.7	0.940	25.55	55.1	52.8	0.943	27.26	55.1	52.9	0.947	95	68	
95	69	24.99	55.4	53.2	0.888	26.77	55.5	53.3	0.891	28.54	55.6	53.4	0.895	95	69	
95	70	26.36	55.7	53.6	0.836	28.21	55.8	53.8	0.840	30.04	56.0	53.9	0.843	95	70	
95	71	27.87	55.9	54.0	0.788	29.81	56.1	54.1	0.791	31.72	56.2	54.3	0.794	95	71	
95	72	29.52	56.1	54.2	0.742	31.55	56.3	54.4	0.745	33.56	56.4	54.6	0.748	95	72	
95	73	31.28	56.2	54.5	0.699	33.43	56.4	54.7	0.702	35.55	56.6	54.9	0.705	95	73	
95	74	33.08	56.3	54.7	0.661	35.36	56.5	54.9	0.663	37.61	56.7	55.1	0.665	95	74	
95	75	34.93	56.4	54.9	0.625	37.34	56.6	55.2	0.627	39.71	56.8	55.4	0.629	95	75	
95	76	36.81	56.5	55.2	0.593	39.36	56.7	55.4	0.594	41.87	56.9	55.6	0.596	95	76	
95	77	38.74	56.6	55.5	0.562	41.42	56.8	55.7	0.564	44.07	57.0	55.9	0.565	95	77	
95	78	40.71	56.7	55.7	0.534	43.54	56.9	56.0	0.536	46.32	57.2	56.2	0.537	95	78	
95	79	42.73	56.8	56.0	0.509	45.70	57.1	56.2	0.509	48.63	57.3	56.5	0.510	95	79	
95	80	44.80	56.9	56.3	0.484	47.91	57.2	56.5	0.485	50.98	57.4	56.8	0.486	95	80	
95	81	46.91	57.0	56.5	0.462	50.18	57.3	56.8	0.462	53.40	57.6	57.1	0.463	95	81	
95	82	49.08	57.2	56.8	0.441	52.50	57.5	57.1	0.441	55.87	57.7	57.4	0.441	95	82	
95	83	51.29	57.3	57.1	0.421	54.87	57.6	57.4	0.421	58.40	57.9	57.7	0.421	95	83	
95	84	53.56	57.4	57.4	0.403	57.30	57.7	57.7	0.403	60.98	58.0	58.0	0.403	95	84	
95	85	55.88	57.8	57.8	0.383	59.78	58.1	58.1	0.383	63.63	58.3	58.3	0.383	95	85	
95	86	58.26	58.1	58.1	0.365	62.33	58.4	58.4	0.365	66.35	58.7	58.7	0.365	95	86	
95	87	60.69	58.4	58.4	0.348	64.94	58.7	58.7	0.348	69.12	59.0	59.0	0.348	95	87	
95	88	63.19	58.8	58.8	0.332	67.61	59.1	59.1	0.332	71.97	59.4	59.4	0.331	95	88	
95	89	65.74	59.1	59.1	0.317	70.34	59.4	59.4	0.316	74.88	59.8	59.8	0.316	95	89	
95	90	68.36	59.5	59.5	0.302	73.14	59.8	59.8	0.302	77.87	60.1	60.1	0.301	95	90	
95	91	71.03	59.8	59.8	0.289	76.01	60.2	60.2	0.288	80.92	60.5	60.5	0.287	95	91	
95	92	73.78	60.2	60.2	0.275	78.95	60.6	60.6	0.275	84.05	60.9	60.9	0.274	95	92	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 63
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	630 CFM (FPM = 467)				670 CFM (FPM = 496)				710 CFM (FPM = 526)				AIR TEMP (F)	
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
75	59	15.25	52.9	50.0	1.000	16.17	52.9	50.0	1.000	17.09	53.0	50.1	1.000	75	59	
75	60	15.26	52.9	51.2	1.000	16.19	52.9	51.2	1.000	17.10	53.0	51.3	1.000	75	60	
75	61	16.33	53.0	51.8	0.932	17.25	53.0	51.8	0.935	18.18	53.1	51.9	0.939	75	61	
75	62	17.39	53.5	52.3	0.857	18.35	53.5	52.4	0.861	19.31	53.6	52.5	0.864	75	62	
75	63	18.72	53.8	52.8	0.785	19.74	53.9	52.9	0.788	20.75	54.0	53.0	0.791	75	63	
75	64	20.29	54.0	53.1	0.718	21.38	54.1	53.2	0.721	22.45	54.2	53.3	0.724	75	64	
75	65	22.07	54.1	53.3	0.657	23.24	54.2	53.4	0.660	24.40	54.3	53.6	0.662	75	65	
75	66	23.92	54.2	53.5	0.605	25.20	54.3	53.7	0.607	26.46	54.4	53.8	0.609	75	66	
75	67	25.80	54.3	53.7	0.559	27.19	54.4	53.9	0.560	28.56	54.6	54.0	0.562	75	67	
75	68	27.73	54.4	54.0	0.518	29.23	54.5	54.1	0.519	30.70	54.7	54.2	0.520	75	68	
75	69	29.70	54.5	54.2	0.482	31.30	54.6	54.3	0.483	32.89	54.8	54.5	0.483	75	69	
75	70	31.70	54.6	54.4	0.450	33.43	54.7	54.6	0.450	35.12	54.9	54.7	0.451	75	70	
75	71	33.75	54.7	54.7	0.421	35.59	54.9	54.8	0.421	37.41	55.0	55.0	0.421	75	71	
75	72	35.85	54.9	54.9	0.393	37.81	55.1	55.1	0.393	39.74	55.2	55.2	0.393	75	72	
80	61	18.30	53.5	50.5	1.000	19.41	53.5	50.5	1.000	20.52	53.6	50.5	1.000	80	61	
80	62	18.32	53.5	51.7	1.000	19.43	53.5	51.7	1.000	20.53	53.6	51.8	1.000	80	62	
80	63	19.66	53.6	52.1	0.928	20.78	53.7	52.2	0.931	21.90	53.7	52.3	0.934	80	63	
80	64	20.83	54.1	52.7	0.861	22.00	54.1	52.8	0.865	23.15	54.2	52.9	0.868	80	64	
80	65	22.26	54.4	53.1	0.797	23.48	54.5	53.2	0.801	24.69	54.6	53.3	0.804	80	65	
80	66	23.90	54.6	53.5	0.737	25.19	54.7	53.6	0.740	26.47	54.8	53.7	0.743	80	66	
80	67	25.73	54.7	53.7	0.682	27.11	54.9	53.9	0.685	28.47	55.0	54.0	0.687	80	67	
80	68	27.65	54.8	53.9	0.633	29.14	55.0	54.1	0.635	30.61	55.1	54.2	0.637	80	68	
80	69	29.61	54.9	54.2	0.590	31.22	55.1	54.3	0.591	32.80	55.2	54.5	0.593	80	69	
80	70	31.62	55.0	54.4	0.551	33.34	55.2	54.5	0.552	35.03	55.4	54.7	0.553	80	70	
80	71	33.67	55.2	54.6	0.515	35.50	55.3	54.8	0.516	37.31	55.5	55.0	0.517	80	71	
80	72	35.76	55.3	54.9	0.484	37.72	55.4	55.0	0.484	39.64	55.6	55.2	0.485	80	72	
80	73	37.90	55.4	55.1	0.455	39.98	55.6	55.3	0.455	42.03	55.7	55.5	0.456	80	73	
80	74	40.09	55.5	55.4	0.429	42.29	55.7	55.6	0.429	44.46	55.9	55.8	0.429	80	74	
80	75	42.33	55.7	55.7	0.404	44.66	55.8	55.8	0.404	46.95	56.0	56.0	0.404	80	75	
80	76	44.62	55.9	55.9	0.380	47.08	56.1	56.1	0.380	49.50	56.3	56.3	0.379	80	76	
80	77	46.96	56.2	56.2	0.357	49.55	56.4	56.4	0.357	52.11	56.6	56.6	0.357	80	77	
85	63	21.35	54.0	51.0	1.000	22.65	54.1	51.1	1.000	23.94	54.2	51.1	1.000	85	63	
85	64	22.07	53.7	51.9	0.979	23.37	53.7	52.0	0.982	24.65	53.8	52.0	0.985	85	64	
85	65	23.08	54.3	52.6	0.920	24.40	54.3	52.7	0.924	25.71	54.4	52.7	0.927	85	65	
85	66	24.38	54.7	53.1	0.860	25.75	54.8	53.2	0.864	27.10	54.9	53.3	0.867	85	66	
85	67	25.90	55.0	53.5	0.802	27.34	55.1	53.7	0.805	28.75	55.2	53.8	0.809	85	67	
85	68	27.63	55.2	53.9	0.748	29.14	55.4	54.0	0.751	30.63	55.5	54.1	0.753	85	68	
85	69	29.53	55.4	54.1	0.697	31.13	55.5	54.3	0.700	32.71	55.7	54.4	0.702	85	69	
85	70	31.54	55.5	54.4	0.651	33.25	55.6	54.5	0.653	34.94	55.8	54.7	0.656	85	70	
85	71	33.58	55.6	54.6	0.610	35.41	55.8	54.8	0.612	37.22	55.9	54.9	0.614	85	71	
85	72	35.68	55.7	54.8	0.573	37.63	55.9	55.0	0.574	39.55	56.1	55.2	0.576	85	72	
85	73	37.82	55.8	55.1	0.539	39.89	56.0	55.3	0.540	41.93	56.2	55.5	0.541	85	73	
85	74	40.00	56.0	55.4	0.508	42.20	56.1	55.5	0.509	44.36	56.3	55.7	0.510	85	74	
85	75	42.24	56.1	55.6	0.480	44.56	56.3	55.8	0.481	46.85	56.5	56.0	0.481	85	75	
85	76	44.53	56.2	55.9	0.454	46.98	56.4	56.1	0.454	49.40	56.6	56.3	0.455	85	76	
85	77	46.87	56.4	56.2	0.430	49.45	56.6	56.4	0.430	52.00	56.8	56.6	0.430	85	77	
85	78	49.26	56.5	56.5	0.408	51.98	56.7	56.7	0.408	54.66	56.9	56.9	0.408	85	78	
85	79	51.71	56.8	56.8	0.385	54.57	57.0	57.0	0.385	57.39	57.2	57.2	0.385	85	79	
85	80	54.21	57.1	57.1	0.364	57.21	57.3	57.3	0.364	60.17	57.5	57.5	0.364	85	80	
85	81	56.77	57.4	57.4	0.345	59.92	57.6	57.6	0.344	63.03	57.8	57.8	0.344	85	81	
85	82	59.40	57.7	57.7	0.326	62.69	57.9	57.9	0.326	65.94	58.2	58.2	0.325	85	82	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 63
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	630 CFM (FPM = 467)				670 CFM (FPM = 496)				710 CFM (FPM = 526)				AIR TEMP (F)	
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
90	65	24.39	54.6	51.7	1.000	25.88	54.7	51.8	1.000	27.36	54.8	51.8	1.000	90	65	
90	66	25.45	54.4	52.4	0.965	26.94	54.5	52.5	0.968	28.42	54.5	52.5	0.971	90	66	
90	67	26.61	55.0	53.0	0.910	28.14	55.1	53.1	0.913	29.65	55.1	53.2	0.917	90	67	
90	68	28.04	55.4	53.6	0.855	29.62	55.5	53.7	0.858	31.18	55.6	53.8	0.861	90	68	
90	69	29.68	55.7	54.0	0.802	31.33	55.8	54.1	0.805	32.96	55.9	54.2	0.808	90	69	
90	70	31.51	55.9	54.3	0.752	33.24	56.0	54.5	0.755	34.95	56.2	54.6	0.758	90	70	
90	71	33.50	56.0	54.6	0.705	35.32	56.2	54.7	0.708	37.12	56.4	54.9	0.710	90	71	
90	72	35.59	56.2	54.8	0.662	37.53	56.3	55.0	0.664	39.45	56.5	55.2	0.667	90	72	
90	73	37.73	56.3	55.1	0.623	39.79	56.5	55.3	0.625	41.83	56.6	55.4	0.627	90	73	
90	74	39.91	56.4	55.3	0.588	42.10	56.6	55.5	0.589	44.26	56.8	55.7	0.591	90	74	
90	75	42.15	56.5	55.6	0.555	44.47	56.7	55.8	0.557	46.75	56.9	56.0	0.558	90	75	
90	76	44.43	56.7	55.9	0.526	46.88	56.9	56.1	0.527	49.29	57.1	56.3	0.528	90	76	
90	77	46.77	56.8	56.1	0.498	49.35	57.0	56.4	0.499	51.90	57.2	56.6	0.500	90	77	
90	78	49.16	56.9	56.4	0.473	51.88	57.2	56.6	0.473	54.56	57.4	56.9	0.474	90	78	
90	79	51.61	57.1	56.7	0.449	54.46	57.3	56.9	0.449	57.28	57.5	57.2	0.450	90	79	
90	80	54.11	57.2	57.0	0.427	57.11	57.5	57.3	0.427	60.06	57.7	57.5	0.427	90	80	
90	81	56.67	57.4	57.3	0.407	59.81	57.6	57.6	0.407	62.91	57.9	57.8	0.407	90	81	
90	82	59.30	57.7	57.7	0.386	62.58	57.9	57.9	0.386	65.83	58.1	58.1	0.386	90	82	
90	83	61.98	58.0	58.0	0.367	65.42	58.2	58.2	0.366	68.82	58.5	58.5	0.366	90	83	
90	84	64.73	58.3	58.3	0.348	68.32	58.6	58.6	0.348	71.87	58.8	58.8	0.348	90	84	
90	85	67.54	58.7	58.7	0.331	71.29	58.9	58.9	0.330	75.00	59.2	59.2	0.330	90	85	
90	86	70.42	59.0	59.0	0.314	74.33	59.3	59.3	0.314	78.20	59.5	59.5	0.313	90	86	
90	87	73.36	59.4	59.4	0.299	77.45	59.6	59.6	0.298	81.48	59.9	59.9	0.298	90	87	
95	67	27.43	55.3	52.5	1.000	29.11	55.3	52.5	1.000	30.79	55.4	52.6	1.000	95	67	
95	68	28.96	55.2	52.9	0.950	30.64	55.3	53.0	0.953	32.32	55.3	53.1	0.956	95	68	
95	69	30.28	55.7	53.6	0.898	32.01	55.8	53.7	0.901	33.73	55.9	53.8	0.904	95	69	
95	70	31.85	56.1	54.0	0.847	33.64	56.2	54.2	0.850	35.42	56.3	54.3	0.853	95	70	
95	71	33.61	56.4	54.4	0.798	35.48	56.5	54.6	0.801	37.33	56.6	54.7	0.804	95	71	
95	72	35.54	56.6	54.8	0.751	37.50	56.7	54.9	0.754	39.44	56.9	55.1	0.757	95	72	
95	73	37.64	56.7	55.0	0.708	39.70	56.9	55.2	0.710	41.73	57.1	55.4	0.713	95	73	
95	74	39.82	56.9	55.3	0.668	42.01	57.0	55.5	0.670	44.16	57.2	55.7	0.672	95	74	
95	75	42.06	57.0	55.6	0.631	44.37	57.2	55.8	0.633	46.65	57.4	55.9	0.635	95	75	
95	76	44.34	57.1	55.8	0.597	46.78	57.3	56.0	0.599	49.19	57.5	56.2	0.601	95	76	
95	77	46.68	57.3	56.1	0.566	49.25	57.5	56.3	0.568	51.79	57.7	56.5	0.569	95	77	
95	78	49.07	57.4	56.4	0.538	51.78	57.6	56.6	0.539	54.45	57.8	56.8	0.540	95	78	
95	79	51.51	57.5	56.7	0.511	54.36	57.8	56.9	0.512	57.17	58.0	57.1	0.513	95	79	
95	80	54.01	57.7	57.0	0.486	57.00	57.9	57.2	0.487	59.96	58.2	57.4	0.488	95	80	
95	81	56.57	57.8	57.3	0.463	59.71	58.1	57.5	0.464	62.80	58.3	57.8	0.464	95	81	
95	82	59.19	58.0	57.6	0.442	62.48	58.3	57.9	0.442	65.72	58.5	58.1	0.442	95	82	
95	83	61.88	58.2	57.9	0.421	65.31	58.4	58.2	0.421	68.70	58.7	58.4	0.422	95	83	
95	84	64.62	58.3	58.3	0.402	68.21	58.6	58.5	0.402	71.76	58.9	58.8	0.402	95	84	
95	85	67.43	58.6	58.6	0.383	71.18	58.9	58.9	0.384	74.88	59.1	59.1	0.384	95	85	
95	86	70.31	59.0	59.0	0.365	74.22	59.2	59.2	0.365	78.08	59.5	59.5	0.365	95	86	
95	87	73.26	59.3	59.3	0.348	77.33	59.6	59.6	0.347	81.36	59.9	59.9	0.347	95	87	
95	88	76.27	59.7	59.7	0.331	80.52	60.0	60.0	0.331	84.71	60.3	60.3	0.330	95	88	
95	89	79.36	60.1	60.1	0.315	83.78	60.4	60.4	0.315	88.15	60.7	60.7	0.315	95	89	
95	90	82.53	60.4	60.4	0.301	87.13	60.8	60.8	0.300	91.67	61.1	61.1	0.300	95	90	
95	91	85.77	60.8	60.8	0.287	90.55	61.2	61.2	0.286	95.27	61.5	61.5	0.286	95	91	
95	92	89.08	61.3	61.3	0.273	94.05	61.6	61.6	0.273	98.96	61.9	61.9	0.272	95	92	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 63
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	750 CFM (FPM = 556)				790 CFM (FPM = 585)				830 CFM (FPM = 615)				AIR TEMP (F)	
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
75	59	18.00	53.1	50.1	1.000	18.91	53.1	50.1	1.000	19.81	53.2	50.2	1.000	75	59	
75	60	18.01	53.1	51.3	1.000	18.92	53.1	51.3	1.000	19.82	53.2	51.3	1.000	75	60	
75	61	19.09	53.1	51.9	0.942	20.00	53.2	52.0	0.945	20.89	53.2	52.1	0.948	75	61	
75	62	20.25	53.7	52.6	0.867	21.19	53.7	52.6	0.871	22.12	53.8	52.7	0.874	75	62	
75	63	21.74	54.0	53.1	0.795	22.72	54.1	53.1	0.798	23.70	54.2	53.2	0.801	75	63	
75	64	23.51	54.3	53.4	0.727	24.56	54.4	53.5	0.729	25.59	54.5	53.6	0.732	75	64	
75	65	25.54	54.5	53.7	0.665	26.67	54.6	53.8	0.667	27.78	54.7	53.9	0.669	75	65	
75	66	27.70	54.6	53.9	0.610	28.93	54.7	54.0	0.612	30.14	54.8	54.1	0.614	75	66	
75	67	29.91	54.7	54.1	0.563	31.24	54.8	54.3	0.564	32.55	54.9	54.4	0.566	75	67	
75	68	32.16	54.8	54.4	0.521	33.59	54.9	54.5	0.522	35.01	55.1	54.6	0.523	75	68	
75	69	34.45	54.9	54.6	0.484	36.00	55.1	54.8	0.485	37.52	55.2	54.9	0.485	75	69	
75	70	36.80	55.1	54.9	0.451	38.45	55.2	55.0	0.451	40.08	55.3	55.2	0.451	75	70	
75	71	39.20	55.2	55.1	0.421	40.96	55.3	55.3	0.421	42.71	55.5	55.4	0.421	75	71	
75	72	41.65	55.4	55.4	0.393	43.53	55.6	55.6	0.393	45.38	55.7	55.7	0.393	75	72	
80	61	21.62	53.7	50.6	1.000	22.71	53.7	50.6	1.000	23.80	53.8	50.6	1.000	80	61	
80	62	21.63	53.7	51.8	1.000	22.73	53.7	51.8	1.000	23.82	53.8	51.9	1.000	80	62	
80	63	23.00	53.8	52.4	0.938	24.10	53.8	52.4	0.941	25.19	53.9	52.5	0.944	80	63	
80	64	24.29	54.3	53.0	0.872	25.43	54.4	53.0	0.875	26.55	54.4	53.1	0.878	80	64	
80	65	25.89	54.7	53.4	0.807	27.07	54.8	53.5	0.810	28.24	54.8	53.6	0.813	80	65	
80	66	27.73	54.9	53.8	0.746	28.98	55.0	53.9	0.749	30.22	55.1	54.0	0.752	80	66	
80	67	29.82	55.1	54.1	0.690	31.14	55.2	54.2	0.692	32.45	55.4	54.4	0.695	80	67	
80	68	32.06	55.2	54.3	0.639	33.49	55.4	54.5	0.641	34.90	55.5	54.6	0.643	80	68	
80	69	34.36	55.4	54.6	0.594	35.90	55.5	54.7	0.596	37.41	55.6	54.9	0.598	80	69	
80	70	36.70	55.5	54.8	0.554	38.35	55.6	55.0	0.555	39.98	55.8	55.1	0.557	80	70	
80	71	39.10	55.6	55.1	0.518	40.86	55.8	55.3	0.519	42.60	55.9	55.4	0.520	80	71	
80	72	41.55	55.8	55.4	0.486	43.42	55.9	55.5	0.486	45.27	56.1	55.7	0.487	80	72	
80	73	44.05	55.9	55.6	0.456	46.04	56.1	55.8	0.456	48.01	56.2	56.0	0.457	80	73	
80	74	46.60	56.1	55.9	0.429	48.72	56.2	56.1	0.429	50.81	56.4	56.3	0.429	80	74	
80	75	49.22	56.2	56.2	0.404	51.46	56.4	56.4	0.404	53.66	56.6	56.6	0.404	80	75	
80	76	51.89	56.5	56.5	0.379	54.26	56.7	56.7	0.379	56.59	56.9	56.9	0.379	80	76	
80	77	54.63	56.8	56.8	0.356	57.12	57.0	57.0	0.356	59.58	57.2	57.2	0.356	80	77	
85	63	25.23	54.3	51.1	1.000	26.51	54.3	51.2	1.000	27.79	54.4	51.2	1.000	85	63	
85	64	25.93	53.8	52.1	0.988	26.53	54.4	52.4	1.000	27.81	54.4	52.5	1.000	85	64	
85	65	27.02	54.5	52.8	0.930	28.31	54.5	52.9	0.933	29.59	54.6	53.0	0.936	85	65	
85	66	28.45	55.0	53.4	0.870	29.78	55.0	53.5	0.873	31.10	55.1	53.6	0.876	85	66	
85	67	30.16	55.3	53.9	0.812	31.54	55.4	54.0	0.815	32.92	55.5	54.1	0.818	85	67	
85	68	32.10	55.6	54.3	0.756	33.56	55.7	54.4	0.759	35.00	55.8	54.5	0.762	85	68	
85	69	34.26	55.8	54.6	0.705	35.80	55.9	54.7	0.708	37.32	56.1	54.8	0.710	85	69	
85	70	36.61	55.9	54.8	0.658	38.25	56.1	55.0	0.660	39.87	56.2	55.1	0.662	85	70	
85	71	39.00	56.1	55.1	0.615	40.75	56.2	55.2	0.617	42.49	56.4	55.4	0.619	85	71	
85	72	41.44	56.2	55.3	0.577	43.32	56.4	55.5	0.579	45.16	56.5	55.6	0.580	85	72	
85	73	43.94	56.4	55.6	0.542	45.93	56.5	55.8	0.543	47.90	56.7	55.9	0.545	85	73	
85	74	46.50	56.5	55.9	0.511	48.61	56.7	56.1	0.511	50.69	56.8	56.2	0.512	85	74	
85	75	49.11	56.7	56.2	0.482	51.34	56.8	56.4	0.482	53.55	57.0	56.5	0.483	85	75	
85	76	51.78	56.8	56.5	0.455	54.14	57.0	56.7	0.455	56.47	57.2	56.8	0.456	85	76	
85	77	54.52	57.0	56.8	0.430	57.00	57.2	57.0	0.431	59.46	57.4	57.1	0.431	85	77	
85	78	57.31	57.1	57.1	0.408	59.93	57.4	57.3	0.408	62.51	57.5	57.5	0.408	85	78	
85	79	60.17	57.4	57.4	0.385	62.92	57.6	57.6	0.385	65.64	57.8	57.8	0.385	85	79	
85	80	63.10	57.7	57.7	0.364	65.99	57.9	57.9	0.364	68.84	58.1	58.1	0.364	85	80	
85	81	66.09	58.1	58.1	0.344	69.12	58.3	58.3	0.343	72.11	58.5	58.5	0.343	85	81	
85	82	69.16	58.4	58.4	0.325	72.33	58.6	58.6	0.325	75.46	58.8	58.8	0.324	85	82	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 63
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	750 CFM (FPM = 556)				790 CFM (FPM = 585)				830 CFM (FPM = 615)				AIR TEMP (F)	
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
90	65	28.84	54.9	51.8	1.000	30.31	55.0	51.9	1.000	31.78	55.0	51.9	1.000	90	65	
90	66	29.88	54.6	52.6	0.974	31.34	54.7	52.7	0.977	32.79	54.7	52.7	0.979	90	66	
90	67	31.15	55.2	53.3	0.920	32.64	55.3	53.4	0.923	34.11	55.4	53.5	0.926	90	67	
90	68	32.73	55.7	53.9	0.865	34.27	55.8	54.0	0.868	35.79	55.9	54.1	0.871	90	68	
90	69	34.57	56.0	54.3	0.811	36.17	56.1	54.5	0.814	37.75	56.2	54.6	0.817	90	69	
90	70	36.64	56.3	54.7	0.760	38.31	56.4	54.9	0.763	39.96	56.5	55.0	0.766	90	70	
90	71	38.90	56.5	55.1	0.713	40.65	56.7	55.2	0.715	42.39	56.8	55.3	0.718	90	71	
90	72	41.34	56.6	55.3	0.669	43.21	56.8	55.5	0.671	45.05	56.9	55.6	0.673	90	72	
90	73	43.84	56.8	55.6	0.629	45.83	57.0	55.7	0.631	47.78	57.1	55.9	0.633	90	73	
90	74	46.40	56.9	55.9	0.593	48.50	57.1	56.0	0.594	50.58	57.3	56.2	0.596	90	74	
90	75	49.01	57.1	56.2	0.559	51.23	57.3	56.3	0.560	53.43	57.4	56.5	0.562	90	75	
90	76	51.68	57.3	56.4	0.529	54.03	57.4	56.6	0.530	56.35	57.6	56.8	0.531	90	76	
90	77	54.41	57.4	56.7	0.500	56.89	57.6	56.9	0.501	59.34	57.8	57.1	0.502	90	77	
90	78	57.20	57.6	57.1	0.474	59.81	57.8	57.2	0.475	62.39	58.0	57.4	0.475	90	78	
90	79	60.06	57.8	57.4	0.450	62.81	58.0	57.6	0.450	65.52	58.2	57.8	0.451	90	79	
90	80	62.98	57.9	57.7	0.428	65.87	58.2	57.9	0.428	68.71	58.4	58.1	0.428	90	80	
90	81	65.98	58.1	58.0	0.407	69.00	58.3	58.2	0.407	71.98	58.6	58.4	0.407	90	81	
90	82	69.04	58.4	58.4	0.386	72.20	58.6	58.6	0.386	75.33	58.8	58.8	0.386	90	82	
90	83	72.17	58.7	58.7	0.366	75.48	58.9	58.9	0.366	78.76	59.2	59.2	0.366	90	83	
90	84	75.38	59.1	59.1	0.347	78.84	59.3	59.3	0.347	82.26	59.5	59.5	0.347	90	84	
90	85	78.66	59.4	59.4	0.330	82.28	59.7	59.7	0.329	85.85	59.9	59.9	0.329	90	85	
90	86	82.02	59.8	59.8	0.313	85.79	60.0	60.0	0.312	89.52	60.3	60.3	0.312	90	86	
90	87	85.46	60.2	60.2	0.297	89.39	60.4	60.4	0.297	93.28	60.7	60.7	0.296	90	87	
95	67	32.45	55.5	52.6	1.000	34.11	55.6	52.6	1.000	35.76	55.7	52.7	1.000	95	67	
95	68	33.98	55.4	53.2	0.959	35.63	55.5	53.3	0.961	37.28	55.5	53.3	0.964	95	68	
95	69	35.43	56.0	53.9	0.907	37.12	56.1	54.0	0.910	38.80	56.1	54.0	0.913	95	69	
95	70	37.18	56.4	54.4	0.856	38.92	56.5	54.5	0.859	40.65	56.6	54.6	0.862	95	70	
95	71	39.16	56.8	54.9	0.807	40.97	56.9	55.0	0.810	42.77	57.0	55.1	0.813	95	71	
95	72	41.35	57.0	55.2	0.760	43.25	57.2	55.4	0.763	45.12	57.3	55.5	0.765	95	72	
95	73	43.74	57.2	55.6	0.716	45.72	57.4	55.7	0.718	47.67	57.5	55.9	0.721	95	73	
95	74	46.29	57.4	55.8	0.674	48.39	57.5	56.0	0.677	50.46	57.7	56.2	0.679	95	74	
95	75	48.90	57.5	56.1	0.637	51.12	57.7	56.3	0.639	53.32	57.9	56.5	0.641	95	75	
95	76	51.57	57.7	56.4	0.602	53.92	57.9	56.6	0.604	56.23	58.1	56.8	0.605	95	76	
95	77	54.30	57.9	56.7	0.570	56.77	58.0	56.9	0.572	59.22	58.2	57.1	0.573	95	77	
95	78	57.09	58.0	57.0	0.541	59.70	58.2	57.2	0.542	62.27	58.4	57.4	0.543	95	78	
95	79	59.95	58.2	57.3	0.514	62.69	58.4	57.5	0.514	65.39	58.6	57.7	0.515	95	79	
95	80	62.87	58.4	57.7	0.488	65.75	58.6	57.9	0.489	68.59	58.8	58.1	0.489	95	80	
95	81	65.86	58.6	58.0	0.464	68.88	58.8	58.2	0.465	71.86	59.0	58.4	0.465	95	81	
95	82	68.92	58.8	58.3	0.442	72.08	59.0	58.5	0.443	75.20	59.2	58.8	0.443	95	82	
95	83	72.05	58.9	58.7	0.422	75.36	59.2	58.9	0.422	78.63	59.4	59.1	0.422	95	83	
95	84	75.26	59.1	59.0	0.402	78.71	59.4	59.3	0.402	82.13	59.6	59.5	0.402	95	84	
95	85	78.54	59.4	59.4	0.384	82.15	59.6	59.6	0.384	85.72	59.9	59.9	0.384	95	85	
95	86	81.90	59.8	59.8	0.365	85.66	60.0	60.0	0.365	89.39	60.2	60.2	0.365	95	86	
95	87	85.34	60.1	60.1	0.347	89.26	60.4	60.4	0.347	93.14	60.6	60.6	0.347	95	87	
95	88	88.86	60.5	60.5	0.330	92.95	60.8	60.8	0.330	96.99	61.0	61.0	0.330	95	88	
95	89	92.46	60.9	60.9	0.314	96.72	61.2	61.2	0.314	100.9	61.5	61.5	0.314	95	89	
95	90	96.15	61.3	61.3	0.299	100.6	61.6	61.6	0.299	105.0	61.9	61.9	0.298	95	90	
95	91	99.93	61.8	61.8	0.285	104.5	62.0	62.0	0.285	109.1	62.3	62.3	0.284	95	91	
95	92	103.8	62.2	62.2	0.271	108.6	62.5	62.5	0.271	113.3	62.8	62.8	0.270	95	92	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 64
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	525 CFM (FPM = 262)				600 CFM (FPM = 300)				675 CFM (FPM = 337)				AIR TEMP (F)	
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
75	59	13.03	52.3	49.8	1.000	14.84	52.4	49.8	1.000	16.64	52.5	49.8	1.000	75	59	
75	60	13.63	52.0	50.5	0.971	15.45	52.1	50.6	0.976	17.25	52.1	50.7	0.981	75	60	
75	61	14.50	52.5	51.1	0.895	16.39	52.5	51.2	0.901	18.25	52.6	51.3	0.907	75	61	
75	62	15.64	52.7	51.5	0.821	17.64	52.9	51.7	0.827	19.60	53.0	51.8	0.832	75	62	
75	63	17.00	52.9	51.8	0.752	19.14	53.0	51.9	0.757	21.23	53.2	52.1	0.762	75	63	
75	64	18.53	52.9	51.9	0.689	20.84	53.1	52.1	0.694	23.11	53.3	52.3	0.698	75	64	
75	65	20.10	52.9	52.1	0.635	22.63	53.1	52.3	0.639	25.10	53.3	52.5	0.642	75	65	
75	66	21.71	52.9	52.2	0.589	24.45	53.2	52.5	0.591	27.13	53.4	52.7	0.594	75	66	
75	67	23.36	53.0	52.4	0.547	26.31	53.2	52.6	0.549	29.21	53.4	52.9	0.551	75	67	
75	68	25.03	53.0	52.6	0.511	28.21	53.3	52.8	0.512	31.32	53.5	53.1	0.513	75	68	
75	69	26.74	53.0	52.8	0.478	30.15	53.3	53.0	0.478	33.48	53.5	53.3	0.479	75	69	
75	70	28.49	53.1	53.0	0.448	32.12	53.4	53.2	0.449	35.69	53.6	53.5	0.449	75	70	
75	71	30.27	53.1	53.1	0.421	34.15	53.4	53.4	0.421	37.94	53.7	53.7	0.421	75	71	
75	72	32.09	53.3	53.3	0.394	36.21	53.6	53.6	0.394	40.24	53.9	53.9	0.394	75	72	
80	61	15.57	52.9	50.2	1.000	17.74	53.0	50.3	1.000	19.90	53.1	50.3	1.000	80	61	
80	62	16.39	52.6	50.9	0.961	18.58	52.7	51.0	0.966	20.75	52.7	51.1	0.971	80	62	
80	63	17.38	53.0	51.4	0.894	19.66	53.1	51.5	0.899	21.90	53.2	51.7	0.905	80	63	
80	64	18.62	53.3	51.8	0.827	21.02	53.4	52.0	0.833	23.37	53.6	52.1	0.838	80	64	
80	65	20.06	53.4	52.0	0.765	22.61	53.6	52.2	0.771	25.10	53.8	52.4	0.776	80	65	
80	66	21.65	53.4	52.2	0.709	24.38	53.7	52.4	0.714	27.05	53.9	52.7	0.718	80	66	
80	67	23.29	53.5	52.4	0.659	26.24	53.7	52.6	0.663	29.12	53.9	52.8	0.666	80	67	
80	68	24.96	53.5	52.6	0.615	28.13	53.8	52.8	0.618	31.23	54.0	53.0	0.621	80	68	
80	69	26.67	53.5	52.7	0.576	30.07	53.8	53.0	0.578	33.39	54.0	53.2	0.580	80	69	
80	70	28.41	53.6	52.9	0.540	32.04	53.9	53.2	0.542	35.60	54.1	53.4	0.544	80	70	
80	71	30.20	53.6	53.1	0.508	34.06	53.9	53.4	0.509	37.85	54.2	53.7	0.511	80	71	
80	72	32.02	53.7	53.3	0.479	36.13	54.0	53.6	0.480	40.15	54.2	53.9	0.481	80	72	
80	73	33.88	53.7	53.5	0.453	38.23	54.0	53.8	0.453	42.50	54.3	54.1	0.453	80	73	
80	74	35.78	53.8	53.7	0.429	40.39	54.1	54.1	0.429	44.90	54.4	54.3	0.429	80	74	
80	75	37.73	54.0	54.0	0.404	42.59	54.3	54.3	0.404	47.36	54.6	54.6	0.404	80	75	
80	76	39.72	54.2	54.2	0.381	44.85	54.5	54.5	0.381	49.88	54.8	54.8	0.381	80	76	
80	77	41.76	54.4	54.4	0.360	47.15	54.8	54.8	0.359	52.45	55.1	55.1	0.359	80	77	
85	63	18.11	53.5	50.8	1.000	20.64	53.6	50.8	1.000	23.16	53.7	50.9	1.000	85	63	
85	64	19.23	53.3	51.3	0.949	21.80	53.4	51.4	0.955	24.35	53.4	51.5	0.959	85	64	
85	65	20.36	53.6	51.8	0.888	23.03	53.8	51.9	0.893	25.66	53.9	52.1	0.898	85	65	
85	66	21.70	53.9	52.1	0.828	24.51	54.0	52.3	0.833	27.27	54.2	52.5	0.838	85	66	
85	67	23.23	54.0	52.4	0.771	26.20	54.2	52.6	0.777	29.11	54.4	52.8	0.781	85	67	
85	68	24.89	54.0	52.5	0.720	28.05	54.3	52.8	0.725	31.15	54.5	53.0	0.729	85	68	
85	69	26.60	54.1	52.7	0.674	29.99	54.3	53.0	0.678	33.30	54.5	53.2	0.681	85	69	
85	70	28.34	54.1	52.9	0.632	31.96	54.4	53.2	0.636	35.50	54.6	53.4	0.638	85	70	
85	71	30.12	54.1	53.1	0.595	33.98	54.4	53.4	0.598	37.75	54.7	53.6	0.600	85	71	
85	72	31.94	54.2	53.3	0.561	36.04	54.5	53.6	0.563	40.05	54.7	53.9	0.565	85	72	
85	73	33.80	54.2	53.5	0.530	38.15	54.5	53.8	0.532	42.40	54.8	54.1	0.533	85	73	
85	74	35.71	54.3	53.7	0.502	40.30	54.6	54.0	0.503	44.81	54.9	54.3	0.504	85	74	
85	75	37.65	54.3	53.9	0.476	42.50	54.7	54.3	0.477	47.26	55.0	54.6	0.477	85	75	
85	76	39.64	54.4	54.2	0.452	44.76	54.7	54.5	0.452	49.77	55.1	54.8	0.453	85	76	
85	77	41.67	54.4	54.4	0.430	47.06	54.8	54.7	0.430	52.34	55.2	55.1	0.430	85	77	
85	78	43.76	54.6	54.6	0.408	49.42	55.0	55.0	0.408	54.97	55.3	55.3	0.408	85	78	
85	79	45.89	54.9	54.9	0.386	51.83	55.2	55.2	0.386	57.66	55.6	55.6	0.386	85	79	
85	80	48.07	55.1	55.1	0.366	54.30	55.5	55.5	0.366	60.41	55.9	55.9	0.365	85	80	
85	81	50.30	55.4	55.4	0.348	56.83	55.8	55.8	0.347	63.23	56.1	56.1	0.346	85	81	
85	82	52.58	55.6	55.6	0.330	59.41	56.0	56.0	0.329	66.11	56.4	56.4	0.329	85	82	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 64
Leaving Water = 51.67

AIR TEMP. (F)		525 CFM (FPM = 262)				600 CFM (FPM = 300)				675 CFM (FPM = 337)				AIR TEMP (F)	
EDB	EWB	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
90	65	20.64	54.1	51.5	1.000	23.54	54.2	51.5	1.000	26.41	54.3	51.6	1.000	90	65
90	66	22.18	53.9	51.7	0.936	25.14	54.0	51.8	0.941	28.07	54.1	52.0	0.946	90	66
90	67	23.45	54.3	52.1	0.879	26.52	54.4	52.3	0.884	29.55	54.5	52.5	0.889	90	67
90	68	24.91	54.5	52.5	0.824	28.13	54.6	52.7	0.829	31.30	54.8	52.9	0.834	90	68
90	69	26.53	54.6	52.7	0.772	29.93	54.8	52.9	0.777	33.27	55.0	53.2	0.782	90	69
90	70	28.27	54.6	52.9	0.725	31.88	54.8	53.2	0.729	35.41	55.1	53.4	0.734	90	70
90	71	30.05	54.6	53.1	0.682	33.90	54.9	53.4	0.686	37.66	55.2	53.6	0.689	90	71
90	72	31.87	54.7	53.3	0.643	35.96	55.0	53.6	0.646	39.96	55.2	53.8	0.649	90	72
90	73	33.73	54.7	53.5	0.608	38.06	55.0	53.8	0.610	42.31	55.3	54.1	0.613	90	73
90	74	35.63	54.8	53.7	0.575	40.21	55.1	54.0	0.577	44.71	55.4	54.3	0.579	90	74
90	75	37.57	54.8	53.9	0.546	42.42	55.2	54.2	0.547	47.16	55.5	54.5	0.549	90	75
90	76	39.56	54.9	54.1	0.518	44.67	55.2	54.5	0.519	49.67	55.6	54.8	0.521	90	76
90	77	41.59	55.0	54.4	0.493	46.97	55.3	54.7	0.494	52.24	55.7	55.0	0.494	90	77
90	78	43.67	55.0	54.6	0.469	49.33	55.4	54.9	0.470	54.87	55.7	55.3	0.470	90	78
90	79	45.80	55.1	54.8	0.448	51.74	55.5	55.2	0.448	57.56	55.8	55.5	0.448	90	79
90	80	47.98	55.1	55.1	0.427	54.20	55.6	55.5	0.427	60.31	55.9	55.8	0.427	90	80
90	81	50.21	55.3	55.3	0.407	56.73	55.7	55.7	0.407	63.12	56.1	56.1	0.407	90	81
90	82	52.49	55.6	55.6	0.387	59.31	56.0	56.0	0.386	66.00	56.4	56.4	0.386	90	82
90	83	54.83	55.9	55.9	0.368	61.96	56.3	56.3	0.368	68.95	56.7	56.7	0.367	90	83
90	84	57.22	56.2	56.2	0.350	64.67	56.6	56.6	0.350	71.97	57.0	57.0	0.349	90	84
90	85	59.67	56.4	56.4	0.334	67.44	56.9	56.9	0.333	75.07	57.3	57.3	0.332	90	85
90	86	62.18	56.7	56.7	0.318	70.28	57.2	57.2	0.317	78.23	57.6	57.6	0.317	90	86
90	87	64.75	57.0	57.0	0.303	73.19	57.5	57.5	0.302	81.47	57.9	57.9	0.301	90	87
95	67	24.10	54.2	51.6	0.974	27.37	54.3	51.7	0.978	30.60	54.3	51.8	0.982	95	67
95	68	25.27	54.6	52.1	0.920	28.63	54.7	52.3	0.926	31.95	54.9	52.4	0.930	95	68
95	69	26.67	54.9	52.5	0.867	30.16	55.1	52.7	0.873	33.61	55.2	52.9	0.878	95	69
95	70	28.25	55.1	52.8	0.817	31.91	55.3	53.1	0.822	35.51	55.5	53.3	0.827	95	70
95	71	29.97	55.1	53.1	0.769	33.82	55.4	53.3	0.774	37.60	55.6	53.6	0.779	95	71
95	72	31.79	55.2	53.2	0.725	35.87	55.5	53.5	0.730	39.86	55.7	53.8	0.734	95	72
95	73	33.65	55.2	53.5	0.685	37.98	55.5	53.7	0.689	42.21	55.8	54.0	0.693	95	73
95	74	35.55	55.3	53.7	0.649	40.13	55.6	54.0	0.652	44.61	55.9	54.3	0.655	95	74
95	75	37.49	55.3	53.9	0.615	42.33	55.7	54.2	0.618	47.06	56.0	54.5	0.620	95	75
95	76	39.48	55.4	54.1	0.585	44.58	55.7	54.4	0.587	49.57	56.1	54.7	0.589	95	76
95	77	41.51	55.5	54.3	0.556	46.88	55.8	54.7	0.558	52.14	56.1	55.0	0.559	95	77
95	78	43.59	55.5	54.6	0.529	49.23	55.9	54.9	0.531	54.76	56.2	55.2	0.532	95	78
95	79	45.72	55.6	54.8	0.505	51.64	56.0	55.2	0.506	57.45	56.3	55.5	0.507	95	79
95	80	47.90	55.7	55.1	0.482	54.11	56.1	55.4	0.483	60.20	56.4	55.8	0.483	95	80
95	81	50.12	55.7	55.3	0.461	56.63	56.1	55.7	0.461	63.01	56.5	56.1	0.461	95	81
95	82	52.40	55.8	55.6	0.441	59.21	56.2	56.0	0.441	65.89	56.6	56.3	0.441	95	82
95	83	54.74	55.9	55.8	0.422	61.86	56.3	56.3	0.422	68.84	56.8	56.6	0.421	95	83
95	84	57.13	56.1	56.1	0.402	64.57	56.5	56.5	0.402	71.86	56.9	56.9	0.402	95	84
95	85	59.58	56.4	56.4	0.384	67.34	56.8	56.8	0.384	74.95	57.3	57.3	0.383	95	85
95	86	62.09	56.7	56.7	0.366	70.18	57.1	57.1	0.366	78.11	57.6	57.6	0.366	95	86
95	87	64.66	57.0	57.0	0.350	73.08	57.5	57.5	0.349	81.35	57.9	57.9	0.349	95	87
95	88	67.29	57.3	57.3	0.334	76.06	57.8	57.8	0.333	84.67	58.2	58.2	0.333	95	88
95	89	69.98	57.6	57.6	0.319	79.11	58.1	58.1	0.318	88.07	58.6	58.6	0.318	95	89
95	90	72.74	57.9	57.9	0.305	82.24	58.5	58.5	0.304	91.55	58.9	58.9	0.303	95	90
95	91	75.57	58.3	58.3	0.291	85.44	58.8	58.8	0.290	95.12	59.3	59.3	0.290	95	91
95	92	78.47	58.6	58.6	0.279	88.71	59.2	59.2	0.278	98.77	59.7	59.7	0.277	95	92

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 64
Leaving Water = 51.67

AIR TEMP (°F) EDB	EWB	AIRFLOW												AIR TEMP (°F) EDB		EWB			
		525 CFM (FPM = 262)				600 CFM (FPM = 300)				675 CFM (FPM = 337)									
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR						
100	69	27 16	55 0	52 1	0 954	30 82	55 1	52 2	0 959	34 44	55 2	52 4	0 963	100	69				
100	70	28 50	55 3	52 6	0 904	32 27	55 5	52 8	0 909	36 00	55 6	52 9	0 914	100	70				
100	71	30 04	55 5	52 9	0 854	33 97	55 7	53 2	0 860	37 84	55 9	53 4	0 865	100	71				
100	72	31 74	55 7	53 2	0 807	35 85	55 9	53 5	0 812	39 90	56 1	53 7	0 817	100	72				
100	73	33 58	55 7	53 4	0 763	37 89	56 0	53 7	0 768	42 13	56 3	54 0	0 772	100	73				
100	74	35 47	55 8	53 6	0 722	40 04	56 1	53 9	0 727	44 51	56 4	54 2	0 731	100	74				
100	75	37 41	55 8	53 8	0 685	42 24	56 2	54 2	0 689	46 96	56 4	54 5	0 692	100	75				
100	76	39 40	55 9	54 1	0 651	44 49	56 2	54 4	0 654	49 47	56 5	54 7	0 657	100	76				
100	77	41 43	56 0	54 3	0 619	46 79	56 3	54 6	0 622	52 04	56 6	55 0	0 624	100	77				
100	78	43 51	56 0	54 5	0 590	49 14	56 4	54 9	0 592	54 66	56 7	55 2	0 594	100	78				
100	79	45 63	56 1	54 8	0 562	51 55	56 5	55 1	0 564	57 34	56 8	55 5	0 566	100	79				
100	80	47 81	56 2	55 0	0 537	54 01	56 6	55 4	0 538	60 09	56 9	55 7	0 540	100	80				
100	81	50 04	56 2	55 3	0 513	56 53	56 6	55 7	0 514	62 90	57 0	56 0	0 515	100	81				
100	82	52 32	56 3	55 5	0 491	59 11	56 7	55 9	0 491	65 78	57 1	56 3	0 492	100	82				
100	83	54 65	56 4	55 8	0 470	61 76	56 8	56 2	0 470	68 73	57 3	56 6	0 471	100	83				
100	84	57 04	56 5	56 1	0 450	64 46	56 9	56 5	0 450	71 75	57 4	56 9	0 451	100	84				
100	85	59 49	56 5	56 4	0 432	67 23	57 0	56 8	0 432	74 83	57 5	57 2	0 432	100	85				
100	86	61 99	56 7	56 7	0 414	70 07	57 1	57 1	0 414	78 00	57 6	57 5	0 414	100	86				
100	87	64 56	57 0	57 0	0 396	72 98	57 4	57 4	0 396	81 24	57 9	57 9	0 396	100	87				
100	88	67 19	57 3	57 3	0 378	75 95	57 7	57 7	0 378	84 55	58 2	58 2	0 378	100	88				
100	89	69 88	57 6	57 6	0 362	79 00	58 1	58 1	0 361	87 95	58 5	58 5	0 361	100	89				
100	90	72 64	57 9	57 9	0 346	82 13	58 4	58 4	0 346	91 43	58 9	58 9	0 345	100	90				
100	91	75 47	58 2	58 2	0 331	85 32	58 8	58 8	0 331	95 00	59 2	59 2	0 330	100	91				
100	92	78 37	58 6	58 6	0 317	88 60	59 1	59 1	0 316	98 65	59 6	59 6	0 316	100	92				
100	93	81 33	58 9	58 9	0 304	91 96	59 5	59 5	0 303	102 4	60 0	60 0	0 302	100	93				
100	94	84 37	59 3	59 3	0 291	95 40	59 9	59 9	0 290	106 2	60 4	60 4	0 289	100	94				
100	95	87 49	59 7	59 7	0 279	98 93	60 2	60 2	0 278	110 2	60 8	60 8	0 277	100	95				
100	96	90 68	60 0	60 0	0 267	102 5	60 6	60 6	0 266	114 2	61 2	61 2	0 265	100	96				
100	97	93 96	60 4	60 4	0 256	106 2	61 0	61 0	0 255	118 3	61 6	61 6	0 253	100	97				
105	71	30 40	55 7	52 6	0 934	34 46	55 8	52 8	0 939	38 49	56 0	52 9	0 944	105	71				
105	72	31 90	56 0	53 0	0 886	36 11	56 2	53 2	0 892	40 26	56 3	53 4	0 896	105	72				
105	73	33 58	56 2	53 3	0 840	37 96	56 4	53 6	0 845	42 28	56 6	53 8	0 850	105	73				
105	74	35 40	56 3	53 6	0 796	39 98	56 6	53 9	0 801	44 49	56 8	54 2	0 806	105	74				
105	75	37 34	56 3	53 8	0 755	42 15	56 6	54 1	0 760	46 87	56 9	54 4	0 764	105	75				
105	76	39 32	56 4	54 0	0 717	44 40	56 7	54 4	0 721	49 37	57 0	54 7	0 725	105	76				
105	77	41 35	56 5	54 3	0 682	46 69	56 8	54 6	0 686	51 93	57 1	54 9	0 689	105	77				
105	78	43 43	56 5	54 5	0 650	49 05	56 9	54 9	0 653	54 56	57 2	55 2	0 656	105	78				
105	79	45 55	56 6	54 7	0 620	51 45	57 0	55 1	0 622	57 24	57 3	55 4	0 625	105	79				
105	80	47 72	56 7	55 0	0 592	53 91	57 1	55 4	0 594	59 98	57 4	55 7	0 596	105	80				
105	81	49 95	56 7	55 2	0 565	56 43	57 1	55 6	0 567	62 80	57 5	56 0	0 569	105	81				
105	82	52 23	56 8	55 5	0 541	59 02	57 2	55 9	0 542	65 67	57 6	56 3	0 544	105	82				
105	83	54 56	56 9	55 8	0 518	61 66	57 3	56 2	0 519	68 62	57 8	56 6	0 520	105	83				
105	84	56 95	57 0	56 0	0 496	64 36	57 4	56 5	0 497	71 63	57 9	56 9	0 498	105	84				
105	85	59 40	57 1	56 3	0 476	67 13	57 5	56 8	0 476	74 72	58 0	57 2	0 477	105	85				
105	86	61 90	57 1	56 6	0 457	69 97	57 6	57 1	0 457	77 88	58 1	57 5	0 457	105	86				
105	87	64 47	57 2	56 9	0 439	72 87	57 8	57 4	0 439	81 12	58 2	57 8	0 439	105	87				
105	88	67 10	57 3	57 2	0 422	75 85	57 9	57 7	0 421	84 43	58 4	58 1	0 421	105	88				
105	89	69 79	57 5	54 04	78 89	58 0	58 0	0 405	87 83	58 5	58 5	0 405	105	89					
105	90	72 55	57 9	57 9	0 387	82 02	58 4	58 4	0 387	91 31	58 8	58 8	0 387	105	90				
105	91	75 37	58 2	58 2	0 371	85 21	58 7	58 7	0 371	94 87	59 2	59 2	0 371	105	91				
105	92	78 27	58 5	58 5	0 355	88 49	59 1	59 1	0 355	98 52	59 6	59 6	0 355	105	92				
105	93	81 23	58 9	58 9	0 341	91 85	59 4	59 4	0 340	102 3	59 9	59 9	0 340	105	93				
105	94	84 27	59 2	59 2	0 327	95 29	59 8	59 8	0 326	106 1	60 3	60 3	0 326	105	94				
105	95	87 39	59 6	59 6	0 313	98 81	60 2	60 2	0 313	110 0	60 7	60 7	0 312	105	95				
105	96	90 58	60 0	60 0	0 300	102 4	60 6	60 6	0 300	114 0	61 1	61 1	0 299	105	96				
105	97	93 85	60 4	60 4	0 288	106 1	61 0	61 0	0 287	118 2	61 6	61 6	0 286	105	97				
105	98	97 21	60 8	60 8	0 276	109 9	61 4	61 4	0 275	122 4	62 0	62 0	0 275	105	98				
105	99	100 6	61 2	61 2	0 265	113 8	61 8	61 8	0 264	126 7	62 4	62 4	0 263	105	99				
105	100	104 2	61 6	61 6	0 254	117 8	62 3	62 3	0 253	131 2	62 9	62 9	0 252	105	100				
105	101	107 8	62 0	62 0	0 244	121 9	62 7	62 7	0 243	135 7	63 3	63 3	0 242	105	101				
105	102	111 5	62 5	62 5	0 234	126 1	63 2	63 2	0 233	140 4	63 8	63 8	0 232	105	102				

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 64
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	750 CFM (FPM = 375)				825 CFM (FPM = 412)				900 CFM (FPM = 450)				AIR TEMP (F)	
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
75	59	18.42	52.6	49.9	1.000	20.19	52.65	49.9	1.000	21.95	52.7	49.9	1.000	75	59	
75	60	19.03	52.2	50.8	0.986	20.20	52.6	51.1	1.000	21.96	52.7	51.1	1.000	75	60	
75	61	20.09	52.7	51.4	0.912	21.90	52.8	51.5	0.917	23.70	52.9	51.6	0.922	75	61	
75	62	21.53	53.1	51.9	0.837	23.43	53.2	52.0	0.842	25.31	53.3	52.1	0.847	75	62	
75	63	23.29	53.3	52.3	0.767	25.31	53.5	52.4	0.771	27.30	53.6	52.5	0.776	75	63	
75	64	25.32	53.5	52.5	0.702	27.49	53.6	52.7	0.706	29.62	53.8	52.8	0.710	75	64	
75	65	27.51	53.5	52.7	0.645	29.88	53.7	52.9	0.649	32.19	53.9	53.0	0.652	75	65	
75	66	29.75	53.6	52.9	0.596	32.32	53.8	53.1	0.598	34.83	53.9	53.2	0.601	75	66	
75	67	32.04	53.6	53.1	0.552	34.81	53.8	53.3	0.554	37.53	54.0	53.5	0.556	75	67	
75	68	34.37	53.7	53.3	0.514	37.35	53.9	53.5	0.515	40.28	54.1	53.7	0.516	75	68	
75	69	36.75	53.8	53.5	0.480	39.95	54.0	53.7	0.480	43.09	54.2	53.9	0.481	75	69	
75	70	39.18	53.9	53.7	0.449	42.60	54.1	53.9	0.449	45.95	54.3	54.1	0.450	75	70	
75	71	41.66	53.9	53.9	0.421	45.30	54.2	54.2	0.421	48.88	54.4	54.4	0.421	75	71	
75	72	44.19	54.2	54.2	0.393	48.07	54.4	54.4	0.393	51.88	54.6	54.6	0.393	75	72	
80	61	22.04	53.1	50.3	1.000	24.17	53.2	50.4	1.000	26.29	53.3	50.4	1.000	80	61	
80	62	22.89	52.8	51.2	0.976	25.02	52.9	51.2	0.980	27.13	52.9	51.3	0.984	80	62	
80	63	24.12	53.3	51.8	0.910	26.30	53.4	51.9	0.914	28.46	53.5	52.0	0.919	80	63	
80	64	25.69	53.7	52.3	0.843	27.98	53.8	52.4	0.848	30.23	53.9	52.5	0.853	80	64	
80	65	27.56	53.9	52.6	0.780	29.97	54.1	52.8	0.785	32.34	54.2	52.9	0.789	80	65	
80	66	29.67	54.1	52.9	0.722	32.23	54.2	53.0	0.726	34.75	54.4	53.2	0.730	80	66	
80	67	31.94	54.1	53.1	0.670	34.71	54.3	53.3	0.673	37.42	54.5	53.4	0.676	80	67	
80	68	34.27	54.2	53.3	0.623	37.25	54.4	53.5	0.626	40.16	54.6	53.7	0.629	80	68	
80	69	36.65	54.3	53.5	0.582	39.84	54.5	53.7	0.584	42.97	54.7	53.9	0.586	80	69	
80	70	39.08	54.3	53.7	0.545	42.49	54.6	53.9	0.547	45.84	54.8	54.1	0.548	80	70	
80	71	41.56	54.4	53.9	0.512	45.19	54.7	54.1	0.513	48.76	54.9	54.4	0.514	80	71	
80	72	44.09	54.5	54.1	0.481	47.96	54.8	54.4	0.482	51.75	55.0	54.6	0.483	80	72	
80	73	46.68	54.6	54.4	0.454	50.78	54.9	54.6	0.454	54.81	55.1	54.9	0.454	80	73	
80	74	49.33	54.7	54.6	0.428	53.67	55.0	54.9	0.428	57.94	55.2	55.1	0.429	80	74	
80	75	52.04	54.9	54.9	0.404	56.63	55.1	55.1	0.404	61.13	55.4	55.4	0.404	80	75	
80	76	54.81	55.1	55.1	0.380	59.65	55.4	55.4	0.380	64.40	55.7	55.7	0.380	80	76	
80	77	57.64	55.4	55.4	0.358	62.74	55.7	55.7	0.358	67.75	56.0	56.0	0.357	80	77	
85	63	25.66	53.7	50.9	1.000	28.14	53.8	51.0	1.000	30.62	53.9	51.0	1.000	85	63	
85	64	26.86	53.5	51.6	0.964	29.35	53.6	51.7	0.968	31.82	53.6	51.8	0.972	85	64	
85	65	28.26	54.0	52.2	0.903	30.82	54.1	52.3	0.908	33.36	54.2	52.4	0.912	85	65	
85	66	29.98	54.3	52.6	0.843	32.66	54.5	52.8	0.848	35.30	54.6	52.9	0.852	85	66	
85	67	31.97	54.5	53.0	0.786	34.78	54.7	53.1	0.791	37.56	54.9	53.3	0.795	85	67	
85	68	34.18	54.7	53.2	0.733	37.16	54.9	53.4	0.737	40.08	55.0	53.6	0.741	85	68	
85	69	36.55	54.8	53.4	0.685	39.73	55.0	53.7	0.688	42.85	55.2	53.9	0.691	85	69	
85	70	38.98	54.8	53.7	0.641	42.38	55.0	53.9	0.644	45.72	55.3	54.1	0.647	85	70	
85	71	41.45	54.9	53.9	0.602	45.08	55.1	54.1	0.604	48.64	55.4	54.3	0.607	85	71	
85	72	43.99	55.0	54.1	0.567	47.84	55.2	54.4	0.568	51.63	55.5	54.6	0.570	85	72	
85	73	46.57	55.1	54.3	0.534	50.67	55.3	54.6	0.536	54.69	55.6	54.8	0.537	85	73	
85	74	49.22	55.2	54.6	0.505	53.56	55.4	54.8	0.506	57.81	55.7	55.1	0.507	85	74	
85	75	51.93	55.3	54.8	0.478	56.51	55.6	55.1	0.478	61.00	55.8	55.4	0.479	85	75	
85	76	54.69	55.4	55.1	0.453	59.53	55.7	55.4	0.453	64.27	55.9	55.6	0.453	85	76	
85	77	57.53	55.5	55.4	0.430	62.61	55.8	55.6	0.430	67.61	56.1	55.9	0.430	85	77	
85	78	60.42	55.6	55.6	0.408	65.77	55.9	55.9	0.408	71.03	56.2	56.2	0.408	85	78	
85	79	63.38	55.9	55.9	0.386	69.00	56.2	56.2	0.386	74.52	56.5	56.5	0.386	85	79	
85	80	66.42	56.2	56.2	0.365	72.31	56.5	56.5	0.365	78.10	56.8	56.8	0.365	85	80	
85	81	69.52	56.5	56.5	0.346	75.69	56.8	56.8	0.345	81.76	57.1	57.1	0.345	85	81	
85	82	72.69	56.8	56.8	0.328	79.16	57.1	57.1	0.327	85.51	57.4	57.4	0.327	85	82	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 64
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	750 CFM (FPM = 375)				825 CFM (FPM = 412)				900 CFM (FPM = 450)				AIR TEMP (F)	
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
90	65	29.27	54.4	51.6	1.000	32.12	54.4	51.6	1.000	34.94	54.5	51.7	1.000	90	65	
90	66	30.96	54.2	52.1	0.950	33.83	54.3	52.2	0.954	36.67	54.4	52.3	0.958	90	66	
90	67	32.55	54.7	52.6	0.894	35.50	54.8	52.8	0.898	38.42	54.9	52.9	0.903	90	67	
90	68	34.43	55.0	53.0	0.839	37.50	55.1	53.2	0.843	40.54	55.3	53.4	0.848	90	68	
90	69	36.55	55.2	53.4	0.787	39.78	55.4	53.6	0.791	42.96	55.5	53.7	0.795	90	69	
90	70	38.88	55.3	53.6	0.738	42.28	55.5	53.9	0.742	45.63	55.7	54.1	0.746	90	70	
90	71	41.35	55.4	53.9	0.693	44.97	55.6	54.1	0.696	48.52	55.8	54.3	0.700	90	71	
90	72	43.88	55.5	54.1	0.652	47.73	55.7	54.3	0.655	51.51	55.9	54.6	0.658	90	72	
90	73	46.47	55.6	54.3	0.615	50.55	55.8	54.6	0.618	54.56	56.1	54.8	0.620	90	73	
90	74	49.11	55.7	54.6	0.581	53.44	55.9	54.8	0.583	57.68	56.2	55.1	0.585	90	74	
90	75	51.82	55.8	54.8	0.550	56.39	56.0	55.1	0.552	60.88	56.3	55.3	0.553	90	75	
90	76	54.58	55.9	55.1	0.522	59.40	56.2	55.3	0.523	64.14	56.4	55.6	0.524	90	76	
90	77	57.41	56.0	55.3	0.495	62.49	56.3	55.6	0.496	67.48	56.6	55.9	0.497	90	77	
90	78	60.31	56.1	55.6	0.471	65.65	56.4	55.9	0.471	70.89	56.7	56.2	0.472	90	78	
90	79	63.27	56.2	55.9	0.448	68.88	56.5	56.2	0.448	74.39	56.8	56.5	0.449	90	79	
90	80	66.30	56.3	56.2	0.427	72.18	56.6	56.5	0.427	77.96	57.0	56.8	0.427	90	80	
90	81	69.40	56.4	56.4	0.407	75.56	56.8	56.8	0.407	81.62	57.1	57.1	0.407	90	81	
90	82	72.57	56.7	56.7	0.386	79.02	57.1	57.1	0.386	85.36	57.4	57.4	0.386	90	82	
90	83	75.82	57.0	57.0	0.367	82.57	57.4	57.4	0.367	89.20	57.7	57.7	0.367	90	83	
90	84	79.15	57.4	57.4	0.349	86.19	57.7	57.7	0.349	93.12	58.1	58.1	0.348	90	84	
90	85	82.55	57.7	57.7	0.332	89.91	58.1	58.1	0.331	97.13	58.4	58.4	0.331	90	85	
90	86	86.04	58.0	58.0	0.316	93.71	58.4	58.4	0.315	101.2	58.8	58.8	0.315	90	86	
90	87	89.61	58.4	58.4	0.301	97.60	58.7	58.7	0.300	105.5	59.1	59.1	0.299	90	87	
95	67	33.81	54.4	51.9	0.986	36.09	55.1	52.4	1.000	39.27	55.2	52.5	1.000	95	67	
95	68	35.23	55.0	52.6	0.935	38.48	55.1	52.7	0.939	41.70	55.2	52.8	0.943	95	68	
95	69	37.00	55.4	53.1	0.882	40.36	55.5	53.2	0.887	43.68	55.6	53.4	0.891	95	69	
95	70	39.05	55.6	53.5	0.832	42.55	55.8	53.7	0.836	45.99	56.0	53.8	0.840	95	70	
95	71	41.32	55.8	53.8	0.783	44.98	56.0	54.0	0.787	48.58	56.2	54.2	0.791	95	71	
95	72	43.78	56.0	54.1	0.738	47.62	56.2	54.3	0.742	51.40	56.4	54.5	0.746	95	72	
95	73	46.36	56.1	54.3	0.696	50.44	56.3	54.5	0.699	54.44	56.5	54.8	0.703	95	73	
95	74	49.01	56.1	54.5	0.658	53.32	56.4	54.8	0.661	57.56	56.6	55.0	0.664	95	74	
95	75	51.71	56.2	54.8	0.623	56.27	56.5	55.0	0.625	60.75	56.8	55.3	0.628	95	75	
95	76	54.47	56.3	55.0	0.591	59.28	56.6	55.3	0.593	64.01	56.9	55.6	0.595	95	76	
95	77	57.30	56.5	55.3	0.561	62.37	56.7	55.6	0.563	67.35	57.0	55.9	0.564	95	77	
95	78	60.19	56.6	55.6	0.533	65.52	56.9	55.9	0.535	70.76	57.2	56.1	0.536	95	78	
95	79	63.15	56.7	55.8	0.508	68.75	57.0	56.1	0.509	74.25	57.3	56.4	0.510	95	79	
95	80	66.18	56.8	56.1	0.484	72.05	57.1	56.4	0.485	77.82	57.4	56.7	0.485	95	80	
95	81	69.28	56.9	56.4	0.462	75.43	57.3	56.7	0.462	81.48	57.6	57.0	0.463	95	81	
95	82	72.45	57.0	56.7	0.441	78.89	57.4	57.0	0.441	85.22	57.7	57.4	0.441	95	82	
95	83	75.70	57.2	57.0	0.421	82.43	57.5	57.4	0.421	89.05	57.9	57.7	0.421	95	83	
95	84	79.02	57.3	57.3	0.403	86.06	57.7	57.7	0.403	92.97	58.1	58.0	0.403	95	84	
95	85	82.42	57.6	57.6	0.383	89.77	58.0	58.0	0.383	96.99	58.4	58.4	0.383	95	85	
95	86	85.91	58.0	58.0	0.365	93.57	58.4	58.4	0.365	101.1	58.7	58.7	0.365	95	86	
95	87	89.48	58.3	58.3	0.348	97.46	58.7	58.7	0.348	105.3	59.1	59.1	0.348	95	87	
95	88	93.13	58.7	58.7	0.332	101.4	59.1	59.1	0.332	109.6	59.5	59.5	0.331	95	88	
95	89	96.87	59.0	59.0	0.317	105.5	59.4	59.4	0.316	114.0	59.8	59.8	0.316	95	89	
95	90	100.7	59.4	59.4	0.302	109.7	59.8	59.8	0.302	118.5	60.2	60.2	0.301	95	90	
95	91	104.6	59.8	59.8	0.289	114.0	60.2	60.2	0.288	123.2	60.6	60.6	0.287	95	91	
95	92	108.7	60.1	60.1	0.276	118.4	60.6	60.6	0.275	127.9	61.0	61.0	0.274	95	92	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 64
Leaving Water = 51.67

AIR TEMP (°F) EDB	EWB	AIRFLOW												AIR TEMP (°F) EDB		EWB			
		750 CFM (FPM = 375)				825 CFM (FPM = 412)				900 CFM (FPM = 450)									
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR						
100	69	38.03	55.2	52.5	0.968	41.59	55.3	52.6	0.971	45.12	55.4	52.7	0.975	100	69				
100	70	39.69	55.7	53.1	0.918	43.33	55.8	53.2	0.923	46.94	56.0	53.4	0.927	100	70				
100	71	41.66	56.1	53.6	0.869	45.43	56.2	53.7	0.874	49.15	56.4	53.9	0.878	100	71				
100	72	43.88	56.3	53.9	0.822	47.80	56.5	54.1	0.826	51.67	56.7	54.3	0.830	100	72				
100	73	46.30	56.5	54.2	0.777	50.40	56.7	54.5	0.781	54.44	56.9	54.7	0.785	100	73				
100	74	48.90	56.6	54.5	0.735	53.20	56.9	54.8	0.738	57.43	57.1	55.0	0.742	100	74				
100	75	51.60	56.7	54.8	0.696	56.15	57.0	55.0	0.699	60.62	57.2	55.3	0.702	100	75				
100	76	54.36	56.8	55.0	0.660	59.16	57.1	55.3	0.663	63.88	57.4	55.5	0.665	100	76				
100	77	57.19	56.9	55.3	0.627	62.24	57.2	55.6	0.629	67.21	57.5	55.8	0.631	100	77				
100	78	60.08	57.0	55.5	0.596	65.40	57.3	55.8	0.598	70.62	57.6	56.1	0.600	100	78				
100	79	63.03	57.2	55.8	0.567	68.62	57.5	56.1	0.569	74.11	57.8	56.4	0.571	100	79				
100	80	66.06	57.3	56.1	0.541	71.92	57.6	56.4	0.542	77.68	57.9	56.7	0.544	100	80				
100	81	69.16	57.4	56.4	0.516	75.30	57.7	56.7	0.517	81.34	58.1	57.0	0.518	100	81				
100	82	72.33	57.5	56.7	0.493	78.76	57.9	57.0	0.494	85.08	58.2	57.3	0.495	100	82				
100	83	75.57	57.7	57.0	0.471	82.30	58.0	57.3	0.472	88.91	58.4	57.7	0.472	100	83				
100	84	78.90	57.8	57.3	0.451	85.92	58.2	57.6	0.451	92.83	58.5	58.0	0.452	100	84				
100	85	82.30	57.9	57.6	0.432	89.63	58.3	58.0	0.432	96.84	58.7	58.3	0.432	100	85				
100	86	85.78	58.1	57.9	0.414	93.43	58.5	58.3	0.414	100.9	58.9	58.7	0.413	100	86				
100	87	89.35	58.3	58.3	0.396	97.32	58.7	58.7	0.396	105.2	59.1	59.0	0.396	100	87				
100	88	93.00	58.6	58.6	0.378	101.3	59.0	59.0	0.378	109.5	59.4	59.4	0.378	100	88				
100	89	96.74	59.0	59.0	0.361	105.4	59.4	59.4	0.361	113.9	59.8	59.8	0.361	100	89				
100	90	100.6	59.3	59.3	0.345	109.6	59.8	59.8	0.345	118.4	60.2	60.2	0.344	100	90				
100	91	104.5	59.7	59.7	0.330	113.8	60.1	60.1	0.329	123.0	60.6	60.6	0.329	100	91				
100	92	108.5	60.1	60.1	0.315	118.2	60.5	60.5	0.315	127.7	61.0	61.0	0.314	100	92				
100	93	112.6	60.5	60.5	0.301	122.7	60.9	60.9	0.301	132.6	61.4	61.4	0.300	100	93				
100	94	116.9	60.9	60.9	0.288	127.3	61.4	61.4	0.287	137.6	61.8	61.8	0.287	100	94				
100	95	121.2	61.3	61.3	0.276	132.0	61.8	61.8	0.275	142.7	62.3	62.3	0.274	100	95				
100	96	125.6	61.7	61.7	0.264	136.8	62.2	62.2	0.263	147.9	62.7	62.7	0.262	100	96				
100	97	130.1	62.2	62.2	0.252	141.8	62.7	62.7	0.251	153.2	63.2	63.2	0.250	100	97				
105	71	42.48	56.1	53.1	0.948	46.42	56.2	53.2	0.952	50.33	56.3	53.3	0.956	105	71				
105	72	44.37	56.5	53.6	0.901	48.42	56.6	53.8	0.905	52.44	56.8	53.9	0.909	105	72				
105	73	46.54	56.8	54.1	0.855	50.74	57.0	54.3	0.859	54.88	57.1	54.4	0.863	105	73				
105	74	48.93	57.0	54.4	0.810	53.30	57.2	54.6	0.815	57.61	57.4	54.9	0.819	105	74				
105	75	51.51	57.2	54.7	0.768	56.07	57.4	55.0	0.772	60.56	57.7	55.2	0.776	105	75				
105	76	54.25	57.3	55.0	0.729	59.04	57.6	55.3	0.733	63.75	57.8	55.5	0.736	105	76				
105	77	57.07	57.4	55.2	0.692	62.12	57.7	55.5	0.696	67.08	58.0	55.8	0.699	105	77				
105	78	59.96	57.5	55.5	0.659	65.27	57.8	55.8	0.661	70.49	58.1	56.1	0.664	105	78				
105	79	62.92	57.6	55.8	0.627	68.50	57.9	56.1	0.630	73.98	58.2	56.4	0.632	105	79				
105	80	65.94	57.8	56.1	0.598	71.80	58.1	56.4	0.600	77.55	58.4	56.7	0.602	105	80				
105	81	69.04	57.9	56.3	0.571	75.17	58.2	56.7	0.572	81.20	58.5	57.0	0.574	105	81				
105	82	72.21	58.0	56.6	0.545	78.63	58.4	57.0	0.547	84.94	58.7	57.3	0.548	105	82				
105	83	75.45	58.1	56.9	0.521	82.16	58.5	57.3	0.522	88.76	58.9	57.6	0.524	105	83				
105	84	78.77	58.3	57.2	0.499	85.79	58.7	57.6	0.500	92.68	59.0	57.9	0.501	105	84				
105	85	82.17	58.4	57.6	0.478	89.49	58.8	57.9	0.478	96.69	59.2	58.3	0.479	105	85				
105	86	85.65	58.6	57.9	0.458	93.29	59.0	58.3	0.458	100.8	59.4	58.6	0.459	105	86				
105	87	89.22	58.7	58.2	0.439	97.18	59.1	58.6	0.439	105.0	59.5	59.0	0.439	105	87				
105	88	92.87	58.8	58.6	0.421	101.2	59.3	59.0	0.421	109.3	59.7	59.4	0.421	105	88				
105	89	96.61	59.0	58.9	0.404	105.2	59.5	59.3	0.404	113.7	59.9	59.7	0.404	105	89				
105	90	100.4	59.3	59.3	0.387	109.4	59.7	59.7	0.388	118.2	60.1	60.1	0.388	105	90				
105	91	104.4	59.7	59.7	0.371	113.7	60.1	60.1	0.371	122.8	60.5	60.5	0.371	105	91				
105	92	108.4	60.0	60.0	0.355	118.1	60.5	60.5	0.355	127.6	60.9	60.9	0.355	105	92				
105	93	112.5	60.4	60.4	0.340	122.6	60.9	60.9	0.339	132.4	61.3	61.3	0.339	105	93				
105	94	116.7	60.8	60.8	0.325	127.1	61.3	61.3	0.325	137.4	61.8	61.8	0.324	105	94				
105	95	121.0	61.2	61.2	0.311	131.9	61.7	61.7	0.311	142.5	62.2	62.2	0.310	105	95				
105	96	125.5	61.7	61.7	0.298	136.7	62.2	62.2	0.298	147.7	62.7	62.7	0.297	105	96				
105	97	130.0	62.1	62.1	0.286	141.6	62.6	62.6	0.285	153.1	63.1	63.1	0.284	105	97				
105	98	134.7	62.5	62.5	0.274	146.7	63.1	63.1	0.273	158.5	63.6	63.6	0.272	105	98				
105	99	139.4	63.0	63.0	0.262	151.9	63.5	63.5	0.261	164.1	64.1	64.1	0.261	105	99				
105	100	144.3	63.5	63.5	0.251	157.2	64.0	64.0	0.250	169.9	64.6	64.6	0.249	105	100				
105	101	149.3	63.9	63.9	0.241	162.6	64.5	64.5	0.240	175.8	65.1	65.1	0.239	105	101				
105	102	154.4	64.4	64.4	0.231	168.2	65.0	65.0	0.229	181.8	65.6	65.6	0.228	105	102				

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 64
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	975 CFM (FPM = 487)				1050 CFM (FPM = 525)				1125 CFM (FPM = 562)				AIR TEMP. (F)	
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
90	65	37.75	54.6	51.7	1.000	40.55	54.7	51.8	1.000	43.33	54.8	51.8	1.000	90	65	
90	66	39.48	54.5	52.4	0.962	42.27	54.5	52.5	0.966	45.03	54.6	52.5	0.969	90	66	
90	67	41.31	55.0	53.0	0.907	44.17	55.1	53.1	0.911	46.99	55.2	53.2	0.915	90	67	
90	68	43.54	55.4	53.5	0.852	46.50	55.5	53.6	0.856	49.42	55.6	53.8	0.860	90	68	
90	69	46.09	55.7	53.9	0.799	49.18	55.8	54.1	0.803	52.23	56.0	54.2	0.807	90	69	
90	70	48.92	55.9	54.3	0.749	52.17	56.1	54.4	0.753	55.36	56.2	54.6	0.756	90	70	
90	71	52.01	56.0	54.5	0.703	55.44	56.2	54.7	0.706	58.81	56.4	54.9	0.709	90	71	
90	72	55.22	56.2	54.8	0.661	58.87	56.4	55.0	0.663	62.45	56.6	55.2	0.666	90	72	
90	73	58.50	56.3	55.0	0.622	62.37	56.5	55.2	0.624	66.18	56.7	55.5	0.627	90	73	
90	74	61.86	56.4	55.3	0.587	65.96	56.6	55.5	0.589	69.99	56.9	55.7	0.591	90	74	
90	75	65.29	56.5	55.6	0.555	69.62	56.8	55.8	0.556	73.89	57.0	56.0	0.558	90	75	
90	76	68.79	56.7	55.9	0.525	73.37	56.9	56.1	0.526	77.87	57.2	56.3	0.528	90	76	
90	77	72.38	56.8	56.1	0.498	77.20	57.1	56.4	0.499	81.95	57.3	56.6	0.500	90	77	
90	78	76.05	57.0	56.4	0.473	81.12	57.2	56.7	0.473	86.12	57.5	57.0	0.474	90	78	
90	79	79.81	57.1	56.8	0.449	85.13	57.4	57.0	0.449	90.38	57.7	57.3	0.450	90	79	
90	80	83.65	57.3	57.1	0.427	89.24	57.6	57.3	0.427	94.74	57.9	57.6	0.427	90	80	
90	81	87.58	57.4	57.4	0.407	93.44	57.7	57.7	0.407	99.20	58.0	57.9	0.407	90	81	
90	82	91.60	57.7	57.7	0.386	97.73	58.0	58.0	0.386	103.8	58.3	58.3	0.386	90	82	
90	83	95.72	58.1	58.1	0.366	102.1	58.4	58.4	0.366	108.4	58.6	58.6	0.366	90	83	
90	84	99.93	58.4	58.4	0.348	106.6	58.7	58.7	0.348	113.2	59.0	59.0	0.347	90	84	
90	85	104.2	58.7	58.7	0.330	111.2	59.1	59.1	0.330	118.1	59.4	59.4	0.330	90	85	
90	86	108.7	59.1	59.1	0.314	116.0	59.4	59.4	0.313	123.1	59.8	59.8	0.313	90	86	
90	87	113.2	59.5	59.5	0.298	120.8	59.8	59.8	0.298	128.3	60.2	60.2	0.297	90	87	
95	67	42.44	55.3	52.5	1.000	45.59	55.4	52.5	1.000	48.72	55.5	52.6	1.000	95	67	
95	68	44.88	55.3	52.9	0.947	48.04	55.3	53.0	0.951	51.17	55.4	53.1	0.954	95	68	
95	69	46.95	55.7	53.5	0.895	50.20	55.9	53.6	0.899	53.40	56.0	53.8	0.903	95	69	
95	70	49.39	56.1	54.0	0.844	52.75	56.3	54.2	0.848	56.07	56.4	54.3	0.852	95	70	
95	71	52.13	56.4	54.4	0.795	55.63	56.6	54.6	0.799	59.09	56.7	54.7	0.803	95	71	
95	72	55.12	56.6	54.7	0.749	58.79	56.8	54.9	0.753	62.40	57.0	55.1	0.756	95	72	
95	73	58.37	56.7	55.0	0.706	62.23	57.0	55.2	0.709	66.03	57.2	55.4	0.712	95	73	
95	74	61.72	56.9	55.3	0.666	65.81	57.1	55.5	0.669	69.84	57.3	55.7	0.672	95	74	
95	75	65.15	57.0	55.5	0.630	69.48	57.2	55.8	0.632	73.73	57.5	56.0	0.635	95	75	
95	76	68.65	57.2	55.8	0.597	73.22	57.4	56.1	0.599	77.71	57.6	56.3	0.601	95	76	
95	77	72.24	57.3	56.1	0.566	77.05	57.5	56.4	0.567	81.79	57.8	56.6	0.569	95	77	
95	78	75.91	57.4	56.4	0.537	80.97	57.7	56.7	0.539	85.95	58.0	56.9	0.540	95	78	
95	79	79.66	57.6	56.7	0.511	84.98	57.9	57.0	0.512	90.21	58.1	57.2	0.513	95	79	
95	80	83.50	57.8	57.0	0.486	89.08	58.0	57.3	0.487	94.57	58.3	57.6	0.488	95	80	
95	81	87.43	57.9	57.3	0.463	93.28	58.2	57.6	0.464	99.03	58.5	57.9	0.464	95	81	
95	82	91.45	58.1	57.7	0.442	97.57	58.4	58.0	0.442	103.6	58.7	58.3	0.442	95	82	
95	83	95.56	58.2	58.0	0.421	102.0	58.6	58.3	0.421	108.3	58.9	58.6	0.422	95	83	
95	84	99.77	58.4	58.4	0.402	106.5	58.8	58.7	0.402	113.1	59.1	59.0	0.402	95	84	
95	85	104.1	58.7	58.7	0.383	111.1	59.0	59.0	0.384	117.9	59.3	59.3	0.384	95	85	
95	86	108.5	59.1	59.1	0.365	115.8	59.4	59.4	0.365	123.0	59.7	59.7	0.365	95	86	
95	87	113.0	59.4	59.4	0.347	120.6	59.8	59.8	0.347	128.1	60.1	60.1	0.347	95	87	
95	88	117.6	59.8	59.8	0.331	125.6	60.2	60.2	0.331	133.3	60.5	60.5	0.330	95	88	
95	89	122.4	60.2	60.2	0.315	130.6	60.6	60.6	0.315	138.7	60.9	60.9	0.314	95	89	
95	90	127.2	60.6	60.6	0.300	135.8	61.0	61.0	0.300	144.2	61.3	61.3	0.299	95	90	
95	91	132.2	61.0	61.0	0.286	141.1	61.4	61.4	0.286	149.8	61.8	61.8	0.285	95	91	
95	92	137.3	61.4	61.4	0.273	146.5	61.8	61.8	0.272	155.6	62.2	62.2	0.271	95	92	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 65
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	850 CFM (FPM = 283)				1000 CFM (FPM = 333)				1150 CFM (FPM = 383)				AIR TEMP (F)	
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
75	59	23.59	49.6	48.6	1.000		27.45	49.9	48.7	1.000	31.24	50.2	48.8	1.000	75	59
75	60	24.97	49.6	49.2	0.947		28.82	49.8	49.4	0.956	32.59	50.1	49.6	0.964	75	60
75	61	26.66	50.0	49.6	0.873		30.66	50.3	49.9	0.882	34.54	50.6	50.1	0.891	75	61
75	62	28.76	50.3	49.9	0.802		32.98	50.6	50.2	0.811	37.06	51.0	50.5	0.819	75	62
75	63	31.18	50.4	50.1	0.737		35.69	50.8	50.5	0.745	40.03	51.2	50.8	0.752	75	63
75	64	33.83	50.4	50.2	0.679		38.70	50.9	50.6	0.685	43.36	51.3	51.0	0.692	75	64
75	65	36.67	50.4	50.2	0.628		41.95	50.9	50.7	0.633	46.99	51.4	51.1	0.638	75	65
75	66	39.57	50.4	50.2	0.583		45.30	50.9	50.7	0.586	50.78	51.4	51.2	0.590	75	66
75	67	42.52	50.4	50.3	0.543		48.72	50.9	50.8	0.546	54.65	51.4	51.2	0.548	75	67
75	68	45.53	50.4	50.3	0.508		52.20	51.0	50.8	0.510	58.59	51.5	51.3	0.511	75	68
75	69	48.60	50.4	50.3	0.477		55.75	51.0	50.9	0.477	62.61	51.5	51.4	0.478	75	69
75	70	51.73	50.4	50.4	0.448		59.38	51.0	51.0	0.448	66.71	51.5	51.5	0.448	75	70
75	71	54.93	50.5	50.5	0.422		63.08	51.1	51.1	0.421	70.90	51.6	51.6	0.421	75	71
75	72	58.19	50.5	50.5	0.398		66.86	51.2	51.2	0.397	75.18	51.7	51.7	0.396	75	72
80	61	28.11	49.8	48.9	1.000		32.74	50.1	49.0	1.000	37.30	50.4	49.1	1.000	80	61
80	62	29.98	49.8	49.3	0.939		34.63	50.1	49.5	0.947	39.17	50.3	49.8	0.954	80	62
80	63	31.89	50.1	49.7	0.873		36.72	50.5	50.0	0.881	41.41	50.8	50.3	0.889	80	63
80	64	34.16	50.4	49.9	0.809		39.24	50.8	50.3	0.818	44.15	51.1	50.6	0.825	80	64
80	65	36.71	50.5	50.1	0.751		42.10	51.0	50.5	0.759	47.29	51.4	50.9	0.766	80	65
80	66	39.46	50.6	50.2	0.698		45.22	51.1	50.7	0.705	50.76	51.5	51.1	0.711	80	66
80	67	42.39	50.6	50.2	0.651		48.56	51.1	50.8	0.656	54.49	51.6	51.2	0.661	80	67
80	68	45.40	50.6	50.3	0.609		52.04	51.1	50.8	0.613	58.41	51.6	51.3	0.617	80	68
80	69	48.46	50.6	50.3	0.571		55.59	51.1	50.9	0.574	62.43	51.7	51.4	0.577	80	69
80	70	51.59	50.6	50.4	0.537		59.21	51.2	51.0	0.539	66.53	51.7	51.5	0.541	80	70
80	71	54.78	50.6	50.4	0.506		62.91	51.2	51.1	0.508	70.72	51.8	51.6	0.509	80	71
80	72	58.04	50.6	50.5	0.478		66.68	51.2	51.1	0.479	74.99	51.8	51.7	0.480	80	72
80	73	61.37	50.6	50.6	0.453		70.54	51.3	51.2	0.453	79.36	51.9	51.8	0.453	80	73
80	74	64.77	50.7	50.7	0.429		74.48	51.3	51.3	0.429	83.82	52.0	52.0	0.428	80	74
80	75	68.25	50.7	50.7	0.406		78.51	51.4	51.4	0.406	88.39	52.1	52.1	0.405	80	75
80	76	71.81	50.8	50.8	0.386		82.63	51.6	51.6	0.385	93.05	52.2	52.2	0.384	80	76
80	77	75.44	50.9	50.9	0.367		86.84	51.7	51.7	0.365	97.82	52.4	52.4	0.364	80	77
85	63	33.44	49.5	48.9	0.988		38.01	50.3	49.4	1.000	43.33	50.6	49.5	1.000	85	63
85	64	35.14	50.0	49.4	0.928		40.60	50.3	49.7	0.936	45.93	50.6	50.0	0.943	85	64
85	65	37.27	50.3	49.8	0.868		42.94	50.7	50.1	0.876	48.45	51.1	50.4	0.884	85	65
85	66	39.72	50.5	50.0	0.811		45.67	51.0	50.4	0.819	51.44	51.4	50.8	0.826	85	66
85	67	42.41	50.6	50.2	0.758		48.70	51.1	50.6	0.765	54.77	51.6	51.1	0.772	85	67
85	68	45.29	50.7	50.3	0.709		51.97	51.2	50.8	0.716	58.40	51.7	51.2	0.722	85	68
85	69	48.32	50.7	50.3	0.665		55.44	51.3	50.9	0.671	62.27	51.8	51.4	0.676	85	69
85	70	51.45	50.7	50.4	0.626		59.05	51.3	51.0	0.630	66.35	51.9	51.5	0.634	85	70
85	71	54.64	50.7	50.4	0.590		62.74	51.4	51.0	0.593	70.53	51.9	51.6	0.597	85	71
85	72	57.89	50.7	50.5	0.557		66.51	51.4	51.1	0.560	74.80	52.0	51.7	0.562	85	72
85	73	61.22	50.8	50.6	0.527		70.37	51.4	51.2	0.529	79.16	52.0	51.8	0.531	85	73
85	74	64.62	50.8	50.6	0.500		74.31	51.5	51.3	0.501	83.62	52.1	51.9	0.503	85	74
85	75	68.09	50.8	50.7	0.475		78.33	51.5	51.4	0.476	88.18	52.2	52.1	0.476	85	75
85	76	71.65	50.8	50.8	0.452		82.45	51.6	51.5	0.452	92.84	52.3	52.2	0.452	85	76
85	77	75.28	50.9	50.9	0.430		86.65	51.6	51.6	0.430	97.61	52.3	52.3	0.430	85	77
85	78	78.99	51.0	51.0	0.409		90.96	51.8	51.8	0.409	102.5	52.5	52.5	0.408	85	78
85	79	82.80	51.1	51.1	0.390		95.36	51.9	51.9	0.389	107.5	52.6	52.6	0.388	85	79
85	80	86.69	51.2	51.2	0.372		99.87	52.0	52.0	0.371	112.6	52.8	52.8	0.369	85	80
85	81	90.67	51.3	51.3	0.355		104.5	52.2	52.2	0.353	117.8	52.9	52.9	0.352	85	81
85	82	94.75	51.4	51.4	0.339		109.2	52.3	52.3	0.337	123.1	53.1	53.1	0.336	85	82

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 65
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	850 CFM (FPM = 283)				1000 CFM (FPM = 333)				1150 CFM (FPM = 383)				AIR TEMP (F)	
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
90	65	38.51	49.8	49.1	0.971	44.64	50.1	49.4	0.978	50.65	50.4	49.6	0.985	90	65	
90	66	40.49	50.2	49.6	0.915	46.78	50.6	49.9	0.923	52.92	51.0	50.2	0.930	90	66	
90	67	42.85	50.5	49.9	0.860	49.38	51.0	50.3	0.868	55.74	51.4	50.7	0.875	90	67	
90	68	45.48	50.7	50.1	0.808	52.33	51.2	50.6	0.815	58.97	51.6	51.0	0.822	90	68	
90	69	48.32	50.8	50.2	0.759	55.54	51.3	50.8	0.766	62.52	51.8	51.2	0.773	90	69	
90	70	51.33	50.9	50.4	0.715	58.97	51.4	50.9	0.721	66.33	52.0	51.4	0.727	90	70	
90	71	54.49	50.9	50.4	0.674	62.58	51.5	51.0	0.679	70.37	52.1	51.6	0.684	90	71	
90	72	57.74	50.9	50.5	0.636	66.35	51.5	51.1	0.641	74.61	52.1	51.7	0.645	90	72	
90	73	61.07	50.9	50.6	0.602	70.20	51.6	51.2	0.606	78.97	52.2	51.8	0.609	90	73	
90	74	64.46	50.9	50.6	0.571	74.13	51.6	51.3	0.574	83.43	52.3	51.9	0.577	90	74	
90	75	67.93	51.0	50.7	0.543	78.15	51.7	51.4	0.545	87.98	52.3	52.0	0.547	90	75	
90	76	71.48	51.0	50.8	0.516	82.26	51.7	51.5	0.517	92.64	52.4	52.2	0.519	90	76	
90	77	75.11	51.0	50.9	0.491	86.47	51.8	51.6	0.492	97.40	52.5	52.3	0.493	90	77	
90	78	78.83	51.1	51.0	0.469	90.77	51.8	51.7	0.469	102.3	52.6	52.5	0.470	90	78	
90	79	82.63	51.1	51.1	0.447	95.17	51.9	51.9	0.447	107.3	52.7	52.6	0.448	90	79	
90	80	86.51	51.2	51.2	0.427	99.67	52.0	52.0	0.427	112.3	52.8	52.8	0.427	90	80	
90	81	90.49	51.3	51.3	0.408	104.3	52.1	52.1	0.407	117.6	52.9	52.9	0.407	90	81	
90	82	94.56	51.4	51.4	0.390	109.0	52.3	52.3	0.389	122.9	53.1	53.1	0.388	90	82	
90	83	98.73	51.5	51.5	0.373	113.8	52.4	52.4	0.372	128.4	53.3	53.3	0.371	90	83	
90	84	103.0	51.7	51.7	0.357	118.8	52.6	52.6	0.356	134.0	53.4	53.4	0.354	90	84	
90	85	107.4	51.8	51.8	0.342	123.8	52.7	52.7	0.340	139.7	53.6	53.6	0.339	90	85	
90	86	111.9	51.9	51.9	0.328	129.0	52.9	52.9	0.326	145.6	53.8	53.8	0.324	90	86	
90	87	116.4	52.1	52.1	0.314	134.3	53.1	53.1	0.312	151.6	54.0	54.0	0.310	90	87	
95	67	43.81	50.1	49.4	0.954	50.74	50.5	49.7	0.961	57.55	50.8	50.0	0.967	95	67	
95	68	46.06	50.5	49.7	0.901	53.21	50.9	50.1	0.909	60.18	51.3	50.5	0.916	95	68	
95	69	48.64	50.7	50.0	0.850	56.08	51.2	50.5	0.858	63.30	51.7	50.9	0.865	95	69	
95	70	51.46	50.9	50.2	0.802	59.24	51.4	50.7	0.809	66.79	51.9	51.2	0.816	95	70	
95	71	54.46	51.0	50.4	0.757	62.65	51.6	50.9	0.764	70.56	52.1	51.4	0.770	95	71	
95	72	57.62	51.0	50.5	0.716	66.25	51.7	51.1	0.722	74.57	52.3	51.6	0.727	95	72	
95	73	60.92	51.1	50.5	0.677	70.03	51.7	51.2	0.683	78.80	52.4	51.8	0.688	95	73	
95	74	64.31	51.1	50.6	0.642	73.95	51.8	51.3	0.647	83.23	52.4	51.9	0.651	95	74	
95	75	67.78	51.1	50.7	0.610	77.97	51.8	51.4	0.614	87.78	52.5	52.0	0.617	95	75	
95	76	71.32	51.1	50.8	0.580	82.08	51.9	51.5	0.583	92.43	52.6	52.2	0.586	95	76	
95	77	74.95	51.2	50.9	0.553	86.28	51.9	51.6	0.555	97.19	52.7	52.3	0.557	95	77	
95	78	78.66	51.2	51.0	0.527	90.58	52.0	51.7	0.529	102.1	52.7	52.4	0.530	95	78	
95	79	82.45	51.2	51.1	0.503	94.97	52.1	51.9	0.504	107.0	52.8	52.6	0.506	95	79	
95	80	86.34	51.3	51.2	0.481	99.47	52.1	52.0	0.482	112.1	52.9	52.7	0.482	95	80	
95	81	90.31	51.3	51.3	0.460	104.1	52.2	52.1	0.460	117.3	53.0	52.9	0.461	95	81	
95	82	94.38	51.4	51.4	0.441	108.8	52.3	52.3	0.441	122.7	53.1	53.1	0.441	95	82	
95	83	98.55	51.5	51.5	0.422	113.6	52.4	52.4	0.421	128.1	53.2	53.2	0.421	95	83	
95	84	102.8	51.6	51.6	0.404	118.6	52.6	52.6	0.403	133.7	53.4	53.4	0.403	95	84	
95	85	107.2	51.8	51.8	0.387	123.6	52.7	52.7	0.386	139.5	53.6	53.6	0.385	95	85	
95	86	111.7	51.9	51.9	0.371	128.8	52.9	52.9	0.370	145.3	53.8	53.8	0.369	95	86	
95	87	116.2	52.0	52.0	0.356	134.1	53.0	53.0	0.354	151.3	54.0	54.0	0.353	95	87	
95	88	120.9	52.2	52.2	0.342	139.5	53.2	53.2	0.340	157.5	54.2	54.2	0.338	95	88	
95	89	125.7	52.3	52.3	0.328	145.1	53.4	53.4	0.326	163.8	54.4	54.4	0.324	95	89	
95	90	130.7	52.5	52.5	0.315	150.8	53.6	53.6	0.313	170.2	54.6	54.6	0.311	95	90	
95	91	135.7	52.6	52.6	0.303	156.6	53.8	53.8	0.301	176.8	54.8	54.8	0.298	95	91	
95	92	140.9	52.8	52.8	0.291	162.6	54.0	54.0	0.289	183.6	55.1	55.1	0.286	95	92	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 65
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	AIRFLOW								AIR TEMP. (F)				
			1300 CFM (FPM = 433)				1450 CFM (FPM = 483)				1600 CFM (FPM = 533)				
MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR				
75	59	34.98	50.4	48.9	1.000	38.66	50.6	49.0	1.000	42.29	50.8	49.1	1.000	75	59
75	60	36.28	50.3	49.8	0.971	39.90	50.4	49.9	0.978	43.45	50.6	50.1	0.984	75	60
75	61	38.33	50.8	50.4	0.899	42.02	51.1	50.6	0.906	45.63	51.3	50.8	0.913	75	61
75	62	41.01	51.2	50.8	0.827	44.85	51.5	51.1	0.834	48.59	51.7	51.3	0.841	75	62
75	63	44.22	51.5	51.1	0.759	48.27	51.8	51.4	0.766	52.20	52.1	51.7	0.772	75	63
75	64	47.85	51.7	51.3	0.697	52.18	52.0	51.7	0.703	56.36	52.3	51.9	0.709	75	64
75	65	51.82	51.8	51.5	0.642	56.48	52.1	51.8	0.647	60.97	52.5	52.1	0.651	75	65
75	66	56.04	51.8	51.6	0.594	61.10	52.2	51.9	0.597	65.98	52.6	52.3	0.600	75	66
75	67	60.34	51.9	51.7	0.551	65.83	52.3	52.1	0.553	71.12	52.6	52.4	0.556	75	67
75	68	64.73	51.9	51.8	0.513	70.65	52.3	52.2	0.515	76.36	52.7	52.6	0.516	75	68
75	69	69.21	52.0	51.9	0.479	75.57	52.4	52.3	0.480	81.71	52.8	52.7	0.481	75	69
75	70	73.78	52.0	52.0	0.449	80.59	52.5	52.5	0.449	87.16	52.9	52.9	0.449	75	70
75	71	78.44	52.1	52.1	0.421	85.71	52.6	52.6	0.421	92.74	53.0	53.0	0.421	75	71
75	72	83.20	52.3	52.3	0.395	90.95	52.7	52.7	0.395	98.43	53.2	53.2	0.394	75	72
80	61	41.79	50.6	49.2	1.000	46.22	50.9	49.4	1.000	50.59	51.1	49.5	1.000	80	61
80	62	43.62	50.6	50.0	0.961	47.99	50.8	50.1	0.968	52.28	50.9	50.3	0.974	80	62
80	63	45.97	51.1	50.5	0.897	50.44	51.3	50.8	0.904	54.80	51.6	51.0	0.910	80	63
80	64	48.91	51.5	51.0	0.833	53.54	51.8	51.2	0.840	58.06	52.0	51.5	0.847	80	64
80	65	52.31	51.7	51.3	0.772	57.18	52.1	51.6	0.779	61.91	52.4	51.9	0.785	80	65
80	66	56.09	51.9	51.5	0.717	61.25	52.3	51.8	0.723	66.24	52.6	52.2	0.728	80	66
80	67	60.18	52.0	51.6	0.666	65.68	52.4	52.0	0.671	70.99	52.8	52.4	0.676	80	67
80	68	64.54	52.1	51.8	0.621	70.44	52.5	52.2	0.625	76.13	52.9	52.5	0.628	80	68
80	69	69.01	52.1	51.9	0.580	75.35	52.6	52.3	0.583	81.47	53.0	52.7	0.586	80	69
80	70	73.57	52.2	52.0	0.543	80.36	52.7	52.4	0.546	86.92	53.1	52.9	0.548	80	70
80	71	78.23	52.3	52.1	0.511	85.48	52.8	52.6	0.512	92.49	53.2	53.0	0.514	80	71
80	72	82.99	52.4	52.2	0.481	90.72	52.9	52.7	0.482	98.18	53.3	53.2	0.483	80	72
80	73	87.86	52.4	52.4	0.453	96.06	53.0	52.9	0.454	104.0	53.4	53.4	0.454	80	73
80	74	92.83	52.5	52.5	0.429	101.5	53.1	53.0	0.428	109.9	53.6	53.5	0.429	80	74
80	75	97.91	52.7	52.7	0.405	107.1	53.2	53.2	0.404	116.0	53.7	53.7	0.404	80	75
80	76	103.1	52.8	52.8	0.383	112.8	53.4	53.4	0.382	122.2	53.9	53.9	0.381	80	76
80	77	108.4	53.0	53.0	0.362	118.6	53.6	53.6	0.361	128.6	54.1	54.1	0.360	80	77
85	63	48.58	50.9	49.7	1.000	53.76	51.1	49.8	1.000	58.87	51.4	49.9	1.000	85	63
85	64	51.15	50.9	50.2	0.950	56.27	51.1	50.4	0.956	61.30	51.4	50.6	0.962	85	64
85	65	53.82	51.4	50.7	0.891	59.07	51.7	51.0	0.898	64.20	51.9	51.2	0.904	85	65
85	66	57.03	51.7	51.1	0.833	62.47	52.1	51.4	0.840	67.77	52.4	51.7	0.846	85	66
85	67	60.65	52.0	51.4	0.778	66.35	52.4	51.8	0.785	71.88	52.7	52.1	0.791	85	67
85	68	64.61	52.2	51.7	0.728	70.62	52.6	52.0	0.733	76.44	53.0	52.4	0.739	85	68
85	69	68.86	52.3	51.8	0.681	75.22	52.7	52.3	0.686	81.38	53.2	52.6	0.691	85	69
85	70	73.37	52.4	52.0	0.638	80.14	52.9	52.4	0.642	86.68	53.3	52.8	0.647	85	70
85	71	78.03	52.5	52.1	0.600	85.26	52.9	52.6	0.603	92.25	53.4	53.0	0.606	85	71
85	72	82.78	52.5	52.2	0.565	90.49	53.0	52.7	0.567	97.93	53.5	53.2	0.570	85	72
85	73	87.64	52.6	52.4	0.533	95.82	53.1	52.9	0.535	103.7	53.6	53.3	0.537	85	73
85	74	92.61	52.7	52.5	0.504	101.3	53.2	53.0	0.505	109.7	53.7	53.5	0.507	85	74
85	75	97.68	52.8	52.6	0.477	106.9	53.3	53.2	0.478	115.7	53.9	53.7	0.479	85	75
85	76	102.9	52.9	52.8	0.453	112.6	53.5	53.4	0.453	121.9	54.0	53.9	0.453	85	76
85	77	108.2	53.0	53.0	0.430	118.4	53.6	53.5	0.430	128.3	54.1	54.1	0.430	85	77
85	78	113.6	53.1	53.1	0.408	124.4	53.7	53.7	0.408	134.8	54.3	54.3	0.408	85	78
85	79	119.2	53.3	53.3	0.387	130.5	53.9	53.9	0.387	141.4	54.5	54.5	0.386	85	79
85	80	124.8	53.5	53.5	0.368	136.7	54.1	54.1	0.368	148.2	54.7	54.7	0.367	85	80
85	81	130.7	53.7	53.7	0.351	143.1	54.3	54.3	0.349	155.1	55.0	55.0	0.348	85	81
85	82	136.6	53.9	53.9	0.334	149.6	54.5	54.5	0.332	162.2	55.2	55.2	0.331	85	82

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 65
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	AIRFLOW								AIR TEMP. (F)				
			1300 CFM (FPM = 433)				1450 CFM (FPM = 483)				1600 CFM (FPM = 533)				
MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR				
90	65	56.57	50.6	49.8	0.990	61.28	51.4	50.3	1.000	67.14	51.7	50.4	1.000	90	65
90	66	58.92	51.3	50.5	0.937	64.82	51.5	50.7	0.943	70.60	51.8	51.0	0.949	90	66
90	67	61.93	51.7	51.0	0.882	67.98	52.0	51.3	0.889	73.89	52.3	51.5	0.895	90	67
90	68	65.41	52.0	51.4	0.829	71.68	52.4	51.7	0.836	77.80	52.8	52.0	0.842	90	68
90	69	69.27	52.3	51.6	0.779	75.82	52.7	52.0	0.785	82.20	53.1	52.4	0.791	90	69
90	70	73.44	52.5	51.9	0.732	80.32	52.9	52.3	0.738	87.00	53.3	52.7	0.743	90	70
90	71	77.88	52.6	52.1	0.689	85.14	53.1	52.5	0.694	92.17	53.5	52.9	0.699	90	71
90	72	82.57	52.7	52.2	0.649	90.26	53.2	52.7	0.653	97.68	53.7	53.1	0.658	90	72
90	73	87.43	52.8	52.3	0.613	95.59	53.3	52.8	0.616	103.5	53.8	53.3	0.620	90	73
90	74	92.39	52.9	52.5	0.579	101.0	53.4	53.0	0.582	109.4	53.9	53.5	0.585	90	74
90	75	97.46	53.0	52.6	0.549	106.6	53.5	53.2	0.551	115.5	54.0	53.7	0.553	90	75
90	76	102.6	53.0	52.8	0.521	112.3	53.6	53.3	0.522	121.7	54.2	53.9	0.524	90	76
90	77	107.9	53.1	52.9	0.495	118.1	53.7	53.5	0.496	128.0	54.3	54.1	0.497	90	77
90	78	113.4	53.2	53.1	0.470	124.1	53.9	53.7	0.471	134.5	54.5	54.3	0.472	90	78
90	79	118.9	53.4	53.3	0.448	130.2	54.0	53.9	0.448	141.1	54.6	54.5	0.449	90	79
90	80	124.6	53.5	53.5	0.427	136.4	54.1	54.1	0.427	147.9	54.8	54.7	0.427	90	80
90	81	130.4	53.6	53.6	0.407	142.8	54.3	54.3	0.407	154.8	54.9	54.9	0.407	90	81
90	82	136.3	53.8	53.8	0.388	149.3	54.5	54.5	0.387	161.9	55.2	55.2	0.387	90	82
90	83	142.4	54.0	54.0	0.370	156.0	54.7	54.7	0.369	169.2	55.4	55.4	0.368	90	83
90	84	148.7	54.2	54.2	0.353	162.9	55.0	55.0	0.352	176.7	55.7	55.7	0.351	90	84
90	85	155.0	54.4	54.4	0.337	169.9	55.2	55.2	0.336	184.3	55.9	55.9	0.335	90	85
90	86	161.6	54.6	54.6	0.322	177.1	55.4	55.4	0.321	192.1	56.2	56.2	0.319	90	86
90	87	168.3	54.9	54.9	0.308	184.4	55.7	55.7	0.306	200.0	56.4	56.4	0.305	90	87
95	67	64.23	51.1	50.2	0.973	70.80	51.4	50.4	0.979	77.27	51.6	50.7	0.984	95	67
95	68	67.00	51.7	50.8	0.922	73.68	52.0	51.1	0.929	80.23	52.3	51.3	0.935	95	68
95	69	70.34	52.1	51.2	0.872	77.21	52.4	51.6	0.878	83.93	52.8	51.9	0.884	95	69
95	70	74.11	52.4	51.6	0.823	81.24	52.8	52.0	0.829	88.18	53.2	52.3	0.835	95	70
95	71	78.22	52.6	51.9	0.776	85.65	53.1	52.3	0.782	92.89	53.5	52.7	0.788	95	71
95	72	82.62	52.8	52.1	0.733	90.41	53.3	52.6	0.738	97.97	53.7	53.0	0.744	95	72
95	73	87.26	52.9	52.3	0.692	95.45	53.5	52.8	0.697	103.4	53.9	53.3	0.702	95	73
95	74	92.17	53.0	52.5	0.655	100.8	53.6	53.0	0.659	109.2	54.1	53.5	0.663	95	74
95	75	97.24	53.1	52.6	0.621	106.4	53.7	53.2	0.624	115.2	54.2	53.7	0.628	95	75
95	76	102.4	53.2	52.8	0.589	112.1	53.8	53.3	0.592	121.4	54.4	53.8	0.595	95	76
95	77	107.7	53.3	52.9	0.559	117.9	53.9	53.5	0.562	127.7	54.5	54.0	0.564	95	77
95	78	113.1	53.4	53.1	0.532	123.8	54.0	54.7	0.534	134.2	54.6	54.2	0.536	95	78
95	79	118.7	53.5	53.3	0.507	129.9	54.2	53.9	0.508	140.8	54.8	54.5	0.510	95	79
95	80	124.3	53.6	53.4	0.483	136.2	54.3	54.1	0.484	147.6	54.9	54.7	0.485	95	80
95	81	130.2	53.7	53.6	0.461	142.5	54.4	54.3	0.462	154.5	55.1	54.9	0.463	95	81
95	82	136.1	53.9	53.8	0.441	149.1	54.6	54.5	0.441	161.6	55.3	55.1	0.441	95	82
95	83	142.2	54.0	54.0	0.421	155.8	54.7	54.7	0.421	168.9	55.4	55.4	0.421	95	83
95	84	148.4	54.2	54.2	0.402	162.6	54.9	54.9	0.402	176.3	55.6	55.6	0.402	95	84
95	85	154.8	54.4	54.4	0.385	169.6	55.2	55.2	0.384	184.0	55.9	55.9	0.384	95	85
95	86	161.3	54.6	54.6	0.368	176.8	55.4	55.4	0.367	191.7	56.1	56.1	0.367	95	86
95	87	168.0	54.8	54.8	0.352	184.1	55.7	55.7	0.351	199.7	56.4	56.4	0.350	95	87
95	88	174.8	55.1	55.1	0.337	191.6	55.9	55.9	0.336	207.9	56.7	56.7	0.335	95	88
95	89	181.8	55.3	55.3	0.323	199.3	56.2	56.2	0.321	216.3	57.0	57.0	0.320	95	89
95	90	189.0	55.6	55.6	0.309	207.2	56.4	56.4	0.308	224.8	57.3	57.3	0.306	95	90
95	91	196.4	55.8	55.8	0.296	215.3	56.7	56.7	0.295	233.6	57.6	57.6	0.293	95	91
95	92	203.9	56.1	56.1	0.284	223.6	57.0	57.0	0.282	242.6	57.9	57.9	0.280	95	92

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART Coil Size: DW 65
Entering Water = 45 Leaving Water = 51.67

AIR TEMP (°F) EDB	AIRFLOW 1750 CFM (FPM = 583) MBH	AIR TEMP (°F) EDB			
		EWB	LDB	LWB	EWB
75	59	45 87	51 0	49 2	1 000
75	60	46 95	50 7	50 2	0 990
75	61	49 16	51 4	50 9	0 920
75	62	52 24	51 9	51 5	0 848
75	63	56 03	52 3	51 9	0 778
75	64	60 42	52 6	52 2	0 714
75	65	65 32	52 8	52 4	0 656
75	66	70 69	52 9	52 6	0 604
75	67	76 23	53 0	52 8	0 558
75	68	81 88	53 1	52 9	0 518
75	69	87 64	53 2	53 1	0 482
75	70	93 53	53 3	53 3	0 450
75	71	99 54	53 4	53 4	0 421
75	72	105 7	53 6	53 6	0 394
80	61	54 91	51 3	49 6	1 000
80	62	56 50	51 1	50 5	0 980
80	63	59 08	51 8	51 2	0 917
80	64	62 47	52 3	51 7	0 853
80	65	66 51	52 7	52 1	0 791
80	66	71 09	52 9	52 5	0 734
80	67	76 13	53 1	52 7	0 681
80	68	81 63	53 3	52 9	0 632
80	69	87 39	53 4	53 1	0 589
80	70	93 27	53 5	53 2	0 550
80	71	99 27	53 6	53 4	0 515
80	72	105 4	53 8	53 6	0 484
80	73	111 7	53 9	53 8	0 455
80	74	118 1	54 0	54 0	0 429
80	75	124 6	54 2	54 2	0 404
80	76	131 3	54 4	54 4	0 381
80	77	138 2	54 6	54 6	0 360
85	63	63 93	51 6	50 0	1 000
85	64	66 25	51 6	50 8	0 968
85	65	69 23	52 2	51 5	0 910
85	66	72 96	52 7	52 0	0 853
85	67	77 28	53 0	52 4	0 797
85	68	82 10	53 3	52 7	0 744
85	69	87 35	53 5	53 0	0 695
85	70	93 01	53 7	53 2	0 651
85	71	99 01	53 8	53 4	0 610
85	72	105 1	53 9	53 6	0 573
85	73	111 4	54 1	53 8	0 539
85	74	117 8	54 2	54 0	0 508
85	75	124 3	54 4	54 2	0 480
85	76	131 0	54 5	54 4	0 454
85	77	137 9	54 7	54 6	0 430
85	78	144 9	54 8	54 8	0 408
85	79	152 0	55 1	55 1	0 386
85	80	159 3	55 3	55 3	0 366
85	81	166 8	55 5	55 5	0 347
85	82	174 5	55 8	55 8	0 330

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART Coil Size: DW 65
 Entering Water = 45 Leaving Water = 51.67

AIR TEMP. (F)		AIRFLOW 1750 CFM (FPM = 583)				AIR TEMP. (F)	
EDB	EWB	MBH	LDB	LWB	SHR	EDB	EWB
90	65	72.93	51.9	50.6	1.000	90	65
90	66	76.28	52.0	51.2	0.955	90	66
90	67	79.69	52.6	51.8	0.901	90	67
90	68	83.77	53.1	52.3	0.848	90	68
90	69	88.40	53.4	52.7	0.797	90	69
90	70	93.50	53.7	53.0	0.749	90	70
90	71	98.99	53.9	53.3	0.704	90	71
90	72	104.9	54.1	53.6	0.662	90	72
90	73	111.1	54.3	53.8	0.623	90	73
90	74	117.5	54.4	53.9	0.588	90	74
90	75	124.1	54.5	54.2	0.555	90	75
90	76	130.7	54.7	54.4	0.526	90	76
90	77	137.6	54.8	54.6	0.498	90	77
90	78	144.6	55.0	54.8	0.473	90	78
90	79	151.7	55.2	55.0	0.449	90	79
90	80	159.0	55.3	55.3	0.427	90	80
90	81	166.5	55.5	55.5	0.407	90	81
90	82	174.2	55.8	55.8	0.387	90	82
90	83	182.0	56.0	56.0	0.368	90	83
90	84	190.0	56.3	56.3	0.350	90	84
90	85	198.2	56.6	56.6	0.334	90	85
90	86	206.6	56.9	56.9	0.318	90	86
90	87	215.2	57.2	57.2	0.303	90	87
95	67	83.65	51.8	50.8	0.989	95	67
95	68	86.67	52.5	51.6	0.940	95	68
95	69	90.51	53.1	52.2	0.890	95	69
95	70	94.97	53.5	52.6	0.841	95	70
95	71	99.94	53.9	53.0	0.794	95	71
95	72	105.3	54.2	53.4	0.749	95	72
95	73	111.1	54.4	53.7	0.707	95	73
95	74	117.2	54.6	53.9	0.668	95	74
95	75	123.8	54.7	54.1	0.631	95	75
95	76	130.5	54.9	54.3	0.598	95	76
95	77	137.3	55.0	54.6	0.567	95	77
95	78	144.3	55.2	54.8	0.538	95	78
95	79	151.4	55.4	55.0	0.511	95	79
95	80	158.7	55.5	55.2	0.486	95	80
95	81	166.2	55.7	55.5	0.463	95	81
95	82	173.8	55.9	55.7	0.442	95	82
95	83	181.7	56.1	56.0	0.421	95	83
95	84	189.7	56.3	56.3	0.402	95	84
95	85	197.9	56.5	56.5	0.384	95	85
95	86	206.3	56.8	56.8	0.366	95	86
95	87	214.9	57.1	57.1	0.349	95	87
95	88	223.7	57.4	57.4	0.334	95	88
95	89	232.7	57.7	57.7	0.319	95	89
95	90	241.9	58.0	58.0	0.305	95	90
95	91	251.4	58.4	58.4	0.291	95	91
95	92	261.1	58.7	58.7	0.279	95	92

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART Coil Size: DW 65
 Entering Water = 45 Leaving Water = 51.67

AIR TEMP (°F) EDB	EWB	AIRFLOW 1750 CFM (FPM = 583)			SHR	AIR TEMP (°F) EDB	EWB
		MBH	LDB	LWB			
100	69	93.91	52.4	51.3	0.972	100	69
100	70	97.47	53.1	52.0	0.925	100	70
100	71	101.8	53.6	52.6	0.878	100	71
100	72	106.6	54.0	53.0	0.831	100	72
100	73	111.9	54.3	53.4	0.787	100	73
100	74	117.6	54.6	53.8	0.746	100	74
100	75	123.7	54.9	54.1	0.706	100	75
100	76	130.2	55.1	54.3	0.669	100	76
100	77	137.0	55.2	54.5	0.635	100	77
100	78	144.0	55.4	54.7	0.603	100	78
100	79	151.1	55.5	55.0	0.573	100	79
100	80	158.4	55.7	55.2	0.546	100	80
100	81	165.9	55.9	55.5	0.520	100	81
100	82	173.5	56.1	55.7	0.496	100	82
100	83	181.3	56.3	56.0	0.473	100	83
100	84	189.4	56.4	56.2	0.452	100	84
100	85	197.6	56.6	56.5	0.432	100	85
100	86	206.0	56.9	56.8	0.414	100	86
100	87	214.5	57.1	57.1	0.396	100	87
100	88	223.3	57.4	57.4	0.378	100	88
100	89	232.4	57.7	57.7	0.362	100	89
100	90	241.6	58.0	58.0	0.346	100	90
100	91	251.0	58.3	58.3	0.331	100	91
100	92	260.7	58.7	58.7	0.317	100	92
100	93	270.6	59.0	59.0	0.304	100	93
100	94	280.8	59.4	59.4	0.291	100	94
100	95	291.2	59.7	59.7	0.278	100	95
100	96	301.8	60.1	60.1	0.267	100	96
100	97	312.8	60.5	60.5	0.256	100	97
105	71	104.7	53.1	51.9	0.953	105	71
105	72	108.7	53.6	52.5	0.908	105	72
105	73	113.5	54.1	53.0	0.864	105	73
105	74	118.7	54.5	53.4	0.820	105	74
105	75	124.4	54.8	53.8	0.779	105	75
105	76	130.5	55.1	54.2	0.740	105	76
105	77	136.8	55.4	54.5	0.703	105	77
105	78	143.7	55.5	54.7	0.668	105	78
105	79	150.8	55.7	55.0	0.635	105	79
105	80	158.1	55.9	55.2	0.605	105	80
105	81	165.6	56.1	55.4	0.577	105	81
105	82	173.2	56.2	55.7	0.550	105	82
105	83	181.0	56.4	55.9	0.525	105	83
105	84	189.0	56.6	56.2	0.502	105	84
105	85	197.2	56.8	56.5	0.480	105	85
105	86	205.6	57.0	56.8	0.459	105	86
105	87	214.2	57.3	57.0	0.440	105	87
105	88	223.0	57.5	57.3	0.422	105	88
105	89	232.0	57.7	57.7	0.404	105	89
105	90	241.2	58.0	58.0	0.387	105	90
105	91	250.7	58.3	58.3	0.371	105	91
105	92	260.3	58.6	58.6	0.355	105	92
105	93	270.3	59.0	59.0	0.341	105	93
105	94	280.4	59.3	59.3	0.327	105	94
105	95	290.8	59.7	59.7	0.313	105	95
105	96	301.5	60.1	60.1	0.300	105	96
105	97	312.4	60.5	60.5	0.288	105	97
105	98	323.5	60.9	60.9	0.276	105	98
105	99	335.0	61.3	61.3	0.265	105	99
105	100	346.7	61.7	61.7	0.254	105	100
105	101	358.8	62.1	62.1	0.244	105	101
105	102	371.1	62.6	62.6	0.234	105	102

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 66
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	1300 CFM (FPM = 260)				1500 CFM (FPM = 300)				1700 CFM (FPM = 340)				AIR TEMP (F)	
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
75	59	37.45	48.7	48.1	1.000	42.90	48.9	48.2	1.000	48.29	49.0	48.3	1.000	75	59	
75	60	40.38	48.8	48.5	0.924	45.95	49.0	48.6	0.931	51.42	49.1	48.8	0.936	75	60	
75	61	43.37	49.1	48.8	0.852	49.23	49.3	49.0	0.858	54.97	49.5	49.2	0.864	75	61	
75	62	46.91	49.3	49.0	0.783	53.17	49.5	49.3	0.789	59.27	49.8	49.5	0.794	75	62	
75	63	50.85	49.3	49.1	0.722	57.59	49.6	49.4	0.727	64.15	49.9	49.6	0.731	75	63	
75	64	55.10	49.3	49.1	0.667	62.38	49.6	49.4	0.671	69.46	49.9	49.7	0.675	75	64	
75	65	59.52	49.3	49.1	0.619	67.45	49.6	49.5	0.622	75.11	49.9	49.8	0.625	75	65	
75	66	64.04	49.3	49.1	0.577	72.61	49.6	49.5	0.579	80.91	49.9	49.8	0.581	75	66	
75	67	68.64	49.2	49.1	0.539	77.87	49.6	49.5	0.540	86.82	49.9	49.8	0.542	75	67	
75	68	73.33	49.2	49.2	0.506	83.23	49.6	49.5	0.506	92.83	50.0	49.9	0.507	75	68	
75	69	78.11	49.2	49.2	0.476	88.70	49.6	49.6	0.476	98.97	50.0	49.9	0.476	75	69	
75	70	82.99	49.2	49.2	0.448	94.28	49.6	49.6	0.448	105.2	50.0	50.0	0.448	75	70	
75	71	87.97	49.2	49.2	0.423	99.97	49.7	49.7	0.422	111.6	50.0	50.0	0.422	75	71	
75	72	93.05	49.3	49.3	0.400	105.8	49.7	49.7	0.399	118.2	50.1	50.1	0.398	75	72	
80	61	45.63	48.4	48.0	0.984	52.12	48.6	48.2	0.989	57.39	49.2	48.6	1.000	80	61	
80	62	48.26	48.9	48.5	0.919	54.96	49.1	48.7	0.924	61.54	49.3	48.9	0.930	80	62	
80	63	51.57	49.1	48.8	0.853	58.61	49.4	49.0	0.859	65.49	49.6	49.3	0.865	80	63	
80	64	55.35	49.3	49.0	0.792	62.82	49.6	49.3	0.798	70.11	49.8	49.5	0.803	80	64	
80	65	59.47	49.3	49.1	0.737	67.45	49.7	49.4	0.742	75.23	50.0	49.7	0.746	80	65	
80	66	63.86	49.4	49.1	0.687	72.41	49.7	49.5	0.691	80.73	50.0	49.8	0.695	80	66	
80	67	68.43	49.3	49.1	0.642	77.63	49.7	49.5	0.645	86.55	50.1	49.8	0.648	80	67	
80	68	73.12	49.3	49.1	0.602	82.99	49.7	49.5	0.604	92.56	50.1	49.9	0.607	80	68	
80	69	77.89	49.3	49.2	0.566	88.45	49.7	49.6	0.568	98.69	50.1	49.9	0.570	80	69	
80	70	82.76	49.3	49.2	0.534	94.02	49.7	49.6	0.535	104.9	50.1	50.0	0.536	80	70	
80	71	87.74	49.3	49.2	0.504	99.71	49.7	49.6	0.505	111.3	50.1	50.0	0.506	80	71	
80	72	92.81	49.3	49.3	0.477	105.5	49.7	49.7	0.478	117.9	50.2	50.1	0.478	80	72	
80	73	98.00	49.3	49.3	0.453	111.4	49.8	49.8	0.453	124.5	50.2	50.2	0.453	80	73	
80	74	103.3	49.4	49.4	0.429	117.5	49.8	49.8	0.429	131.3	50.2	50.2	0.429	80	74	
80	75	108.7	49.4	49.4	0.408	123.7	49.9	49.9	0.407	138.3	50.3	50.3	0.407	80	75	
80	76	114.3	49.5	49.5	0.388	130.0	50.0	50.0	0.387	145.4	50.4	50.4	0.386	80	76	
80	77	119.9	49.5	49.5	0.370	136.5	50.0	50.0	0.368	152.7	50.5	50.5	0.367	80	77	
85	63	53.34	48.6	48.2	0.970	60.92	48.8	48.3	0.975	68.39	49.0	48.5	0.980	85	63	
85	64	56.39	49.0	48.6	0.910	64.23	49.2	48.8	0.915	71.94	49.5	49.0	0.920	85	64	
85	65	60.01	49.2	48.8	0.850	68.25	49.5	49.1	0.856	76.31	49.8	49.3	0.861	85	65	
85	66	64.04	49.3	49.0	0.795	72.75	49.7	49.3	0.800	81.26	50.0	49.6	0.805	85	66	
85	67	68.37	49.4	49.1	0.745	77.62	49.8	49.4	0.749	86.65	50.1	49.7	0.754	85	67	
85	68	72.91	49.4	49.1	0.699	82.79	49.8	49.5	0.702	92.39	50.2	49.8	0.706	85	68	
85	69	77.67	49.4	49.2	0.657	88.20	49.8	49.5	0.660	98.42	50.2	49.9	0.663	85	69	
85	70	82.54	49.4	49.2	0.619	93.76	49.8	49.6	0.622	104.7	50.2	50.0	0.624	85	70	
85	71	87.51	49.4	49.2	0.585	99.45	49.8	49.6	0.587	111.0	50.2	50.0	0.589	85	71	
85	72	92.58	49.4	49.3	0.554	105.2	49.9	49.7	0.555	117.6	50.3	50.1	0.556	85	72	
85	73	97.76	49.4	49.3	0.525	111.2	49.9	49.7	0.526	124.2	50.3	50.2	0.527	85	73	
85	74	103.1	49.4	49.3	0.499	117.2	49.9	49.8	0.499	131.0	50.3	50.2	0.500	85	74	
85	75	108.5	49.4	49.4	0.474	123.4	49.9	49.9	0.475	138.0	50.4	50.3	0.475	85	75	
85	76	114.0	49.5	49.5	0.452	129.8	49.9	49.9	0.452	145.1	50.4	50.4	0.452	85	76	
85	77	119.7	49.5	49.5	0.430	136.2	50.0	50.0	0.430	152.3	50.5	50.5	0.430	85	77	
85	78	125.5	49.6	49.6	0.410	142.8	50.1	50.1	0.410	159.8	50.6	50.6	0.410	85	78	
85	79	131.4	49.6	49.6	0.392	149.6	50.2	50.2	0.391	167.4	50.7	50.7	0.390	85	79	
85	80	137.4	49.7	49.7	0.374	156.6	50.3	50.3	0.374	175.2	50.8	50.8	0.373	85	80	
85	81	143.7	49.8	49.8	0.358	163.7	50.4	50.4	0.357	183.1	50.9	50.9	0.356	85	81	
85	82	150.0	49.9	49.9	0.343	170.9	50.5	50.5	0.341	191.3	51.0	51.0	0.340	85	82	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 66
Leaving Water = 51.67

AIR TEMP. (F)		1300 CFM (FPM = 260)				1500 CFM (FPM = 300)				1700 CFM (FPM = 340)				AIR TEMP. (F)	
EDB	EWB	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
90	65	61.37	48.8	48.3	0.955	70.06	49.1	48.5	0.960	78.63	49.3	48.7	0.965	90	65
90	66	64.82	49.1	48.7	0.899	73.85	49.4	48.9	0.904	82.72	49.7	49.2	0.909	90	66
90	67	68.76	49.3	48.9	0.844	78.23	49.6	49.2	0.850	87.51	49.9	49.5	0.855	90	67
90	68	73.04	49.4	49.0	0.794	83.03	49.8	49.4	0.799	92.80	50.1	49.7	0.803	90	68
90	69	77.59	49.5	49.1	0.747	88.16	49.9	49.5	0.752	98.48	50.2	49.8	0.756	90	69
90	70	82.32	49.5	49.2	0.705	93.56	49.9	49.6	0.708	104.5	50.3	49.9	0.712	90	70
90	71	87.28	49.5	49.2	0.666	99.18	49.9	49.6	0.669	110.8	50.4	50.0	0.672	90	71
90	72	92.34	49.5	49.2	0.630	105.0	50.0	49.7	0.632	117.3	50.4	50.1	0.635	90	72
90	73	97.52	49.5	49.3	0.597	110.9	50.0	49.7	0.599	123.9	50.4	50.1	0.601	90	73
90	74	102.8	49.5	49.3	0.567	117.0	50.0	49.8	0.569	130.7	50.4	50.2	0.570	90	74
90	75	108.2	49.5	49.4	0.540	123.1	50.0	49.9	0.541	137.6	50.5	50.3	0.542	90	75
90	76	113.7	49.6	49.4	0.514	129.5	50.1	49.9	0.515	144.8	50.5	50.4	0.516	90	76
90	77	119.4	49.6	49.5	0.490	135.9	50.1	50.0	0.491	152.0	50.6	50.5	0.491	90	77
90	78	125.2	49.6	49.6	0.468	142.5	50.1	50.1	0.468	159.4	50.6	50.6	0.469	90	78
90	79	131.1	49.6	49.6	0.447	149.3	50.2	50.2	0.447	167.0	50.7	50.7	0.447	90	79
90	80	137.2	49.7	49.7	0.428	156.2	50.2	50.2	0.427	174.8	50.8	50.8	0.427	90	80
90	81	143.4	49.8	49.8	0.409	163.3	50.3	50.3	0.409	182.8	50.9	50.9	0.408	90	81
90	82	149.7	49.9	49.9	0.392	170.6	50.4	50.4	0.391	190.9	51.0	51.0	0.390	90	82
90	83	156.2	49.9	49.9	0.375	178.0	50.5	50.5	0.374	199.3	51.1	51.1	0.374	90	83
90	84	162.9	50.0	50.0	0.360	185.6	50.6	50.6	0.359	207.8	51.2	51.2	0.358	90	84
90	85	169.7	50.1	50.1	0.345	193.4	50.8	50.8	0.344	216.6	51.4	51.4	0.343	90	85
90	86	176.7	50.2	50.2	0.331	201.4	50.9	50.9	0.330	225.5	51.5	51.5	0.329	90	86
90	87	183.8	50.3	50.3	0.318	209.6	51.0	51.0	0.317	234.7	51.6	51.6	0.315	90	87
95	67	69.75	49.0	48.5	0.938	79.63	49.3	48.7	0.943	89.34	49.5	48.9	0.948	95	67
95	68	73.60	49.3	48.8	0.886	83.86	49.6	49.1	0.891	93.93	49.9	49.3	0.896	95	68
95	69	77.84	49.4	48.9	0.836	88.60	49.8	49.3	0.841	99.13	50.1	49.6	0.846	95	69
95	70	82.38	49.5	49.1	0.789	93.71	49.9	49.4	0.794	104.8	50.3	49.8	0.798	95	70
95	71	87.14	49.6	49.2	0.746	99.11	50.0	49.6	0.750	110.8	50.4	49.9	0.754	95	71
95	72	92.12	49.6	49.2	0.706	104.8	50.1	49.6	0.710	117.1	50.5	50.0	0.713	95	72
95	73	97.28	49.6	49.3	0.670	110.6	50.1	49.7	0.673	123.6	50.5	50.1	0.676	95	73
95	74	102.6	49.6	49.3	0.636	116.7	50.1	49.8	0.639	130.4	50.6	50.2	0.641	95	74
95	75	108.0	49.7	49.4	0.605	122.9	50.1	49.8	0.607	137.3	50.6	50.3	0.609	95	75
95	76	113.5	49.7	49.4	0.576	129.2	50.2	49.9	0.578	144.4	50.6	50.4	0.580	95	76
95	77	119.1	49.7	49.5	0.550	135.6	50.2	50.0	0.551	151.7	50.7	50.5	0.552	95	77
95	78	124.9	49.7	49.6	0.525	142.2	50.2	50.1	0.526	159.1	50.7	50.5	0.527	95	78
95	79	130.8	49.7	49.6	0.502	149.0	50.3	50.1	0.502	166.7	50.8	50.6	0.503	95	79
95	80	136.9	49.8	49.7	0.480	155.9	50.3	50.2	0.481	174.5	50.8	50.8	0.481	95	80
95	81	143.1	49.8	49.8	0.460	163.0	50.3	50.3	0.460	182.4	50.9	50.9	0.460	95	81
95	82	149.4	49.8	49.8	0.441	170.3	50.4	50.4	0.441	190.6	51.0	51.0	0.441	95	82
95	83	155.9	49.9	49.9	0.422	177.7	50.5	50.5	0.422	198.9	51.1	51.1	0.422	95	83
95	84	162.6	50.0	50.0	0.405	185.3	50.6	50.6	0.404	207.4	51.2	51.2	0.404	95	84
95	85	169.4	50.1	50.1	0.389	193.1	50.7	50.7	0.388	216.2	51.3	51.3	0.387	95	85
95	86	176.4	50.2	50.2	0.373	201.0	50.9	50.9	0.372	225.1	51.5	51.5	0.371	95	86
95	87	183.5	50.3	50.3	0.359	209.2	51.0	51.0	0.358	234.3	51.6	51.6	0.357	95	87
95	88	190.8	50.4	50.4	0.345	217.6	51.1	51.1	0.343	243.7	51.8	51.8	0.342	95	88
95	89	198.3	50.5	50.5	0.332	226.2	51.2	51.2	0.330	253.3	51.9	51.9	0.329	95	89
95	90	206.0	50.6	50.6	0.319	235.0	51.4	51.4	0.318	263.2	52.1	52.1	0.316	95	90
95	91	213.9	50.8	50.8	0.307	244.0	51.5	51.5	0.305	273.3	52.2	52.2	0.304	95	91
95	92	222.0	50.9	50.9	0.296	253.2	51.7	51.7	0.294	283.6	52.4	52.4	0.292	95	92

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 66
Leaving Water = 51.67

AIR TEMP. (F)		AIRFLOW								AIR TEMP. (F)					
EDB	EWB	1900 CFM (FPM = 380)				2100 CFM (FPM = 420)				2300 CFM (FPM = 460)					
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR		
75	59	53.62	49.2	48.4	1.000	58.89	49.4	48.5	1.000	64.11	49.5	48.5	1.000	75	59
75	60	56.81	49.3	48.9	0.942	62.11	49.4	49.1	0.947	67.33	49.6	49.2	0.952	75	60
75	61	60.59	49.7	49.4	0.869	66.11	49.9	49.6	0.874	71.53	50.1	49.7	0.880	75	61
75	62	65.23	50.0	49.7	0.800	71.07	50.2	49.9	0.805	76.78	50.4	50.1	0.809	75	62
75	63	70.54	50.1	49.9	0.736	76.77	50.4	50.1	0.740	82.87	50.6	50.3	0.744	75	63
75	64	76.35	50.2	50.0	0.678	83.06	50.5	50.3	0.682	89.61	50.7	50.5	0.686	75	64
75	65	82.56	50.2	50.1	0.628	89.82	50.5	50.3	0.630	96.89	50.8	50.6	0.633	75	65
75	66	88.98	50.3	50.1	0.583	96.84	50.5	50.4	0.585	104.5	50.8	50.7	0.587	75	66
75	67	95.52	50.3	50.2	0.543	104.0	50.6	50.4	0.545	112.3	50.9	50.7	0.546	75	67
75	68	102.2	50.3	50.2	0.508	111.3	50.6	50.5	0.509	120.2	50.9	50.8	0.510	75	68
75	69	109.0	50.3	50.3	0.477	118.7	50.6	50.6	0.477	128.3	51.0	50.9	0.478	75	69
75	70	115.9	50.3	50.3	0.448	126.3	50.7	50.7	0.448	136.5	51.0	51.0	0.448	75	70
75	71	123.0	50.4	50.4	0.422	134.1	50.8	50.8	0.422	144.9	51.1	51.1	0.421	75	71
75	72	130.2	50.5	50.5	0.398	142.0	50.9	50.9	0.397	153.5	51.2	51.2	0.397	75	72
80	61	63.76	49.3	48.7	1.000	70.07	49.5	48.7	1.000	76.33	49.7	48.8	1.000	80	61
80	62	68.01	49.5	49.1	0.935	74.38	49.6	49.2	0.940	80.67	49.8	49.3	0.944	80	62
80	63	72.25	49.8	49.5	0.870	78.88	50.0	49.7	0.875	85.39	50.2	49.8	0.880	80	63
80	64	77.24	50.1	49.7	0.808	84.22	50.3	50.0	0.813	91.07	50.5	50.2	0.817	80	64
80	65	82.81	50.3	49.9	0.750	90.23	50.5	50.2	0.755	97.48	50.8	50.4	0.759	80	65
80	66	88.84	50.3	50.1	0.698	96.75	50.6	50.3	0.702	104.5	50.9	50.6	0.706	80	66
80	67	95.23	50.4	50.1	0.651	103.7	50.7	50.4	0.654	112.0	51.0	50.7	0.657	80	67
80	68	101.9	50.4	50.2	0.609	111.0	50.7	50.5	0.611	119.8	51.0	50.8	0.614	80	68
80	69	108.7	50.4	50.3	0.571	118.4	50.8	50.6	0.573	127.9	51.1	50.9	0.575	80	69
80	70	115.6	50.5	50.3	0.537	126.0	50.8	50.7	0.539	136.1	51.1	51.0	0.540	80	70
80	71	122.7	50.5	50.4	0.506	133.7	50.9	50.8	0.507	144.6	51.2	51.1	0.508	80	71
80	72	129.9	50.5	50.5	0.478	141.7	50.9	50.8	0.479	153.1	51.3	51.2	0.479	80	72
80	73	137.3	50.6	50.6	0.453	149.7	51.0	50.9	0.453	161.9	51.3	51.3	0.453	80	73
80	74	144.8	50.7	50.7	0.429	158.0	51.0	51.0	0.429	170.9	51.4	51.4	0.429	80	74
80	75	152.5	50.8	50.8	0.406	166.4	51.2	51.2	0.406	180.0	51.5	51.5	0.406	80	75
80	76	160.4	50.9	50.9	0.386	175.1	51.3	51.3	0.385	189.4	51.7	51.7	0.384	80	76
80	77	168.5	51.0	51.0	0.366	183.9	51.4	51.4	0.366	199.0	51.8	51.8	0.365	80	77
85	63	75.77	49.1	48.6	0.984	83.06	49.3	48.8	0.988	90.27	49.4	48.9	0.992	85	63
85	64	79.52	49.7	49.2	0.925	86.99	49.9	49.4	0.930	94.35	50.0	49.5	0.934	85	64
85	65	84.22	50.0	49.6	0.866	91.99	50.2	49.8	0.871	99.63	50.4	50.0	0.876	85	65
85	66	89.59	50.2	49.8	0.810	97.75	50.5	50.1	0.814	105.8	50.7	50.3	0.819	85	66
85	67	95.47	50.4	50.0	0.758	104.1	50.7	50.3	0.762	112.5	50.9	50.5	0.766	85	67
85	68	101.8	50.5	50.2	0.710	110.9	50.8	50.4	0.713	119.9	51.1	50.7	0.717	85	68
85	69	108.4	50.5	50.2	0.666	118.1	50.9	50.6	0.669	127.6	51.2	50.9	0.672	85	69
85	70	115.3	50.6	50.3	0.627	125.7	50.9	50.6	0.629	135.8	51.3	51.0	0.632	85	70
85	71	122.4	50.6	50.4	0.591	133.4	51.0	50.7	0.593	144.2	51.3	51.1	0.595	85	71
85	72	129.6	50.7	50.5	0.558	141.3	51.0	50.8	0.559	152.8	51.4	51.2	0.561	85	72
85	73	136.9	50.7	50.6	0.528	149.4	51.1	50.9	0.529	161.5	51.4	51.3	0.530	85	73
85	74	144.5	50.7	50.6	0.501	157.6	51.1	51.0	0.501	170.5	51.5	51.4	0.502	85	74
85	75	152.2	50.8	50.7	0.475	166.0	51.2	51.1	0.476	179.6	51.6	51.5	0.476	85	75
85	76	160.0	50.9	50.8	0.452	174.7	51.3	51.2	0.452	189.0	51.7	51.6	0.452	85	76
85	77	168.1	50.9	50.9	0.430	183.5	51.4	51.4	0.430	198.5	51.8	51.8	0.430	85	77
85	78	176.3	51.1	51.1	0.409	192.5	51.5	51.5	0.409	208.3	51.9	51.9	0.409	85	78
85	79	184.7	51.2	51.2	0.390	201.7	51.6	51.6	0.389	218.3	52.1	52.1	0.389	85	79
85	80	193.4	51.3	51.3	0.372	211.2	51.8	51.8	0.371	228.6	52.2	52.2	0.370	85	80
85	81	202.2	51.4	51.4	0.355	220.8	51.9	51.9	0.354	239.1	52.4	52.4	0.353	85	81
85	82	211.2	51.5	51.5	0.339	230.7	52.0	52.0	0.338	249.8	52.5	52.5	0.337	85	82

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 66
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	1900 CFM (FPM = 380)				2100 CFM (FPM = 420)				2300 CFM (FPM = 460)				AIR TEMP (F)	
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
90	65	87.09	49.4	48.9	0.969	95.44	49.6	49.0	0.973	103.7	49.8	49.2	0.977	90	65	
90	66	91.44	49.9	49.4	0.914	100.0	50.1	49.6	0.918	108.5	50.3	49.8	0.923	90	66	
90	67	96.61	50.2	49.7	0.859	105.6	50.4	49.9	0.864	114.3	50.7	50.2	0.868	90	67	
90	68	102.4	50.4	49.9	0.808	111.7	50.7	50.2	0.812	120.9	51.0	50.5	0.816	90	68	
90	69	108.6	50.6	50.1	0.760	118.4	50.9	50.4	0.764	128.1	51.2	50.7	0.768	90	69	
90	70	115.2	50.7	50.3	0.716	125.6	51.0	50.6	0.719	135.8	51.3	50.9	0.723	90	70	
90	71	122.1	50.7	50.4	0.675	133.1	51.1	50.7	0.678	143.9	51.4	51.0	0.681	90	71	
90	72	129.2	50.8	50.5	0.638	140.9	51.1	50.8	0.640	152.4	51.5	51.2	0.643	90	72	
90	73	136.6	50.8	50.5	0.603	149.0	51.2	50.9	0.605	161.1	51.6	51.3	0.607	90	73	
90	74	144.1	50.9	50.6	0.572	157.2	51.3	51.0	0.574	170.1	51.6	51.4	0.575	90	74	
90	75	151.8	50.9	50.7	0.543	165.7	51.3	51.1	0.544	179.2	51.7	51.5	0.546	90	75	
90	76	159.7	51.0	50.8	0.517	174.3	51.4	51.2	0.517	188.6	51.8	51.6	0.518	90	76	
90	77	167.7	51.0	50.9	0.492	183.1	51.5	51.3	0.492	198.1	51.9	51.8	0.493	90	77	
90	78	176.0	51.1	51.0	0.469	192.1	51.5	51.5	0.469	207.9	52.0	51.9	0.469	90	78	
90	79	184.4	51.2	51.1	0.447	201.3	51.6	51.6	0.447	217.9	52.1	52.0	0.448	90	79	
90	80	193.0	51.3	51.3	0.427	210.7	51.7	51.7	0.427	228.1	52.2	52.2	0.427	90	80	
90	81	201.8	51.4	51.4	0.408	220.4	51.9	51.9	0.408	238.6	52.3	52.3	0.407	90	81	
90	82	210.8	51.5	51.5	0.390	230.3	52.0	52.0	0.389	249.3	52.5	52.5	0.389	90	82	
90	83	220.1	51.7	51.7	0.373	240.4	52.2	52.2	0.372	260.3	52.7	52.7	0.371	90	83	
90	84	229.5	51.8	51.8	0.357	250.7	52.3	52.3	0.356	271.5	52.8	52.8	0.355	90	84	
90	85	239.2	51.9	51.9	0.342	261.3	52.5	52.5	0.341	283.0	53.0	53.0	0.340	90	85	
90	86	249.1	52.1	52.1	0.327	272.2	52.7	52.7	0.326	294.8	53.2	53.2	0.325	90	86	
90	87	259.3	52.3	52.3	0.314	283.3	52.8	52.8	0.313	306.9	53.4	53.4	0.311	90	87	
95	67	98.91	49.8	49.1	0.952	108.4	50.0	49.3	0.956	117.7	50.1	49.5	0.960	95	67	
95	68	103.8	50.1	49.6	0.900	113.6	50.4	49.8	0.905	123.2	50.6	50.0	0.909	95	68	
95	69	109.5	50.4	49.9	0.850	119.6	50.7	50.1	0.854	129.6	50.9	50.4	0.859	95	69	
95	70	115.6	50.6	50.1	0.803	126.2	50.9	50.4	0.807	136.7	51.2	50.7	0.811	95	70	
95	71	122.2	50.7	50.3	0.758	133.3	51.1	50.6	0.762	144.3	51.4	50.9	0.766	95	71	
95	72	129.1	50.8	50.4	0.717	140.8	51.2	50.7	0.720	152.4	51.5	51.1	0.724	95	72	
95	73	136.3	50.9	50.5	0.679	148.7	51.3	50.9	0.682	160.8	51.7	51.2	0.685	95	73	
95	74	143.8	51.0	50.6	0.644	156.9	51.4	51.0	0.646	169.7	51.8	51.4	0.649	95	74	
95	75	151.5	51.0	50.7	0.611	165.3	51.4	51.1	0.613	178.8	51.8	51.5	0.615	95	75	
95	76	159.3	51.1	50.8	0.581	173.9	51.5	51.2	0.583	188.1	51.9	51.6	0.585	95	76	
95	77	167.4	51.1	50.9	0.554	182.7	51.6	51.3	0.555	197.7	52.0	51.7	0.556	95	77	
95	78	175.6	51.2	51.0	0.528	191.7	51.7	51.5	0.529	207.5	52.1	51.9	0.530	95	78	
95	79	184.0	51.3	51.1	0.504	200.9	51.7	51.6	0.504	217.5	52.2	52.0	0.505	95	79	
95	80	192.6	51.3	51.2	0.481	210.3	51.8	51.7	0.482	227.7	52.3	52.2	0.482	95	80	
95	81	201.4	51.4	51.4	0.460	220.0	51.9	51.9	0.460	238.1	52.4	52.3	0.461	95	81	
95	82	210.4	51.5	51.5	0.441	229.8	52.0	52.0	0.441	248.9	52.5	52.5	0.441	95	82	
95	83	219.6	51.6	51.6	0.422	239.9	52.2	52.2	0.421	259.8	52.6	52.6	0.421	95	83	
95	84	229.1	51.8	51.8	0.404	250.3	52.3	52.3	0.403	271.0	52.8	52.8	0.403	95	84	
95	85	238.8	51.9	51.9	0.387	260.9	52.5	52.5	0.386	282.5	53.0	53.0	0.386	95	85	
95	86	248.7	52.1	52.1	0.371	271.7	52.6	52.6	0.370	294.3	53.2	53.2	0.369	95	86	
95	87	258.8	52.2	52.2	0.356	282.8	52.8	52.8	0.355	306.4	53.4	53.4	0.354	95	87	
95	88	269.2	52.4	52.4	0.341	294.2	53.0	53.0	0.340	318.7	53.6	53.6	0.339	95	88	
95	89	279.9	52.6	52.6	0.328	305.9	53.2	53.2	0.326	331.3	53.8	53.8	0.325	95	89	
95	90	290.8	52.7	52.7	0.315	317.8	53.4	53.4	0.313	344.3	54.0	54.0	0.312	95	90	
95	91	302.0	52.9	52.9	0.302	330.0	53.6	53.6	0.301	357.6	54.2	54.2	0.300	95	91	
95	92	313.4	53.1	53.1	0.291	342.6	53.8	53.8	0.289	371.1	54.5	54.5	0.288	95	92	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 66
Leaving Water = 51.67

AIR TEMP (°F)		AIRFLOW								AIR TEMP (°F)					
EDB	EWB	1900 CFM (FPM = 380)				2100 CFM (FPM = 420)			2300 CFM (FPM = 460)			EDB	EWB		
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR		
100	69	111 3	50 1	49 4	0 935	121 9	50 3	49 6	0 939	132 3	50 5	49 8	0 943	100	69
100	70	116 8	50 4	49 8	0 886	127 7	50 7	50 0	0 890	138 5	50 9	50 3	0 894	100	70
100	71	122 9	50 6	50 0	0 839	134 3	50 9	50 3	0 843	145 5	51 2	50 6	0 847	100	71
100	72	129 4	50 8	50 3	0 795	141 4	51 2	50 6	0 799	153 1	51 5	50 9	0 803	100	72
100	73	136 3	51 0	50 4	0 754	148 9	51 3	50 8	0 757	161 1	51 7	51 1	0 761	100	73
100	74	143 6	51 1	50 6	0 715	156 7	51 4	50 9	0 718	169 6	51 8	51 3	0 722	100	74
100	75	151 1	51 1	50 7	0 679	164 9	51 5	51 1	0 682	178 5	51 9	51 4	0 685	100	75
100	76	159 0	51 2	50 8	0 646	173 5	51 6	51 2	0 649	187 7	52 0	51 6	0 651	100	76
100	77	167 0	51 3	50 9	0 615	182 3	51 7	51 3	0 617	197 3	52 1	51 7	0 619	100	77
100	78	175 2	51 3	51 0	0 587	191 3	51 8	51 4	0 588	207 0	52 2	51 9	0 590	100	78
100	79	183 6	51 4	51 1	0 560	200 5	51 9	51 6	0 561	217 0	52 3	52 0	0 563	100	79
100	80	192 2	51 5	51 2	0 535	209 9	51 9	51 7	0 536	227 2	52 4	52 1	0 537	100	80
100	81	201 0	51 5	51 4	0 512	219 5	52 0	51 8	0 513	237 7	52 5	52 3	0 513	100	81
100	82	210 0	51 6	51 5	0 490	229 4	52 1	52 0	0 490	248 4	52 6	52 5	0 491	100	82
100	83	219 2	51 7	51 6	0 469	239 5	52 2	52 1	0 470	259 3	52 7	52 6	0 470	100	83
100	84	228 7	51 8	51 8	0 450	249 8	52 3	52 3	0 450	270 6	52 9	52 8	0 450	100	84
100	85	238 3	51 9	51 9	0 432	260 4	52 4	52 4	0 432	282 0	53 0	53 0	0 432	100	85
100	86	248 2	52 1	52 1	0 414	271 3	52 6	52 6	0 414	293 8	53 2	53 2	0 414	100	86
100	87	258 4	52 2	52 2	0 397	282 4	52 8	52 8	0 397	305 8	53 4	53 4	0 397	100	87
100	88	268 8	52 4	52 4	0 381	293 7	53 0	53 0	0 381	318 2	53 5	53 5	0 380	100	88
100	89	279 4	52 5	52 5	0 366	305 4	53 2	53 2	0 366	330 8	53 8	53 8	0 365	100	89
100	90	290 3	52 7	52 7	0 352	317 3	53 4	53 4	0 351	343 7	54 0	54 0	0 350	100	90
100	91	301 5	52 9	52 9	0 338	329 5	53 6	53 6	0 337	357 0	54 2	54 2	0 336	100	91
100	92	312 9	53 1	53 1	0 325	342 1	53 8	53 8	0 324	370 6	54 4	54 4	0 323	100	92
100	93	324 7	53 3	53 3	0 313	354 9	54 0	54 0	0 312	384 5	54 7	54 7	0 311	100	93
100	94	336 7	53 5	53 5	0 301	368 1	54 2	54 2	0 300	398 8	54 9	54 9	0 299	100	94
100	95	349 0	53 7	53 7	0 290	381 5	54 5	54 5	0 289	413 4	55 2	55 2	0 287	100	95
100	96	361 7	53 9	53 9	0 279	395 4	54 7	54 7	0 278	428 4	55 4	55 4	0 276	100	96
100	97	374 6	54 2	54 2	0 269	409 5	54 9	54 9	0 267	443 7	55 7	55 7	0 266	100	97
105	71	124 3	50 4	49 7	0 916	136 1	50 7	49 9	0 920	147 7	50 9	50 1	0 924	105	71
105	72	130 3	50 7	50 0	0 870	142 5	51 0	50 3	0 875	154 6	51 3	50 5	0 879	105	72
105	73	136 9	50 9	50 2	0 827	149 6	51 2	50 5	0 831	162 1	51 5	50 8	0 835	105	73
105	74	143 8	51 0	50 4	0 785	157 1	51 4	50 8	0 789	170 2	51 8	51 1	0 793	105	74
105	75	151 1	51 2	50 6	0 747	165 0	51 6	51 0	0 750	178 7	51 9	51 3	0 754	105	75
105	76	158 7	51 3	50 7	0 711	173 3	51 7	51 1	0 714	187 6	52 1	51 5	0 717	105	76
105	77	166 6	51 4	50 9	0 677	181 9	51 8	51 3	0 680	196 9	52 2	51 7	0 683	105	77
105	78	174 8	51 4	51 0	0 646	190 9	51 9	51 4	0 648	206 6	52 3	51 8	0 650	105	78
105	79	183 2	51 5	51 1	0 616	200 1	52 0	51 5	0 618	216 6	52 4	52 0	0 620	105	79
105	80	191 8	51 6	51 2	0 589	209 5	52 1	51 7	0 591	226 8	52 5	52 1	0 592	105	80
105	81	200 6	51 7	51 3	0 563	219 1	52 2	51 8	0 565	237 2	52 6	52 3	0 566	105	81
105	82	209 6	51 7	51 5	0 539	229 0	52 2	52 0	0 540	247 9	52 7	52 4	0 542	105	82
105	83	218 8	51 8	51 6	0 517	239 1	52 3	52 1	0 518	258 9	52 9	52 6	0 518	105	83
105	84	228 3	51 9	51 7	0 496	249 4	52 4	52 3	0 496	270 1	53 0	52 8	0 497	105	84
105	85	237 9	52 0	51 9	0 476	260 0	52 6	52 4	0 476	281 5	53 1	52 9	0 476	105	85
105	86	247 8	52 1	52 0	0 457	270 8	52 7	52 6	0 457	293 3	53 2	53 1	0 457	105	86
105	87	257 9	52 2	52 2	0 439	281 9	52 8	52 8	0 439	305 3	53 4	53 3	0 439	105	87
105	88	268 3	52 3	52 3	0 421	293 2	52 9	52 9	0 421	317 7	53 5	53 5	0 421	105	88
105	89	279 0	52 5	52 5	0 405	304 9	53 1	53 1	0 405	330 3	53 7	53 7	0 404	105	89
105	90	289 9	52 7	52 7	0 389	316 8	53 3	53 3	0 389	343 2	53 9	53 9	0 388	105	90
105	91	301 0	52 9	52 9	0 374	329 0	53 5	53 5	0 374	356 5	54 2	54 2	0 373	105	91
105	92	312 5	53 1	53 1	0 360	341 6	53 7	53 7	0 359	370 0	54 4	54 4	0 359	105	92
105	93	324 2	53 3	53 3	0 347	354 4	54 0	54 0	0 346	384 0	54 6	54 6	0 345	105	93
105	94	336 2	53 5	53 5	0 334	367 5	54 2	54 2	0 333	398 2	54 9	54 9	0 332	105	94
105	95	348 5	53 7	53 7	0 321	381 0	54 4	54 4	0 320	412 8	55 1	55 1	0 319	105	95
105	96	361 2	53 9	53 9	0 310	394 8	54 7	54 7	0 308	427 8	55 4	55 4	0 307	105	96
105	97	374 1	54 1	54 1	0 298	409 0	54 9	54 9	0 297	443 1	55 7	55 7	0 296	105	97
105	98	387 4	54 4	54 4	0 287	423 5	55 2	55 2	0 286	458 9	55 9	55 9	0 285	105	98
105	99	401 0	54 6	54 6	0 277	438 4	55 4	55 4	0 276	475 0	56 2	56 2	0 274	105	99
105	100	415 0	54 9	54 9	0 267	453 6	55 7	55 7	0 266	491 5	56 5	56 5	0 264	105	100
105	101	429 3	55 1	55 1	0 258	469 3	56 0	56 0	0 256	508 5	56 8	56 8	0 254	105	101
105	102	444 0	55 4	55 4	0 248	485 3	56 3	56 3	0 247	525 9	57 2	57 2	0 245	105	102

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 66
Leaving Water = 51.67

AIR TEMP (°F) EDB	EWB	AIRFLOW						AIR TEMP (°F) EDB				EWB
		2500 CFM (FPM = 500)			2700 CFM (FPM = 540)			MBH	LDB	LWB	SHR	
75	59	69.28	49.7	48.6	1.000	74.41	49.8	48.7	1.000	75	59	
75	60	72.49	49.7	49.3	0.956	77.57	49.8	49.4	0.961	75	60	
75	61	76.85	50.2	49.9	0.884	82.10	50.3	50.0	0.889	75	61	
75	62	82.38	50.6	50.3	0.814	87.88	50.7	50.4	0.818	75	62	
75	63	88.83	50.8	50.5	0.748	94.68	51.0	50.7	0.752	75	63	
75	64	96.02	51.0	50.7	0.689	102.3	51.2	50.9	0.692	75	64	
75	65	103.8	51.0	50.8	0.636	110.5	51.3	51.1	0.639	75	65	
75	66	112.0	51.1	50.9	0.589	119.3	51.3	51.1	0.591	75	66	
75	67	120.4	51.1	51.0	0.548	128.3	51.4	51.2	0.549	75	67	
75	68	128.9	51.2	51.1	0.511	137.4	51.5	51.4	0.512	75	68	
75	69	137.6	51.2	51.2	0.478	146.7	51.5	51.5	0.479	75	69	
75	70	146.5	51.3	51.3	0.448	156.2	51.6	51.6	0.449	75	70	
75	71	155.5	51.4	51.4	0.421	165.9	51.7	51.7	0.421	75	71	
75	72	164.8	51.5	51.5	0.396	175.8	51.8	51.8	0.396	75	72	
80	61	82.52	49.8	48.9	1.000	88.67	50.0	49.0	1.000	80	61	
80	62	86.87	49.9	49.5	0.949	92.99	50.0	49.6	0.953	80	62	
80	63	91.81	50.4	50.0	0.884	98.12	50.6	50.1	0.889	80	63	
80	64	97.79	50.7	50.4	0.822	104.4	50.9	50.5	0.826	80	64	
80	65	104.6	51.0	50.6	0.763	111.6	51.2	50.8	0.767	80	65	
80	66	112.1	51.1	50.8	0.709	119.5	51.4	51.1	0.712	80	66	
80	67	120.0	51.2	51.0	0.660	128.0	51.5	51.2	0.663	80	67	
80	68	128.5	51.3	51.1	0.616	137.0	51.6	51.3	0.618	80	68	
80	69	137.2	51.4	51.2	0.577	146.3	51.7	51.4	0.578	80	69	
80	70	146.1	51.4	51.3	0.541	155.8	51.7	51.6	0.542	80	70	
80	71	155.1	51.5	51.4	0.509	165.5	51.8	51.7	0.510	80	71	
80	72	164.4	51.6	51.5	0.480	175.4	51.9	51.8	0.480	80	72	
80	73	173.8	51.7	51.6	0.453	185.5	52.0	52.0	0.453	80	73	
80	74	183.5	51.8	51.8	0.428	195.8	52.1	52.1	0.428	80	74	
80	75	193.3	51.9	51.9	0.405	206.4	52.2	52.2	0.405	80	75	
80	76	203.4	52.0	52.0	0.384	217.2	52.4	52.4	0.383	80	76	
80	77	213.8	52.2	52.2	0.364	228.2	52.6	52.6	0.363	80	77	
85	63	95.72	50.0	49.3	1.000	102.9	50.2	49.4	1.000	85	63	
85	64	101.6	50.2	49.7	0.939	108.8	50.3	49.8	0.943	85	64	
85	65	107.1	50.6	50.2	0.880	114.6	50.8	50.3	0.884	85	65	
85	66	113.6	51.0	50.5	0.823	121.3	51.2	50.7	0.827	85	66	
85	67	120.8	51.2	50.8	0.770	129.0	51.4	51.0	0.774	85	67	
85	68	128.6	51.4	51.0	0.720	137.2	51.6	51.2	0.724	85	68	
85	69	136.9	51.5	51.1	0.675	146.0	51.8	51.4	0.678	85	69	
85	70	145.7	51.6	51.3	0.634	155.4	51.9	51.5	0.636	85	70	
85	71	154.7	51.6	51.4	0.596	165.0	51.9	51.7	0.598	85	71	
85	72	164.0	51.7	51.5	0.562	174.9	52.0	51.8	0.564	85	72	
85	73	173.4	51.8	51.6	0.531	185.0	52.1	51.9	0.532	85	73	
85	74	183.0	51.9	51.7	0.503	195.4	52.2	52.1	0.504	85	74	
85	75	192.9	52.0	51.9	0.476	205.9	52.3	52.2	0.477	85	75	
85	76	203.0	52.1	52.0	0.452	216.7	52.4	52.4	0.452	85	76	
85	77	213.3	52.2	52.2	0.430	227.7	52.5	52.5	0.430	85	77	
85	78	223.8	52.3	52.3	0.408	239.0	52.7	52.7	0.408	85	78	
85	79	234.6	52.5	52.5	0.388	250.6	52.9	52.9	0.388	85	79	
85	80	245.6	52.6	52.6	0.370	262.4	53.0	53.0	0.369	85	80	
85	81	256.9	52.8	52.8	0.352	274.5	53.2	53.2	0.351	85	81	
85	82	268.5	53.0	53.0	0.336	286.8	53.4	53.4	0.335	85	82	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 66
Leaving Water = 51.67

AIR TEMP. (F)				AIRFLOW								AIR TEMP. (F)			
EDB	EWB	MBH	LDB	2500 CFM (FPM = 500)			MBH	LDB	2700 CFM (FPM = 540)			EDB	EWB		
				LWB	SHR				LWB	SHR					
90	65	111.9	49.9	49.3	0.981		120.0	50.1	49.5	0.984		90	65		
90	66	116.9	50.5	49.9	0.927		125.1	50.7	50.1	0.931		90	66		
90	67	123.0	50.9	50.4	0.873		131.5	51.1	50.6	0.877		90	67		
90	68	130.0	51.2	50.7	0.820		138.9	51.4	50.9	0.824		90	68		
90	69	137.6	51.4	51.0	0.771		146.9	51.7	51.2	0.775		90	69		
90	70	145.8	51.6	51.2	0.726		155.6	51.9	51.4	0.729		90	70		
90	71	154.4	51.7	51.3	0.684		164.8	52.0	51.6	0.687		90	71		
90	72	163.5	51.8	51.5	0.645		174.5	52.1	51.8	0.648		90	72		
90	73	173.0	51.9	51.6	0.610		184.6	52.2	51.9	0.612		90	73		
90	74	182.6	52.0	51.7	0.577		194.9	52.3	52.1	0.579		90	74		
90	75	192.5	52.1	51.9	0.547		205.4	52.4	52.2	0.548		90	75		
90	76	202.5	52.2	52.0	0.519		216.2	52.5	52.4	0.520		90	76		
90	77	212.8	52.3	52.1	0.494		227.2	52.7	52.5	0.494		90	77		
90	78	223.4	52.4	52.3	0.470		238.5	52.8	52.7	0.470		90	78		
90	79	234.1	52.5	52.5	0.448		250.1	52.9	52.8	0.448		90	79		
90	80	245.2	52.6	52.6	0.427		261.9	53.0	53.0	0.427		90	80		
90	81	256.4	52.8	52.8	0.407		273.9	53.2	53.2	0.407		90	81		
90	82	268.0	53.0	53.0	0.388		286.3	53.4	53.4	0.388		90	82		
90	83	279.8	53.1	53.1	0.371		298.9	53.6	53.6	0.370		90	83		
90	84	291.9	53.3	53.3	0.354		311.9	53.8	53.8	0.354		90	84		
90	85	304.3	53.5	53.5	0.339		325.1	54.0	54.0	0.338		90	85		
90	86	317.0	53.7	53.7	0.324		338.7	54.2	54.2	0.323		90	86		
90	87	329.9	53.9	53.9	0.310		352.6	54.5	54.5	0.309		90	87		
95	67	126.9	50.3	49.7	0.964		136.1	50.5	49.8	0.968		95	67		
95	68	132.7	50.8	50.2	0.913		142.0	51.0	50.4	0.917		95	68		
95	69	139.4	51.2	50.6	0.863		149.1	51.4	50.8	0.867		95	69		
95	70	146.9	51.5	50.9	0.815		157.0	51.7	51.2	0.819		95	70		
95	71	155.0	51.7	51.2	0.769		165.6	52.0	51.4	0.773		95	71		
95	72	163.6	51.9	51.4	0.727		174.7	52.2	51.7	0.730		95	72		
95	73	172.7	52.0	51.6	0.688		184.3	52.3	51.9	0.691		95	73		
95	74	182.2	52.1	51.7	0.651		194.4	52.5	52.0	0.654		95	74		
95	75	192.0	52.2	51.8	0.617		205.0	52.6	52.2	0.620		95	75		
95	76	202.1	52.3	52.0	0.586		215.7	52.7	52.3	0.588		95	76		
95	77	212.4	52.4	52.1	0.558		226.8	52.8	52.5	0.559		95	77		
95	78	222.9	52.5	52.3	0.531		238.0	52.9	52.7	0.532		95	78		
95	79	233.7	52.6	52.4	0.506		249.5	53.0	52.8	0.507		95	79		
95	80	244.7	52.7	52.6	0.483		261.3	53.1	53.0	0.483		95	80		
95	81	255.9	52.8	52.8	0.461		273.4	53.3	53.2	0.461		95	81		
95	82	267.5	53.0	52.9	0.441		285.7	53.4	53.4	0.441		95	82		
95	83	279.3	53.1	53.1	0.421		298.4	53.6	53.6	0.421		95	83		
95	84	291.4	53.3	53.3	0.403		311.3	53.8	53.8	0.403		95	84		
95	85	303.8	53.5	53.5	0.385		324.6	54.0	54.0	0.385		95	85		
95	86	316.4	53.7	53.7	0.369		338.1	54.2	54.2	0.368		95	86		
95	87	329.4	53.9	53.9	0.353		352.0	54.4	54.4	0.353		95	87		
95	88	342.7	54.1	54.1	0.338		366.2	54.7	54.7	0.338		95	88		
95	89	356.3	54.4	54.4	0.324		380.8	54.9	54.9	0.323		95	89		
95	90	370.2	54.6	54.6	0.311		395.7	55.1	55.1	0.310		95	90		
95	91	384.5	54.8	54.8	0.298		411.0	55.4	55.4	0.297		95	91		
95	92	399.1	55.1	55.1	0.286		426.6	55.7	55.7	0.285		95	92		

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 66
Leaving Water = 51.67

AIR TEMP (°F)				AIRFLOW						AIR TEMP (°F)			
EDB	EWB	2500 CFM (FPM = 500)			SHR	2700 CFM (FPM = 540)			EDB	EWB			
		MBH	LDB	LWB		MBH	LDB	LWB		SHR	EDB	EWB	
100	69	142.7	50.7	50.0	0.947	152.9	50.9	50.2	0.950	100	69		
100	70	149.2	51.2	50.5	0.898	159.7	51.4	50.7	0.902	100	70		
100	71	156.5	51.5	50.9	0.851	167.4	51.8	51.1	0.855	100	71		
100	72	164.6	51.8	51.2	0.807	175.9	52.1	51.4	0.810	100	72		
100	73	173.2	52.0	51.4	0.764	185.0	52.3	51.7	0.768	100	73		
100	74	182.2	52.2	51.6	0.725	194.6	52.5	51.9	0.728	100	74		
100	75	191.7	52.3	51.8	0.688	204.7	52.7	52.1	0.691	100	75		
100	76	201.6	52.4	52.0	0.653	215.3	52.8	52.3	0.656	100	76		
100	77	211.9	52.5	52.1	0.621	226.3	52.9	52.5	0.624	100	77		
100	78	222.4	52.6	52.3	0.592	237.5	53.0	52.6	0.594	100	78		
100	79	233.2	52.7	52.4	0.564	249.0	53.1	52.8	0.566	100	79		
100	80	244.2	52.8	52.6	0.538	260.8	53.3	53.0	0.539	100	80		
100	81	255.5	53.0	52.7	0.514	272.9	53.4	53.2	0.515	100	81		
100	82	267.0	53.1	52.9	0.492	285.2	53.5	53.3	0.492	100	82		
100	83	278.8	53.2	53.1	0.470	297.8	53.7	53.5	0.471	100	83		
100	84	290.9	53.4	53.3	0.450	310.8	53.8	53.7	0.451	100	84		
100	85	303.2	53.5	53.5	0.432	324.0	54.0	54.0	0.432	100	85		
100	86	315.9	53.7	53.7	0.414	337.5	54.2	54.2	0.413	100	86		
100	87	328.9	53.9	53.9	0.396	351.4	54.4	54.4	0.396	100	87		
100	88	342.1	54.1	54.1	0.380	365.6	54.6	54.6	0.380	100	88		
100	89	355.7	54.3	54.3	0.364	380.2	54.9	54.9	0.364	100	89		
100	90	369.7	54.6	54.6	0.350	395.1	55.1	55.1	0.349	100	90		
100	91	383.9	54.8	54.8	0.336	410.3	55.4	55.4	0.335	100	91		
100	92	398.6	55.0	55.0	0.322	426.0	55.6	55.6	0.321	100	92		
100	93	413.5	55.3	55.3	0.310	442.0	55.9	55.9	0.308	100	93		
100	94	428.9	55.6	55.6	0.297	458.4	56.2	56.2	0.296	100	94		
100	95	444.6	55.8	55.8	0.286	475.2	56.5	56.5	0.285	100	95		
100	96	460.7	56.1	56.1	0.275	492.5	56.8	56.8	0.273	100	96		
100	97	477.3	56.4	56.4	0.264	510.1	57.1	57.1	0.263	100	97		
105	71	159.2	51.1	50.4	0.928	170.5	51.4	50.6	0.932	105	71		
105	72	166.4	51.5	50.8	0.883	178.1	51.8	51.0	0.886	105	72		
105	73	174.4	51.8	51.1	0.839	186.5	52.1	51.4	0.842	105	73		
105	74	183.0	52.1	51.4	0.797	195.6	52.4	51.7	0.800	105	74		
105	75	192.1	52.3	51.7	0.757	205.2	52.6	52.0	0.760	105	75		
105	76	201.6	52.5	51.9	0.720	215.3	52.8	52.2	0.723	105	76		
105	77	211.6	52.6	52.1	0.685	225.9	53.0	52.4	0.688	105	77		
105	78	222.0	52.7	52.2	0.653	237.0	53.1	52.6	0.655	105	78		
105	79	232.7	52.9	52.4	0.622	248.5	53.3	52.8	0.624	105	79		
105	80	243.7	53.0	52.5	0.594	260.3	53.4	53.0	0.596	105	80		
105	81	255.0	53.1	52.7	0.567	272.4	53.5	53.1	0.569	105	81		
105	82	266.5	53.2	52.9	0.543	284.7	53.7	53.3	0.544	105	82		
105	83	278.3	53.3	53.1	0.519	297.3	53.8	53.5	0.520	105	83		
105	84	290.3	53.5	53.3	0.497	310.2	54.0	53.7	0.498	105	84		
105	85	302.7	53.6	53.4	0.477	323.4	54.1	53.9	0.477	105	85		
105	86	315.3	53.8	53.6	0.457	337.0	54.3	54.1	0.458	105	86		
105	87	328.3	53.9	53.9	0.439	350.8	54.4	54.4	0.439	105	87		
105	88	341.6	54.1	54.1	0.421	365.0	54.6	54.6	0.421	105	88		
105	89	355.2	54.3	54.3	0.404	379.6	54.8	54.8	0.404	105	89		
105	90	369.1	54.5	54.5	0.388	394.5	55.1	55.1	0.388	105	90		
105	91	383.4	54.8	54.8	0.373	409.7	55.3	55.3	0.372	105	91		
105	92	398.0	55.0	55.0	0.358	425.4	55.6	55.6	0.358	105	92		
105	93	412.9	55.3	55.3	0.344	441.4	55.9	55.9	0.343	105	93		
105	94	428.3	55.5	55.5	0.331	457.8	56.2	56.2	0.330	105	94		
105	95	444.0	55.8	55.8	0.318	474.6	56.4	56.4	0.317	105	95		
105	96	460.1	56.1	56.1	0.306	491.8	56.7	56.7	0.305	105	96		
105	97	476.6	56.4	56.4	0.294	509.5	57.1	57.1	0.293	105	97		
105	98	493.6	56.7	56.7	0.283	527.5	57.4	57.4	0.282	105	98		
105	99	510.9	57.0	57.0	0.273	546.1	57.7	57.7	0.271	105	99		
105	100	528.7	57.3	57.3	0.262	565.1	58.1	58.1	0.261	105	100		
105	101	546.9	57.6	57.6	0.253	584.6	58.4	58.4	0.251	105	101		
105	102	565.6	58.0	58.0	0.243	604.5	58.8	58.8	0.242	105	102		

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 67
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	2200 CFM (FPM = 293)				2600 CFM (FPM = 347)				3000 CFM (FPM = 400)				AIR TEMP. (F)	
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
75	59	62.87	49.2	48.4	1.000	73.77	49.5	48.5	1.000	84.30	49.8	48.6	1.000	75	59	
75	60	67.39	49.3	48.8	0.934	78.51	49.5	49.1	0.943	89.10	49.8	49.3	0.950	75	60	
75	61	72.24	49.6	49.2	0.861	83.88	50.0	49.5	0.869	94.95	50.2	49.8	0.878	75	61	
75	62	78.01	49.8	49.5	0.791	90.37	50.2	49.8	0.799	102.2	50.6	50.1	0.807	75	62	
75	63	84.55	49.9	49.6	0.728	97.82	50.4	50.0	0.735	110.4	50.7	50.4	0.742	75	63	
75	64	91.59	49.9	49.7	0.672	105.9	50.4	50.1	0.678	119.5	50.8	50.5	0.684	75	64	
75	65	99.01	49.9	49.7	0.622	114.5	50.4	50.2	0.627	129.2	50.9	50.6	0.632	75	65	
75	66	106.6	49.9	49.7	0.579	123.3	50.4	50.2	0.583	139.3	50.9	50.7	0.586	75	66	
75	67	114.3	49.9	49.8	0.541	132.4	50.5	50.3	0.543	149.6	50.9	50.8	0.545	75	67	
75	68	122.1	49.9	49.8	0.507	141.6	50.5	50.4	0.508	160.0	51.0	50.9	0.509	75	68	
75	69	130.2	49.9	49.9	0.476	151.0	50.5	50.4	0.477	170.7	51.0	51.0	0.477	75	69	
75	70	138.3	49.9	49.9	0.448	160.5	50.5	50.5	0.448	181.6	51.1	51.1	0.448	75	70	
75	71	146.7	50.0	50.0	0.422	170.3	50.6	50.6	0.422	192.7	51.2	51.2	0.421	75	71	
75	72	155.2	50.1	50.1	0.398	180.3	50.7	50.7	0.397	204.1	51.3	51.3	0.397	75	72	
80	61	76.44	49.4	48.7	1.000	87.81	49.7	48.8	1.000	100.3	50.0	49.0	1.000	80	61	
80	62	80.59	49.5	48.9	0.927	93.91	49.8	49.2	0.936	106.7	50.0	49.5	0.943	80	62	
80	63	85.98	49.8	49.3	0.862	99.95	50.1	49.6	0.870	113.3	50.5	49.9	0.878	80	63	
80	64	92.16	49.9	49.5	0.800	107.0	50.4	49.9	0.808	121.0	50.8	50.3	0.815	80	64	
80	65	99.00	50.0	49.6	0.743	114.7	50.5	50.1	0.750	129.7	50.9	50.5	0.757	80	65	
80	66	106.3	50.1	49.7	0.692	123.1	50.6	50.2	0.698	139.1	51.1	50.6	0.704	80	66	
80	67	113.9	50.1	49.8	0.646	132.0	50.6	50.3	0.651	149.1	51.1	50.8	0.656	80	67	
80	68	121.8	50.1	49.8	0.605	141.2	50.6	50.4	0.609	159.5	51.2	50.8	0.612	80	68	
80	69	129.8	50.1	49.9	0.568	150.5	50.7	50.4	0.571	170.2	51.2	50.9	0.574	80	69	
80	70	138.0	50.1	49.9	0.535	160.1	50.7	50.5	0.537	181.1	51.3	51.0	0.539	80	70	
80	71	146.3	50.1	50.0	0.505	169.8	50.7	50.6	0.506	192.2	51.3	51.2	0.508	80	71	
80	72	154.8	50.1	50.1	0.478	179.8	50.8	50.7	0.478	203.6	51.4	51.3	0.479	80	72	
80	73	163.5	50.1	50.1	0.453	190.0	50.8	50.8	0.453	215.1	51.4	51.4	0.453	80	73	
80	74	172.4	50.2	50.2	0.429	200.4	50.9	50.9	0.429	227.0	51.5	51.5	0.428	80	74	
80	75	181.5	50.3	50.3	0.407	211.0	51.0	51.0	0.406	239.1	51.7	51.7	0.405	80	75	
80	76	190.8	50.4	50.4	0.386	221.9	51.1	51.1	0.385	251.5	51.8	51.8	0.384	80	76	
80	77	200.3	50.5	50.5	0.367	233.0	51.2	51.2	0.366	264.1	51.9	51.9	0.365	80	77	
85	63	89.29	49.2	48.6	0.979	104.5	49.5	48.8	0.986	119.0	50.2	49.4	1.000	85	63	
85	64	94.23	49.7	49.1	0.918	109.8	50.0	49.4	0.926	124.8	50.3	49.7	0.933	85	64	
85	65	100.1	49.9	49.4	0.859	116.5	50.4	49.8	0.867	132.1	50.7	50.1	0.874	85	65	
85	66	106.8	50.1	49.6	0.802	124.0	50.6	50.0	0.810	140.4	51.0	50.4	0.817	85	66	
85	67	113.9	50.2	49.7	0.751	132.2	50.7	50.2	0.758	149.6	51.2	50.6	0.764	85	67	
85	68	121.5	50.2	49.8	0.704	140.9	50.8	50.3	0.710	159.4	51.3	50.8	0.715	85	68	
85	69	129.5	50.2	49.8	0.661	150.1	50.8	50.4	0.666	169.7	51.4	50.9	0.671	85	69	
85	70	137.6	50.2	49.9	0.622	159.7	50.9	50.5	0.626	180.6	51.4	51.0	0.630	85	70	
85	71	145.9	50.3	50.0	0.587	169.4	50.9	50.6	0.590	191.7	51.5	51.1	0.593	85	71	
85	72	154.4	50.3	50.0	0.555	179.4	50.9	50.7	0.558	203.0	51.5	51.3	0.560	85	72	
85	73	163.1	50.3	50.1	0.526	189.5	51.0	50.8	0.528	214.6	51.6	51.4	0.530	85	73	
85	74	172.0	50.3	50.2	0.499	199.9	51.0	50.9	0.500	226.4	51.7	51.5	0.502	85	74	
85	75	181.1	50.3	50.3	0.475	210.5	51.1	51.0	0.475	238.5	51.7	51.6	0.476	85	75	
85	76	190.3	50.4	50.4	0.452	221.4	51.1	51.1	0.452	250.9	51.8	51.8	0.452	85	76	
85	77	199.9	50.5	50.5	0.430	232.5	51.2	51.2	0.430	263.6	51.9	51.9	0.430	85	77	
85	78	209.5	50.6	50.6	0.410	243.9	51.3	51.3	0.409	276.5	52.1	52.1	0.408	85	78	
85	79	219.5	50.7	50.7	0.390	255.5	51.5	51.5	0.389	289.7	52.2	52.2	0.389	85	79	
85	80	229.6	50.8	50.8	0.373	267.4	51.6	51.6	0.371	303.2	52.4	52.4	0.370	85	80	
85	81	240.1	50.9	50.9	0.356	279.5	51.7	51.7	0.354	317.1	52.5	52.5	0.353	85	81	
85	82	250.7	51.0	51.0	0.340	291.9	51.9	51.9	0.338	331.3	52.7	52.7	0.336	85	82	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 67
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	AIRFLOW								AIR TEMP. (F)				
			2200 CFM (FPM = 293)				2600 CFM (FPM = 347)				3000 CFM (FPM = 400)				
MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR				
90	65	102.7	49.5	48.8	0.963	120.1	49.9	49.1	0.970	136.8	50.2	49.4	0.976	90	65
90	66	108.3	49.9	49.2	0.907	126.3	50.3	49.6	0.914	143.5	50.7	49.9	0.922	90	66
90	67	114.7	50.1	49.5	0.852	133.5	50.6	49.9	0.860	151.5	51.0	50.3	0.867	90	67
90	68	121.8	50.3	49.7	0.801	141.6	50.8	50.2	0.808	160.4	51.3	50.6	0.815	90	68
90	69	129.4	50.3	49.8	0.753	150.3	50.9	50.3	0.760	170.2	51.4	50.8	0.766	90	69
90	70	137.3	50.4	49.9	0.709	159.4	51.0	50.5	0.715	180.5	51.6	51.0	0.721	90	70
90	71	145.5	50.4	50.0	0.670	169.0	51.1	50.6	0.674	191.3	51.6	51.1	0.679	90	71
90	72	154.0	50.4	50.0	0.633	178.9	51.1	50.7	0.637	202.5	51.7	51.2	0.641	90	72
90	73	162.7	50.4	50.1	0.600	189.0	51.1	50.8	0.603	214.1	51.8	51.4	0.606	90	73
90	74	171.6	50.5	50.2	0.569	199.5	51.2	50.9	0.572	225.9	51.8	51.5	0.574	90	74
90	75	180.6	50.5	50.3	0.541	210.0	51.2	51.0	0.543	238.0	51.9	51.6	0.545	90	75
90	76	189.9	50.5	50.4	0.515	220.9	51.3	51.1	0.516	250.4	52.0	51.8	0.518	90	76
90	77	199.4	50.6	50.4	0.491	232.0	51.3	51.2	0.492	263.0	52.1	51.9	0.493	90	77
90	78	209.1	50.6	50.5	0.468	243.4	51.4	51.3	0.469	275.9	52.2	52.0	0.469	90	78
90	79	219.0	50.6	50.6	0.447	255.0	51.5	51.5	0.447	289.1	52.2	52.2	0.448	90	79
90	80	229.2	50.8	50.8	0.427	266.8	51.6	51.6	0.427	302.6	52.4	52.4	0.427	90	80
90	81	239.6	50.9	50.9	0.408	279.0	51.7	51.7	0.408	316.5	52.5	52.5	0.407	90	81
90	82	250.2	51.0	51.0	0.390	291.4	51.9	51.9	0.389	330.6	52.7	52.7	0.389	90	82
90	83	261.1	51.1	51.1	0.374	304.1	52.0	52.0	0.372	345.2	52.9	52.9	0.371	90	83
90	84	272.3	51.2	51.2	0.358	317.2	52.2	52.2	0.356	360.0	53.1	53.1	0.355	90	84
90	85	283.7	51.4	51.4	0.343	330.6	52.3	52.3	0.341	375.2	53.2	53.2	0.339	90	85
90	86	295.4	51.5	51.5	0.329	344.2	52.5	52.5	0.327	390.8	53.4	53.4	0.325	90	86
90	87	307.4	51.7	51.7	0.315	358.2	52.7	52.7	0.313	406.7	53.6	53.6	0.311	90	87
95	67	116.7	49.8	49.0	0.946	136.4	50.2	49.4	0.953	155.3	50.6	49.7	0.960	95	67
95	68	123.0	50.1	49.4	0.894	143.4	50.6	49.8	0.901	163.0	51.0	50.2	0.908	95	68
95	69	129.9	50.3	49.6	0.843	151.3	50.9	50.1	0.851	171.7	51.3	50.5	0.858	95	69
95	70	137.5	50.5	49.8	0.796	159.9	51.0	50.3	0.803	181.3	51.5	50.8	0.809	95	70
95	71	145.4	50.5	49.9	0.752	169.0	51.2	50.5	0.758	191.5	51.7	51.0	0.764	95	71
95	72	153.7	50.6	50.0	0.711	178.6	51.2	50.6	0.717	202.3	51.8	51.2	0.722	95	72
95	73	162.3	50.6	50.1	0.674	188.6	51.3	50.7	0.679	213.6	51.9	51.3	0.683	95	73
95	74	171.2	50.6	50.2	0.639	198.9	51.3	50.8	0.643	225.4	52.0	51.5	0.647	95	74
95	75	180.2	50.7	50.2	0.608	209.6	51.4	50.9	0.611	237.5	52.1	51.6	0.614	95	75
95	76	189.5	50.7	50.3	0.578	220.4	51.5	51.1	0.581	249.8	52.2	51.7	0.584	95	76
95	77	199.0	50.7	50.4	0.551	231.5	51.5	51.2	0.553	262.4	52.2	51.9	0.555	95	77
95	78	208.7	50.8	50.5	0.526	242.8	51.6	51.3	0.528	275.3	52.3	52.0	0.529	95	78
95	79	218.6	50.8	50.6	0.503	254.4	51.6	51.4	0.504	288.5	52.4	52.2	0.505	95	79
95	80	228.7	50.8	50.7	0.481	266.3	51.7	51.6	0.481	302.0	52.5	52.3	0.482	95	80
95	81	239.1	50.9	50.8	0.460	278.4	51.8	51.7	0.460	315.8	52.6	52.5	0.461	95	81
95	82	249.7	51.0	51.0	0.441	290.8	51.9	51.8	0.441	330.0	52.7	52.7	0.441	95	82
95	83	260.6	51.1	51.1	0.422	303.6	52.0	52.0	0.421	344.5	52.8	52.8	0.421	95	83
95	84	271.8	51.2	51.2	0.404	316.6	52.2	52.2	0.403	359.3	53.0	53.0	0.403	95	84
95	85	283.2	51.3	51.3	0.387	330.0	52.3	52.3	0.386	374.6	53.2	53.2	0.386	95	85
95	86	294.9	51.5	51.5	0.371	343.7	52.5	52.5	0.370	390.1	53.4	53.4	0.369	95	86
95	87	306.9	51.6	51.6	0.356	357.6	52.7	52.7	0.355	406.1	53.6	53.6	0.354	95	87
95	88	319.1	51.8	51.8	0.342	372.0	52.8	52.8	0.341	422.3	53.8	53.8	0.339	95	88
95	89	331.7	51.9	51.9	0.329	386.7	53.0	53.0	0.327	439.1	54.0	54.0	0.325	95	89
95	90	344.6	52.1	52.1	0.316	401.8	53.2	53.2	0.314	456.2	54.3	54.3	0.312	95	90
95	91	357.8	52.3	52.3	0.304	417.2	53.4	53.4	0.301	473.8	54.5	54.5	0.299	95	91
95	92	371.4	52.4	52.4	0.292	433.0	53.6	53.6	0.290	491.7	54.7	54.7	0.287	95	92

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 67
Leaving Water = 51.67

AIR TEMP (°F)	AIRFLOW								AIR TEMP (°F)							
	2200 CFM (FPM = 293)				2600 CFM (FPM = 347)				3000 CFM (FPM = 400)				EDB EWB			
EDB	EWB	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB	
100	69	131.4	50.1	49.3	0.928	153.5	50.6	49.7	0.935	174.8	51.0	50.0	0.942	100	69	
100	70	138.3	50.4	49.6	0.879	161.3	50.9	50.0	0.886	183.2	51.4	50.4	0.893	100	70	
100	71	145.8	50.5	49.8	0.832	169.8	51.1	50.3	0.839	192.8	51.6	50.8	0.846	100	71	
100	72	153.8	50.7	49.9	0.788	178.9	51.3	50.5	0.795	203.0	51.9	51.0	0.801	100	72	
100	73	162.1	50.7	50.1	0.747	188.6	51.4	50.7	0.753	213.8	52.0	51.2	0.759	100	73	
100	74	170.8	50.8	50.1	0.709	198.6	51.5	50.8	0.715	225.1	52.1	51.4	0.720	100	74	
100	75	179.8	50.8	50.2	0.674	209.1	51.6	50.9	0.679	236.9	52.2	51.6	0.684	100	75	
100	76	189.1	50.8	50.3	0.642	219.9	51.6	51.0	0.646	249.2	52.3	51.7	0.650	100	76	
100	77	198.5	50.9	50.4	0.612	231.0	51.7	51.2	0.615	261.8	52.4	51.8	0.618	100	77	
100	78	208.2	50.9	50.5	0.584	242.3	51.7	51.3	0.586	274.7	52.5	52.0	0.589	100	78	
100	79	218.1	51.0	50.6	0.558	253.9	51.8	51.4	0.560	287.9	52.6	52.1	0.562	100	79	
100	80	228.3	51.0	50.7	0.533	265.8	51.9	51.5	0.535	301.4	52.7	52.3	0.537	100	80	
100	81	238.7	51.0	50.8	0.510	277.9	51.9	51.7	0.512	315.2	52.8	52.5	0.513	100	81	
100	82	249.2	51.1	50.9	0.489	290.3	52.0	51.8	0.490	329.4	52.9	52.6	0.491	100	82	
100	83	260.2	51.2	51.1	0.469	303.0	52.1	52.0	0.469	343.9	53.0	52.8	0.470	100	83	
100	84	271.2	51.2	51.2	0.450	316.0	52.2	52.1	0.450	358.7	53.1	53.0	0.450	100	84	
100	85	282.7	51.3	51.3	0.432	329.4	52.3	52.3	0.432	373.9	53.2	53.2	0.432	100	85	
100	86	294.3	51.5	51.5	0.414	343.1	52.5	52.5	0.414	389.4	53.4	53.4	0.414	100	86	
100	87	306.3	51.6	51.6	0.398	357.0	52.6	52.6	0.397	405.3	53.6	53.6	0.396	100	87	
100	88	318.6	51.7	51.7	0.382	371.4	52.8	52.8	0.381	421.7	53.8	53.8	0.380	100	88	
100	89	331.2	51.9	51.9	0.367	386.1	53.0	53.0	0.366	438.4	54.0	54.0	0.365	100	89	
100	90	344.1	52.1	52.1	0.353	401.1	53.2	53.2	0.351	455.5	54.2	54.2	0.350	100	90	
100	91	357.2	52.2	52.2	0.339	416.5	53.4	53.4	0.338	473.0	54.5	54.5	0.336	100	91	
100	92	370.8	52.4	52.4	0.327	432.3	53.6	53.6	0.325	491.0	54.7	54.7	0.323	100	92	
100	93	384.6	52.6	52.6	0.314	448.6	53.8	53.8	0.312	509.4	55.0	55.0	0.310	100	93	
100	94	398.9	52.8	52.8	0.303	465.2	54.0	54.0	0.300	528.3	55.2	55.2	0.298	100	94	
100	95	413.4	53.0	53.0	0.292	482.1	54.3	54.3	0.289	547.7	55.5	55.5	0.287	100	95	
100	96	428.4	53.2	53.2	0.281	499.6	54.5	54.5	0.278	567.5	55.8	55.8	0.275	100	96	
100	97	443.7	53.4	53.4	0.271	517.5	54.8	54.8	0.268	587.9	56.0	56.0	0.265	100	97	
105	71	146.8	50.4	49.5	0.910	171.4	50.9	50.0	0.917	195.1	51.4	50.4	0.924	105	71	
105	72	154.3	50.6	49.8	0.864	179.9	51.2	50.3	0.871	204.5	51.7	50.7	0.878	105	72	
105	73	162.4	50.8	49.9	0.820	189.1	51.4	50.5	0.827	214.7	52.0	51.0	0.834	105	73	
105	74	170.8	50.9	50.1	0.779	198.8	51.6	50.7	0.785	225.5	52.2	51.3	0.792	105	74	
105	75	179.5	50.9	50.2	0.741	209.0	51.7	50.9	0.747	236.9	52.3	51.5	0.752	105	75	
105	76	188.6	51.0	50.3	0.705	219.5	51.8	51.0	0.710	248.9	52.5	51.7	0.716	105	76	
105	77	198.1	51.0	50.4	0.672	230.5	51.8	51.1	0.677	261.2	52.6	51.8	0.681	105	77	
105	78	207.8	51.1	50.5	0.641	241.8	51.9	51.3	0.645	274.1	52.6	52.0	0.649	105	78	
105	79	217.7	51.1	50.6	0.613	253.4	52.0	51.4	0.616	287.3	52.7	52.1	0.619	105	79	
105	80	227.8	51.1	50.7	0.586	265.2	52.0	51.5	0.589	300.8	52.8	52.3	0.591	105	80	
105	81	238.2	51.2	50.8	0.561	277.4	52.1	51.7	0.563	314.6	52.9	52.4	0.565	105	81	
105	82	248.8	51.2	50.9	0.537	289.9	52.2	51.8	0.539	328.7	53.0	52.6	0.541	105	82	
105	83	259.6	51.3	51.0	0.515	302.4	52.3	51.9	0.517	343.2	53.1	52.8	0.518	105	83	
105	84	270.8	51.4	51.2	0.495	315.5	52.3	52.1	0.495	358.1	53.2	53.0	0.496	105	84	
105	85	282.2	51.4	51.3	0.475	328.8	52.4	52.3	0.475	373.2	53.4	53.2	0.476	105	85	
105	86	293.8	51.5	51.4	0.456	342.5	52.5	52.4	0.457	388.7	53.5	53.4	0.457	105	86	
105	87	305.8	51.6	51.6	0.439	356.4	52.6	52.6	0.439	404.6	53.6	53.6	0.439	105	87	
105	88	318.0	51.7	51.7	0.422	370.7	52.8	52.8	0.421	421.0	53.8	53.8	0.421	105	88	
105	89	330.7	51.9	51.9	0.405	385.5	53.0	53.0	0.405	437.6	54.0	54.0	0.404	105	89	
105	90	343.5	52.0	52.0	0.390	400.5	53.2	53.2	0.389	454.7	54.2	54.2	0.388	105	90	
105	91	356.7	52.2	52.2	0.375	415.9	53.4	53.4	0.374	472.3	54.4	54.4	0.373	105	91	
105	92	370.2	52.4	52.4	0.361	431.7	53.6	53.6	0.360	490.3	54.7	54.7	0.358	105	92	
105	93	384.1	52.6	52.6	0.347	447.9	53.8	53.8	0.346	508.7	54.9	54.9	0.345	105	93	
105	94	398.3	52.7	52.7	0.335	464.4	54.0	54.0	0.333	527.6	55.2	55.2	0.331	105	94	
105	95	412.8	52.9	52.9	0.322	481.5	54.2	54.2	0.320	546.9	55.4	55.4	0.319	105	95	
105	96	427.8	53.1	53.1	0.311	498.9	54.5	54.5	0.309	566.7	55.7	55.7	0.307	105	96	
105	97	443.1	53.3	53.3	0.300	516.8	54.7	54.7	0.297	587.0	56.0	56.0	0.295	105	97	
105	98	458.8	53.6	53.6	0.289	535.1	55.0	55.0	0.286	607.9	56.3	56.3	0.284	105	98	
105	99	474.9	53.8	53.8	0.279	553.9	55.2	55.2	0.276	629.3	56.6	56.6	0.273	105	99	
105	100	491.4	54.0	54.0	0.269	573.2	55.5	55.5	0.266	651.2	56.9	56.9	0.263	105	100	
105	101	508.4	54.2	54.2	0.259	593.0	55.8	55.8	0.256	673.6	57.2	57.2	0.253	105	101	
105	102	525.7	54.5	54.5	0.250	613.2	56.1	56.1	0.247	696.6	57.6	57.6	0.244	105	102	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 67
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	AIRFLOW								AIR TEMP. (F)				
			3400 CFM (FPM = 453)				3800 CFM (FPM = 507)				4200 CFM (FPM = 560)				
MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR				
75	59	94.7	50.0	48.7	1.000	105.2	50.2	48.8	1.000	115.3	50.4	48.9	1.000	75	59
75	60	99.5	50.0	49.5	0.958	109.9	50.2	49.6	0.964	120.0	50.3	49.8	0.971	75	60
75	61	105.7	50.5	50.0	0.885	116.5	50.7	50.2	0.893	126.9	50.9	50.4	0.900	75	61
75	62	113.6	50.9	50.4	0.815	124.9	51.1	50.7	0.822	135.8	51.4	50.9	0.829	75	62
75	63	122.6	51.1	50.7	0.749	134.6	51.4	51.0	0.755	146.2	51.7	51.3	0.761	75	63
75	64	132.6	51.2	50.9	0.689	145.5	51.6	51.2	0.695	157.9	51.9	51.5	0.700	75	64
75	65	143.3	51.3	51.0	0.636	157.2	51.7	51.4	0.640	170.6	52.0	51.7	0.645	75	65
75	66	154.6	51.3	51.1	0.589	169.7	51.7	51.5	0.592	184.2	52.1	51.8	0.596	75	66
75	67	166.1	51.4	51.2	0.548	182.4	51.8	51.6	0.550	198.0	52.2	52.0	0.552	75	67
75	68	177.8	51.5	51.3	0.511	195.4	51.9	51.7	0.513	212.2	52.3	52.1	0.514	75	68
75	69	189.7	51.5	51.4	0.478	208.6	52.0	51.9	0.479	226.6	52.4	52.3	0.480	75	69
75	70	201.9	51.6	51.6	0.448	222.0	52.1	52.0	0.449	241.3	52.5	52.4	0.449	75	70
75	71	214.3	51.7	51.7	0.421	235.8	52.2	52.2	0.421	256.3	52.6	52.6	0.421	75	71
75	72	227.1	51.8	51.8	0.396	249.9	52.3	52.3	0.395	271.6	52.8	52.8	0.395	75	72
80	61	112.7	50.2	49.1	1.000	125.3	50.5	49.2	1.000	137.4	50.7	49.3	1.000	80	61
80	62	119.3	50.3	49.7	0.950	131.8	50.5	49.9	0.957	143.9	50.7	50.0	0.963	80	62
80	63	126.3	50.8	50.2	0.886	139.2	51.0	50.4	0.892	151.7	51.3	50.6	0.899	80	63
80	64	134.7	51.1	50.6	0.823	148.3	51.4	50.9	0.829	161.3	51.7	51.1	0.836	80	64
80	65	144.2	51.3	50.8	0.764	158.6	51.7	51.2	0.770	172.3	52.0	51.5	0.776	80	65
80	66	154.5	51.5	51.0	0.709	169.9	51.9	51.4	0.715	184.5	52.2	51.7	0.720	80	66
80	67	165.6	51.6	51.2	0.660	181.9	52.0	51.6	0.665	197.6	52.4	52.0	0.670	80	67
80	68	177.3	51.6	51.3	0.616	194.7	52.1	51.7	0.620	211.5	52.5	52.1	0.624	80	68
80	69	189.2	51.7	51.4	0.577	207.9	52.1	51.9	0.580	225.9	52.6	52.3	0.582	80	69
80	70	201.4	51.8	51.5	0.541	221.4	52.2	52.0	0.543	240.6	52.7	52.4	0.545	80	70
80	71	213.8	51.8	51.7	0.509	235.1	52.3	52.1	0.510	255.6	52.8	52.6	0.512	80	71
80	72	226.5	51.9	51.8	0.480	249.2	52.4	52.3	0.481	271.0	52.9	52.8	0.482	80	72
80	73	239.5	52.0	52.0	0.453	263.5	52.5	52.5	0.453	286.6	53.0	52.9	0.454	80	73
80	74	252.7	52.1	52.1	0.428	278.2	52.6	52.6	0.428	302.6	53.2	53.1	0.428	80	74
80	75	266.2	52.3	52.3	0.405	293.1	52.8	52.8	0.405	319.0	53.3	53.3	0.404	80	75
80	76	280.1	52.4	52.4	0.383	308.5	53.0	53.0	0.383	335.7	53.5	53.5	0.382	80	76
80	77	294.2	52.6	52.6	0.363	324.1	53.2	53.2	0.362	352.7	53.7	53.7	0.361	80	77
85	63	133.3	50.5	49.5	1.000	145.3	50.8	49.6	1.000	159.5	51.0	49.7	1.000	85	63
85	64	139.5	50.6	49.9	0.940	154.1	50.9	50.1	0.947	168.4	51.1	50.3	0.953	85	64
85	65	147.3	51.1	50.4	0.881	162.5	51.4	50.7	0.888	177.1	51.6	50.9	0.895	85	65
85	66	156.4	51.4	50.8	0.824	172.3	51.7	51.1	0.831	187.5	52.0	51.4	0.837	85	66
85	67	166.5	51.6	51.0	0.771	183.2	52.0	51.4	0.777	199.2	52.3	51.7	0.783	85	67
85	68	177.2	51.8	51.2	0.721	195.0	52.2	51.6	0.726	212.0	52.6	52.0	0.732	85	68
85	69	188.8	51.9	51.4	0.676	207.6	52.3	51.8	0.680	225.5	52.7	52.2	0.685	85	69
85	70	200.8	51.9	51.5	0.634	220.8	52.4	52.0	0.638	239.9	52.9	52.4	0.642	85	70
85	71	213.2	52.0	51.7	0.597	234.5	52.5	52.1	0.600	255.0	53.0	52.6	0.603	85	71
85	72	225.9	52.1	51.8	0.562	248.6	52.6	52.3	0.565	270.3	53.1	52.7	0.567	85	72
85	73	238.9	52.2	51.9	0.531	262.9	52.7	52.4	0.533	285.9	53.2	52.9	0.535	85	73
85	74	252.1	52.3	52.1	0.503	277.5	52.8	52.6	0.504	301.9	53.3	53.1	0.505	85	74
85	75	265.6	52.4	52.2	0.477	292.5	52.9	52.8	0.477	318.2	53.5	53.3	0.478	85	75
85	76	279.5	52.5	52.4	0.452	307.8	53.0	53.0	0.453	334.9	53.6	53.5	0.453	85	76
85	77	293.6	52.6	52.6	0.430	323.4	53.2	53.2	0.430	352.0	53.7	53.7	0.430	85	77
85	78	308.1	52.7	52.7	0.408	339.4	53.3	53.3	0.408	369.5	53.9	53.9	0.408	85	78
85	79	322.9	52.9	52.9	0.388	355.8	53.5	53.5	0.387	387.3	54.1	54.1	0.387	85	79
85	80	338.0	53.1	53.1	0.369	372.5	53.8	53.8	0.368	405.6	54.4	54.4	0.367	85	80
85	81	353.5	53.3	53.3	0.351	389.6	54.0	54.0	0.350	424.3	54.6	54.6	0.349	85	81
85	82	369.4	53.5	53.5	0.335	407.2	54.2	54.2	0.333	443.4	54.9	54.9	0.332	85	82

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 67
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	AIRFLOW								AIR TEMP.				
			3400 CFM (FPM = 453)				3800 CFM (FPM = 507)				4200 CFM (FPM = 560)				
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	
90	65	153.2	50.4	49.6	0.982	169.7	50.6	49.8	0.988	185.8	51.3	50.3	1.000	90	65
90	66	160.4	51.0	50.2	0.928	177.3	51.3	50.4	0.935	193.6	51.5	50.7	0.941	90	66
90	67	169.0	51.4	50.6	0.874	186.5	51.7	50.9	0.881	203.4	52.0	51.2	0.887	90	67
90	68	178.8	51.7	51.0	0.822	197.1	52.1	51.3	0.828	214.7	52.4	51.7	0.834	90	68
90	69	189.5	51.9	51.2	0.772	208.6	52.3	51.6	0.778	227.1	52.7	52.0	0.784	90	69
90	70	200.9	52.1	51.5	0.727	221.0	52.5	51.9	0.732	240.4	53.0	52.3	0.737	90	70
90	71	212.8	52.2	51.6	0.684	234.2	52.7	52.1	0.689	254.7	53.1	52.5	0.694	90	71
90	72	225.4	52.3	51.8	0.645	248.0	52.8	52.3	0.649	269.6	53.3	52.7	0.653	90	72
90	73	238.3	52.4	51.9	0.610	262.2	52.9	52.4	0.613	285.2	53.4	52.9	0.616	90	73
90	74	251.5	52.4	52.1	0.577	276.9	53.0	52.6	0.580	301.2	53.5	53.1	0.582	90	74
90	75	265.0	52.5	52.2	0.547	291.8	53.1	52.8	0.549	317.5	53.7	53.3	0.551	90	75
90	76	278.9	52.6	52.4	0.519	307.1	53.2	52.9	0.521	334.2	53.8	53.5	0.523	90	76
90	77	293.0	52.7	52.5	0.494	322.7	53.4	53.1	0.495	351.3	53.9	53.7	0.496	90	77
90	78	307.4	52.8	52.7	0.470	338.7	53.5	53.3	0.471	368.7	54.1	53.9	0.471	90	78
90	79	322.2	52.9	52.9	0.448	355.0	53.6	53.5	0.448	386.6	54.2	54.1	0.448	90	79
90	80	337.3	53.1	53.1	0.427	371.8	53.7	53.7	0.427	404.8	54.4	54.3	0.427	90	80
90	81	352.9	53.3	53.3	0.407	388.9	53.9	53.9	0.407	423.5	54.6	54.6	0.407	90	81
90	82	368.7	53.5	53.5	0.388	406.4	54.2	54.2	0.387	442.6	54.8	54.8	0.387	90	82
90	83	384.9	53.7	53.7	0.370	424.3	54.4	54.4	0.369	462.2	55.1	55.1	0.369	90	83
90	84	401.5	53.9	53.9	0.354	442.7	54.6	54.6	0.352	482.2	55.3	55.3	0.351	90	84
90	85	418.5	54.1	54.1	0.338	461.4	54.9	54.9	0.336	502.7	55.6	55.6	0.335	90	85
90	86	435.9	54.3	54.3	0.323	480.7	55.1	55.1	0.321	523.7	55.9	55.9	0.320	90	86
90	87	453.7	54.5	54.5	0.309	500.4	55.4	55.4	0.307	545.2	56.1	56.1	0.305	90	87
95	67	173.9	50.9	49.9	0.966	192.6	51.1	50.2	0.972	210.7	51.4	50.4	0.977	95	67
95	68	182.1	51.4	50.5	0.915	201.3	51.7	50.8	0.921	219.8	52.0	51.1	0.927	95	68
95	69	191.6	51.7	50.9	0.864	211.5	52.1	51.3	0.871	230.6	52.5	51.6	0.877	95	69
95	70	202.1	52.0	51.2	0.816	222.8	52.4	51.6	0.822	242.8	52.8	52.0	0.828	95	70
95	71	213.4	52.2	51.5	0.770	235.1	52.7	51.9	0.776	255.9	53.1	52.3	0.782	95	71
95	72	225.3	52.4	51.7	0.728	248.1	52.9	52.2	0.733	270.0	53.4	52.6	0.738	95	72
95	73	237.8	52.5	51.9	0.688	261.8	53.1	52.4	0.693	284.9	53.6	52.9	0.697	95	73
95	74	250.9	52.6	52.0	0.651	276.2	53.2	52.6	0.655	300.5	53.7	53.1	0.659	95	74
95	75	264.4	52.7	52.2	0.618	291.2	53.3	52.7	0.621	316.8	53.8	53.3	0.624	95	75
95	76	278.2	52.8	52.3	0.587	306.4	53.4	52.9	0.589	333.5	54.0	53.5	0.592	95	76
95	77	292.4	52.9	52.5	0.558	322.0	53.5	53.1	0.560	350.5	54.1	53.7	0.562	95	77
95	78	306.8	53.0	52.7	0.531	338.0	53.7	53.3	0.533	367.9	54.3	53.9	0.534	95	78
95	79	321.6	53.1	52.9	0.506	354.3	53.8	53.5	0.507	385.7	54.4	54.1	0.509	95	79
95	80	336.7	53.2	53.0	0.483	371.0	53.9	53.7	0.484	404.0	54.6	54.3	0.485	95	80
95	81	352.2	53.4	53.2	0.461	388.1	54.1	53.9	0.462	422.7	54.7	54.6	0.462	95	81
95	82	368.0	53.5	53.4	0.441	405.6	54.2	54.1	0.441	441.7	54.9	54.8	0.441	95	82
95	83	384.2	53.6	53.6	0.421	423.6	54.4	54.4	0.421	461.3	55.1	55.0	0.421	95	83
95	84	400.8	53.8	53.8	0.403	441.9	54.6	54.6	0.402	481.4	55.3	55.3	0.402	95	84
95	85	417.8	54.1	54.1	0.385	460.7	54.8	54.8	0.384	501.9	55.6	55.6	0.384	95	85
95	86	435.2	54.3	54.3	0.368	479.9	55.1	55.1	0.367	522.8	55.8	55.8	0.367	95	86
95	87	453.0	54.5	54.5	0.352	499.6	55.3	55.3	0.351	544.3	56.1	56.1	0.350	95	87
95	88	471.2	54.7	54.7	0.337	519.7	55.6	55.6	0.336	566.3	56.4	56.4	0.335	95	88
95	89	489.9	55.0	55.0	0.323	540.4	55.9	55.9	0.322	588.8	56.7	56.7	0.320	95	89
95	90	509.1	55.2	55.2	0.310	561.5	56.2	56.2	0.308	611.9	57.0	57.0	0.307	95	90
95	91	528.7	55.5	55.5	0.297	583.2	56.4	56.4	0.295	635.5	57.3	57.3	0.293	95	91
95	92	548.8	55.8	55.8	0.285	605.4	56.7	56.7	0.283	659.8	57.6	57.6	0.281	95	92

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 67
Leaving Water = 51.67

AIR TEMP (°F)	EDB	EWB	3400 CFM (FPM = 453)				3800 CFM (FPM = 507)				4200 CFM (FPM = 560)				AIR TEMP (°F)	
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
100	69	195 6	51 3	50 3	0 948	216 5	51 7	50 6	0 954	236 7	52 0	50 9	0 960	100	69	
100	70	204 7	51 8	50 8	0 900	226 3	52 2	51 2	0 906	247 1	52 5	51 5	0 912	100	70	
100	71	215 1	52 1	51 2	0 853	237 4	52 5	51 6	0 859	258 9	52 9	51 9	0 865	100	71	
100	72	226 3	52 4	51 5	0 808	249 6	52 8	51 9	0 814	272 0	53 3	52 3	0 820	100	72	
100	73	238 3	52 6	51 8	0 765	262 6	53 1	52 2	0 771	286 0	53 6	52 7	0 776	100	73	
100	74	250 8	52 7	52 0	0 725	276 3	53 3	52 5	0 731	300 8	53 8	53 0	0 736	100	74	
100	75	263 9	52 9	52 2	0 688	290 6	53 5	52 7	0 693	316 4	54 0	53 2	0 698	100	75	
100	76	277 6	53 0	52 3	0 654	305 7	53 6	52 9	0 658	332 7	54 1	53 4	0 662	100	76	
100	77	291 7	53 1	52 5	0 622	321 3	53 7	53 1	0 625	349 8	54 3	53 6	0 628	100	77	
100	78	306 2	53 2	52 7	0 592	337 2	53 8	53 3	0 595	367 1	54 4	53 8	0 598	100	78	
100	79	320 9	53 3	52 8	0 564	353 6	54 0	53 5	0 567	385 0	54 6	54 1	0 569	100	79	
100	80	336 0	53 4	53 0	0 538	370 3	54 1	53 7	0 540	403 2	54 8	54 3	0 542	100	80	
100	81	351 5	53 5	53 2	0 514	387 4	54 2	53 9	0 516	421 9	54 9	54 5	0 517	100	81	
100	82	367 3	53 7	53 4	0 492	404 7	54 4	54 1	0 493	441 0	55 1	54 8	0 494	100	82	
100	83	383 5	53 8	53 6	0 470	422 8	54 5	54 3	0 471	460 5	55 3	55 0	0 472	100	83	
100	84	400 9	53 9	53 8	0 450	441 1	54 7	54 6	0 451	480 5	55 4	55 3	0 451	100	84	
100	85	417 1	54 1	54 0	0 432	459 9	54 9	54 8	0 432	501 0	55 6	55 5	0 432	100	85	
100	86	434 4	54 2	54 2	0 413	479 1	55 0	55 0	0 414	522 0	55 8	55 8	0 414	100	86	
100	87	452 2	54 5	54 5	0 396	498 7	55 3	55 3	0 396	543 4	56 1	56 1	0 396	100	87	
100	88	470 5	54 7	54 7	0 379	518 9	55 6	55 6	0 379	565 3	56 4	56 4	0 379	100	88	
100	89	489 2	55 0	55 0	0 364	539 5	55 8	55 8	0 363	587 9	56 7	56 7	0 362	100	89	
100	90	508 3	55 2	55 2	0 349	560 7	56 1	56 1	0 348	611 0	57 0	57 0	0 347	100	90	
100	91	527 9	55 5	55 5	0 335	582 3	56 4	56 4	0 333	634 5	57 3	57 3	0 332	100	91	
100	92	548 0	55 7	55 7	0 321	604 5	56 7	56 7	0 320	658 8	57 6	57 6	0 318	100	92	
100	93	568 5	56 0	56 0	0 308	627 2	57 0	57 0	0 307	683 5	57 9	57 9	0 305	100	93	
100	94	589 7	56 3	56 3	0 296	650 5	57 3	57 3	0 294	708 9	58 3	58 3	0 293	100	94	
100	95	611 2	56 6	56 6	0 284	674 4	57 7	57 7	0 282	735 0	58 6	58 6	0 280	100	95	
100	96	633 4	56 9	56 9	0 273	698 8	58 0	58 0	0 271	761 6	59 0	59 0	0 269	100	96	
100	97	656 1	57 2	57 2	0 262	723 9	58 3	58 3	0 260	788 9	59 4	59 4	0 258	100	97	
105	71	218 3	51 8	50 7	0 930	241 5	52 2	51 0	0 936	264 0	52 5	51 3	0 942	105	71	
105	72	228 5	52 2	51 2	0 884	252 4	52 6	51 5	0 890	275 6	53 0	51 9	0 896	105	72	
105	73	239 7	52 5	51 5	0 840	264 5	53 0	51 9	0 846	288 5	53 4	52 3	0 852	105	73	
105	74	251 6	52 7	51 8	0 798	277 5	53 3	52 3	0 804	302 5	53 7	52 7	0 809	105	74	
105	75	264 2	52 9	52 1	0 758	291 2	53 5	52 6	0 764	317 3	54 0	53 1	0 769	105	75	
105	76	277 4	53 1	52 3	0 721	305 7	53 7	52 8	0 726	332 9	54 3	53 4	0 731	105	76	
105	77	291 2	53 2	52 5	0 686	320 8	53 9	53 1	0 690	349 2	54 5	53 6	0 695	105	77	
105	78	305 5	53 3	52 6	0 653	336 6	54 0	53 2	0 657	366 4	54 6	53 8	0 661	105	78	
105	79	320 3	53 5	52 8	0 623	352 9	54 1	53 4	0 626	384 2	54 8	54 0	0 629	105	79	
105	80	335 4	53 6	53 0	0 594	369 6	54 3	53 6	0 597	402 4	54 9	54 3	0 600	105	80	
105	81	350 8	53 7	53 2	0 568	386 7	54 4	53 9	0 570	421 1	55 1	54 5	0 572	105	81	
105	82	366 6	53 8	53 4	0 543	404 1	54 6	54 1	0 545	440 1	55 3	54 7	0 547	105	82	
105	83	382 8	54 0	53 6	0 519	422 0	54 7	54 3	0 521	459 7	55 4	55 0	0 523	105	83	
105	84	399 3	54 1	53 8	0 497	440 3	54 9	54 5	0 499	479 6	55 6	55 2	0 500	105	84	
105	85	416 3	54 2	54 0	0 477	459 1	55 0	54 8	0 478	500 1	55 8	55 5	0 479	105	85	
105	86	433 7	54 4	54 2	0 457	478 2	55 2	55 0	0 458	521 1	56 0	55 8	0 458	105	86	
105	87	451 5	54 5	54 4	0 439	497 9	55 4	55 3	0 439	542 5	56 2	56 0	0 439	105	87	
105	88	469 7	54 7	54 7	0 421	518 0	55 6	55 5	0 421	564 5	56 4	56 3	0 421	105	88	
105	89	488 4	54 9	54 9	0 404	538 7	55 8	55 8	0 404	587 0	56 6	56 6	0 404	105	89	
105	90	507 5	55 2	55 2	0 388	559 8	56 1	56 1	0 387	610 0	56 9	56 9	0 387	105	90	
105	91	527 1	55 4	55 4	0 372	581 4	56 4	56 4	0 372	633 6	57 2	57 2	0 371	105	91	
105	92	547 2	55 7	55 7	0 357	603 6	56 7	56 7	0 357	657 8	57 6	57 6	0 356	105	92	
105	93	567 7	56 0	56 0	0 343	626 3	57 0	57 0	0 342	682 5	57 9	57 9	0 341	105	93	
105	94	588 8	56 3	56 3	0 330	649 6	57 3	57 3	0 329	708 0	58 2	58 2	0 328	105	94	
105	95	610 4	56 6	56 6	0 317	673 4	57 6	57 6	0 316	734 0	58 6	58 6	0 314	105	95	
105	96	632 5	56 9	56 9	0 305	697 8	57 9	57 9	0 303	760 6	59 0	59 0	0 302	105	96	
105	97	655 2	57 2	57 2	0 293	722 9	58 3	58 3	0 291	787 9	59 3	59 3	0 290	105	97	
105	98	678 5	57 5	57 5	0 282	748 5	58 6	58 6	0 280	815 9	59 7	59 7	0 278	105	98	
105	99	702 4	57 8	57 8	0 271	774 9	59 0	59 0	0 269	844 5	60 1	60 1	0 267	105	99	
105	100	726 8	58 2	58 2	0 261	801 8	59 4	59 4	0 259	873 9	60 5	60 5	0 256	105	100	
105	101	751 9	58 6	58 6	0 251	829 5	59 8	59 8	0 248	904 1	60 9	60 9	0 246	105	101	
105	102	777 6	58 9	58 9	0 241	857 8	60 2	60 2	0 239	935 0	61 4	61 4	0 237	105	102	

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 68
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	2500 CFM (FPM = 250)				3000 CFM (FPM = 300)				3500 CFM (FPM = 350)				AIR TEMP (F)	
			MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
75	59	72.10	48.6	48.1	1.000		85.73	48.9	48.2	1.000	99.17	49.1	48.3	1.000	75	59
75	60	77.86	48.7	48.4	0.923		91.81	49.0	48.7	0.931	105.5	49.2	48.9	0.938	75	60
75	61	83.68	49.0	48.8	0.850		98.37	49.3	49.0	0.858	112.7	49.6	49.3	0.865	75	61
75	62	90.55	49.2	48.9	0.782		106.2	49.5	49.3	0.789	121.4	49.8	49.6	0.796	75	62
75	63	98.18	49.3	49.0	0.721		115.1	49.6	49.4	0.727	131.4	50.0	49.7	0.733	75	63
75	64	106.3	49.3	49.1	0.666		124.7	49.7	49.5	0.671	142.3	50.0	49.8	0.676	75	64
75	65	114.9	49.2	49.0	0.618		134.8	49.6	49.5	0.622	153.8	50.0	49.9	0.626	75	65
75	66	123.6	49.2	49.0	0.576		145.1	49.6	49.5	0.579	165.7	50.0	49.9	0.581	75	66
75	67	132.5	49.2	49.1	0.539		155.6	49.6	49.5	0.541	177.9	50.1	49.9	0.542	75	67
75	68	141.5	49.1	49.1	0.505		166.3	49.6	49.5	0.506	190.2	50.1	50.0	0.508	75	68
75	69	150.7	49.1	49.1	0.475		177.3	49.6	49.6	0.476	202.8	50.1	50.0	0.476	75	69
75	70	160.1	49.1	49.1	0.448		188.4	49.6	49.6	0.448	215.7	50.1	50.1	0.448	75	70
75	71	169.7	49.2	49.2	0.423		199.8	49.7	49.7	0.422	228.8	50.2	50.2	0.422	75	71
75	72	179.5	49.2	49.2	0.400		211.4	49.7	49.7	0.399	242.2	50.2	50.2	0.398	75	72
80	61	87.92	48.4	48.0	0.983		104.2	48.6	48.2	0.990	117.9	49.2	48.6	1.000	80	61
80	62	93.05	48.8	48.5	0.917		109.8	49.1	48.7	0.925	126.2	49.3	48.9	0.931	80	62
80	63	99.49	49.1	48.7	0.852		117.1	49.4	49.1	0.859	134.3	49.7	49.3	0.866	80	63
80	64	106.8	49.2	48.9	0.791		125.5	49.6	49.3	0.798	143.7	49.9	49.6	0.804	80	64
80	65	114.8	49.3	49.0	0.736		134.8	49.7	49.4	0.742	154.1	50.1	49.8	0.747	80	65
80	66	123.2	49.3	49.0	0.686		144.7	49.7	49.5	0.691	165.4	50.1	49.9	0.696	80	66
80	67	132.1	49.3	49.0	0.641		155.1	49.7	49.5	0.645	177.3	50.2	49.9	0.649	80	67
80	68	141.1	49.2	49.1	0.601		165.8	49.7	49.5	0.604	189.7	50.2	50.0	0.607	80	68
80	69	150.3	49.2	49.1	0.566		176.8	49.7	49.6	0.568	202.2	50.2	50.0	0.570	80	69
80	70	159.7	49.2	49.1	0.533		187.9	49.7	49.6	0.535	215.1	50.2	50.1	0.536	80	70
80	71	169.3	49.2	49.1	0.504		199.3	49.7	49.7	0.505	228.2	50.2	50.2	0.506	80	71
80	72	179.1	49.2	49.2	0.477		210.9	49.8	49.7	0.478	241.6	50.3	50.2	0.478	80	72
80	73	189.1	49.2	49.2	0.453		222.7	49.8	49.8	0.453	255.3	50.3	50.3	0.453	80	73
80	74	199.3	49.3	49.3	0.429		234.8	49.8	49.8	0.429	269.2	50.4	50.4	0.429	80	74
80	75	209.7	49.3	49.3	0.408		247.2	49.9	49.9	0.407	283.5	50.5	50.5	0.407	80	75
80	76	220.4	49.4	49.4	0.388		259.9	50.0	50.0	0.387	298.1	50.6	50.6	0.386	80	76
80	77	231.3	49.4	49.4	0.370		272.9	50.1	50.1	0.368	313.1	50.6	50.6	0.367	80	77
85	63	102.8	48.6	48.1	0.969		121.7	48.8	48.4	0.976	140.4	49.0	48.6	0.981	85	63
85	64	108.7	49.0	48.5	0.908		128.4	49.3	48.8	0.915	147.6	49.5	49.1	0.922	85	64
85	65	115.8	49.2	48.8	0.849		136.4	49.5	49.1	0.856	156.5	49.9	49.4	0.863	85	65
85	66	123.6	49.3	48.9	0.794		145.4	49.7	49.3	0.801	166.6	50.1	49.7	0.807	85	66
85	67	131.9	49.3	49.0	0.744		155.1	49.8	49.4	0.749	177.6	50.2	49.8	0.755	85	67
85	68	140.7	49.4	49.1	0.698		165.4	49.8	49.5	0.703	189.3	50.3	49.9	0.707	85	68
85	69	149.9	49.3	49.1	0.656		176.3	49.8	49.6	0.660	201.7	50.3	50.0	0.664	85	69
85	70	159.3	49.3	49.1	0.619		187.4	49.9	49.6	0.622	214.5	50.3	50.1	0.625	85	70
85	71	168.8	49.3	49.1	0.584		198.7	49.9	49.7	0.587	227.6	50.4	50.1	0.589	85	71
85	72	178.6	49.3	49.2	0.553		210.3	49.9	49.7	0.555	241.0	50.4	50.2	0.557	85	72
85	73	188.6	49.3	49.2	0.525		222.2	49.9	49.8	0.526	254.6	50.4	50.3	0.527	85	73
85	74	198.8	49.3	49.2	0.498		234.3	49.9	49.8	0.499	268.6	50.5	50.4	0.500	85	74
85	75	209.2	49.3	49.3	0.474		246.7	49.9	49.9	0.475	282.9	50.5	50.4	0.475	85	75
85	76	219.9	49.4	49.4	0.452		259.3	50.0	50.0	0.452	297.5	50.6	50.5	0.452	85	76
85	77	230.8	49.4	49.4	0.430		272.3	50.0	50.0	0.430	312.4	50.6	50.6	0.430	85	77
85	78	241.9	49.5	49.5	0.411		285.5	50.1	50.1	0.410	327.7	50.7	50.7	0.409	85	78
85	79	253.4	49.5	49.5	0.392		299.0	50.2	50.2	0.391	343.3	50.8	50.8	0.390	85	79
85	80	265.0	49.6	49.6	0.375		312.9	50.3	50.3	0.373	359.3	50.9	50.9	0.372	85	80
85	81	277.0	49.7	49.7	0.358		327.1	50.4	50.4	0.357	375.6	51.1	51.1	0.356	85	81
85	82	289.3	49.8	49.8	0.343		341.6	50.5	50.5	0.341	392.3	51.2	51.2	0.340	85	82

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 68
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	AIRFLOW								AIR TEMP. (F)				
			2500 CFM (FPM = 250)				3000 CFM (FPM = 300)				3500 CFM (FPM = 350)				
MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR				
90	65	118.3	48.8	48.3	0.954	140.0	49.1	48.5	0.960	161.4	49.3	48.8	0.966	90	65
90	66	125.0	49.1	48.6	0.897	147.6	49.4	48.9	0.904	169.7	49.7	49.2	0.910	90	66
90	67	132.6	49.3	48.8	0.843	156.3	49.7	49.2	0.850	179.4	50.0	49.5	0.856	90	67
90	68	140.9	49.4	48.9	0.793	165.9	49.8	49.4	0.799	190.2	50.2	49.8	0.805	90	68
90	69	149.6	49.4	49.0	0.746	176.2	49.9	49.5	0.752	201.9	50.3	49.9	0.757	90	69
90	70	158.8	49.4	49.1	0.704	187.0	49.9	49.6	0.708	214.2	50.4	50.0	0.713	90	70
90	71	168.4	49.4	49.1	0.665	198.2	50.0	49.6	0.669	227.0	50.5	50.1	0.673	90	71
90	72	178.2	49.4	49.2	0.629	209.8	50.0	49.7	0.633	240.4	50.5	50.2	0.636	90	72
90	73	188.1	49.4	49.2	0.597	221.6	50.0	49.7	0.599	254.0	50.5	50.3	0.602	90	73
90	74	198.3	49.4	49.2	0.567	233.7	50.0	49.8	0.569	268.0	50.6	50.3	0.571	90	74
90	75	208.7	49.4	49.3	0.539	246.1	50.1	49.9	0.541	282.2	50.6	50.4	0.542	90	75
90	76	219.4	49.5	49.3	0.514	258.7	50.1	49.9	0.515	296.8	50.7	50.5	0.516	90	76
90	77	230.3	49.5	49.4	0.490	271.7	50.1	50.0	0.491	311.7	50.7	50.6	0.491	90	77
90	78	241.4	49.5	49.5	0.468	284.9	50.1	50.1	0.468	327.0	50.8	50.7	0.469	90	78
90	79	252.8	49.5	49.5	0.447	298.4	50.2	50.2	0.447	342.6	50.8	50.8	0.447	90	79
90	80	264.5	49.6	49.6	0.428	312.3	50.3	50.3	0.427	358.5	50.9	50.9	0.427	90	80
90	81	276.5	49.7	49.7	0.409	326.4	50.4	50.4	0.409	374.9	51.0	51.0	0.408	90	81
90	82	288.7	49.7	49.7	0.392	340.9	50.5	50.5	0.391	391.6	51.2	51.2	0.390	90	82
90	83	301.2	49.8	49.8	0.376	355.8	50.6	50.6	0.374	408.7	51.3	51.3	0.373	90	83
90	84	314.0	49.9	49.9	0.360	371.0	50.7	50.7	0.359	426.3	51.4	51.4	0.357	90	84
90	85	327.2	50.0	50.0	0.346	386.6	50.8	50.8	0.344	444.2	51.6	51.6	0.342	90	85
90	86	340.6	50.1	50.1	0.332	402.5	50.9	50.9	0.330	462.6	51.7	51.7	0.328	90	86
90	87	354.4	50.2	50.2	0.319	418.9	51.0	51.0	0.317	481.4	51.8	51.8	0.315	90	87
95	67	134.4	49.0	48.4	0.937	159.1	49.3	48.7	0.943	183.3	49.6	49.0	0.949	95	67
95	68	141.9	49.2	48.7	0.885	167.6	49.6	49.1	0.891	192.7	50.0	49.4	0.897	95	68
95	69	150.1	49.4	48.9	0.835	177.0	49.8	49.3	0.841	203.3	50.2	49.7	0.847	95	69
95	70	158.9	49.5	49.0	0.788	187.3	49.9	49.5	0.794	214.8	50.4	49.9	0.800	95	70
95	71	168.1	49.5	49.1	0.745	198.1	50.0	49.6	0.750	227.1	50.5	50.0	0.755	95	71
95	72	177.7	49.5	49.1	0.706	209.4	50.1	49.7	0.710	240.0	50.6	50.2	0.715	95	72
95	73	187.7	49.5	49.2	0.669	221.1	50.1	49.7	0.673	253.4	50.7	50.3	0.677	95	73
95	74	197.8	49.5	49.2	0.636	233.2	50.1	49.8	0.639	267.3	50.7	50.3	0.642	95	74
95	75	208.3	49.6	49.3	0.605	245.5	50.2	49.9	0.607	281.6	50.7	50.4	0.610	95	75
95	76	218.9	49.6	49.3	0.576	258.2	50.2	49.9	0.578	296.1	50.8	50.5	0.580	95	76
95	77	229.8	49.6	49.4	0.549	271.1	50.2	50.0	0.551	311.0	50.8	50.6	0.553	95	77
95	78	240.9	49.6	49.4	0.525	284.3	50.3	50.1	0.526	326.3	50.9	50.7	0.527	95	78
95	79	252.3	49.6	49.5	0.502	297.8	50.3	50.2	0.502	341.9	50.9	50.8	0.503	95	79
95	80	264.0	49.6	49.6	0.480	311.6	50.3	50.3	0.481	357.8	51.0	50.9	0.481	95	80
95	81	275.9	49.7	49.6	0.460	325.8	50.4	50.4	0.460	374.1	51.1	51.0	0.460	95	81
95	82	288.1	49.7	49.7	0.441	340.3	50.4	50.4	0.441	390.8	51.1	51.1	0.441	95	82
95	83	300.6	49.8	49.8	0.422	355.1	50.6	50.6	0.422	408.0	51.3	51.3	0.422	95	83
95	84	313.5	49.9	49.9	0.405	370.3	50.7	50.7	0.404	425.5	51.4	51.4	0.404	95	84
95	85	326.6	50.0	50.0	0.389	385.9	50.8	50.8	0.388	443.4	51.5	51.5	0.387	95	85
95	86	340.0	50.1	50.1	0.373	401.8	50.9	50.9	0.372	461.8	51.7	51.7	0.371	95	86
95	87	353.8	50.2	50.2	0.359	418.2	51.0	51.0	0.357	480.6	51.8	51.8	0.356	95	87
95	88	367.9	50.3	50.3	0.345	434.9	51.1	51.1	0.343	499.9	52.0	52.0	0.342	95	88
95	89	382.4	50.4	50.4	0.332	452.0	51.3	51.3	0.330	519.6	52.1	52.1	0.328	95	89
95	90	397.2	50.5	50.5	0.319	469.6	51.4	51.4	0.317	539.9	52.3	52.3	0.316	95	90
95	91	412.4	50.6	50.6	0.307	487.6	51.6	51.6	0.305	560.6	52.5	52.5	0.303	95	91
95	92	428.0	50.7	50.7	0.296	506.1	51.7	51.7	0.294	581.9	52.6	52.6	0.292	95	92

**MIL-PRF-2939G(SH)
w/AMENDMENT 2**
APPENDIX A
DW COIL PERFORMANCE CHART
Entering Water = 45
Coil Size: DW 68
Leaving Water = 51.67

AIR TEMP (°F)		AIRFLOW								AIR TEMP (°F)					
		2500 CFM (FPM = 250)				3000 CFM (FPM = 300)									
EDB	EWB	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB
100	69	151.4	49.2	48.6	0.920	179.1	49.6	48.9	0.926	206.3	49.9	49.3	0.932	100	69
100	70	159.6	49.4	48.8	0.871	188.5	49.8	49.2	0.877	216.7	50.2	49.6	0.883	100	70
100	71	168.3	49.5	49.0	0.824	198.6	50.0	49.4	0.830	228.2	50.4	49.8	0.836	100	71
100	72	177.6	49.6	49.1	0.781	209.5	50.1	49.6	0.787	240.4	50.6	50.0	0.792	100	72
100	73	187.3	49.6	49.2	0.741	220.8	50.2	49.7	0.746	253.4	50.7	50.2	0.751	100	73
100	74	197.4	49.6	49.2	0.704	232.7	50.2	49.8	0.708	266.9	50.8	50.3	0.713	100	74
100	75	207.8	49.7	49.3	0.670	245.0	50.3	49.8	0.674	280.9	50.8	50.4	0.677	100	75
100	76	218.4	49.7	49.3	0.638	257.6	50.3	49.9	0.641	295.5	50.9	50.5	0.644	100	76
100	77	229.3	49.7	49.4	0.609	270.5	50.3	50.0	0.611	310.4	50.9	50.6	0.614	100	77
100	78	240.4	49.7	49.4	0.581	283.7	50.4	50.1	0.583	325.6	51.0	50.7	0.585	100	78
100	79	251.8	49.7	49.5	0.556	297.2	50.4	50.2	0.557	341.2	51.1	50.8	0.559	100	79
100	80	263.4	49.7	49.6	0.532	311.0	50.4	50.2	0.533	357.1	51.1	50.9	0.534	100	80
100	81	275.4	49.8	49.6	0.510	325.2	50.5	50.3	0.510	373.4	51.2	51.0	0.511	100	81
100	82	287.6	49.8	49.7	0.489	339.6	50.5	50.4	0.489	390.1	51.2	51.1	0.490	100	82
100	83	300.1	49.8	49.8	0.469	354.5	50.6	50.5	0.469	407.2	51.3	51.2	0.469	100	83
100	84	312.9	49.9	49.9	0.450	369.6	50.6	50.6	0.450	424.7	51.4	51.4	0.450	100	84
100	85	326.0	50.0	50.0	0.432	385.2	50.7	50.7	0.432	442.6	51.5	51.5	0.432	100	85
100	86	339.4	50.1	50.1	0.415	401.1	50.9	50.9	0.414	461.0	51.6	51.6	0.414	100	86
100	87	353.2	50.1	50.1	0.399	417.4	51.0	51.0	0.398	479.8	51.8	51.8	0.397	100	87
100	88	367.3	50.2	50.2	0.384	434.2	51.1	51.1	0.383	499.1	51.9	51.9	0.382	100	88
100	89	381.7	50.4	50.4	0.369	451.3	51.2	51.2	0.368	518.8	52.1	52.1	0.367	100	89
100	90	396.5	50.5	50.5	0.355	468.9	51.4	51.4	0.354	539.0	52.3	52.3	0.353	100	90
100	91	411.7	50.6	50.6	0.342	486.8	51.5	51.5	0.341	559.7	52.4	52.4	0.339	100	91
100	92	427.3	50.7	50.7	0.330	505.3	51.7	51.7	0.328	581.0	52.6	52.6	0.326	100	92
100	93	443.2	50.8	50.8	0.318	524.2	51.8	51.8	0.316	602.8	52.8	52.8	0.314	100	93
100	94	459.6	51.0	51.0	0.306	543.6	52.0	52.0	0.304	625.1	53.0	53.0	0.302	100	94
100	95	476.4	51.1	51.1	0.295	563.4	52.2	52.2	0.293	647.9	53.2	53.2	0.291	100	95
100	96	493.6	51.2	51.2	0.285	583.8	52.3	52.3	0.283	671.4	53.4	53.4	0.280	100	96
100	97	511.2	51.4	51.4	0.275	604.7	52.5	52.5	0.273	695.4	53.6	53.6	0.270	100	97
105	71	169.2	49.4	48.7	0.901	200.1	49.8	49.1	0.907	230.4	50.2	49.5	0.913	105	71
105	72	178.0	49.5	48.9	0.856	210.3	50.0	49.4	0.862	241.8	50.5	49.8	0.867	105	72
105	73	187.4	49.6	49.1	0.813	221.2	50.2	49.5	0.818	254.1	50.6	50.0	0.824	105	73
105	74	197.2	49.7	49.2	0.773	232.7	50.3	49.7	0.778	267.1	50.8	50.2	0.783	105	74
105	75	207.4	49.7	49.2	0.735	244.6	50.3	49.8	0.740	280.8	50.9	50.3	0.744	105	75
105	76	217.9	49.8	49.3	0.700	257.0	50.4	49.9	0.704	295.0	51.0	50.5	0.708	105	76
105	77	228.8	49.8	49.4	0.668	269.9	50.4	50.0	0.672	309.7	51.1	50.6	0.675	105	77
105	78	239.9	49.8	49.4	0.638	283.1	50.5	50.1	0.641	324.9	51.1	50.7	0.644	105	78
105	79	251.3	49.8	49.5	0.610	296.6	50.5	50.1	0.612	340.5	51.2	50.8	0.615	105	79
105	80	262.9	49.8	49.5	0.584	310.4	50.6	50.2	0.586	356.4	51.2	50.9	0.588	105	80
105	81	274.8	49.9	49.6	0.559	324.5	50.6	50.3	0.561	372.7	51.3	51.0	0.562	105	81
105	82	287.0	49.9	49.7	0.536	339.0	50.6	50.4	0.537	389.4	51.4	51.1	0.539	105	82
105	83	299.5	49.9	49.8	0.514	353.8	50.7	50.5	0.515	406.4	51.4	51.2	0.516	105	83
105	84	312.3	50.0	49.9	0.494	369.0	50.8	50.6	0.494	423.9	51.5	51.3	0.495	105	84
105	85	325.4	50.0	49.9	0.475	384.5	50.8	50.7	0.475	441.8	51.6	51.5	0.475	105	85
105	86	338.8	50.0	50.0	0.456	400.4	50.9	50.8	0.456	460.2	51.7	51.6	0.457	105	86
105	87	352.6	50.1	50.1	0.439	416.7	51.0	51.0	0.439	479.0	51.8	51.8	0.439	105	87
105	88	366.7	50.2	50.2	0.422	433.4	51.1	51.1	0.422	498.2	51.9	51.9	0.421	105	88
105	89	381.1	50.3	50.3	0.406	450.6	51.2	51.2	0.406	518.0	52.1	52.1	0.405	105	89
105	90	395.9	50.4	50.4	0.391	468.1	51.4	51.4	0.390	538.2	52.2	52.2	0.390	105	90
105	91	411.1	50.6	50.6	0.377	486.1	51.5	51.5	0.376	558.9	52.4	52.4	0.375	105	91
105	92	426.6	50.7	50.7	0.363	504.5	51.6	51.6	0.362	580.1	52.6	52.6	0.361	105	92
105	93	442.6	50.8	50.8	0.350	523.4	51.8	51.8	0.348	601.9	52.8	52.8	0.347	105	93
105	94	458.9	50.9	50.9	0.337	542.8	52.0	52.0	0.336	624.1	53.0	53.0	0.334	105	94
105	95	475.7	51.1	51.1	0.326	562.6	52.1	52.1	0.324	647.0	53.1	53.1	0.322	105	95
105	96	492.9	51.2	51.2	0.314	583.0	52.3	52.3	0.312	670.4	53.4	53.4	0.310	105	96
105	97	510.5	51.4	51.4	0.303	603.8	52.5	52.5	0.301	694.5	53.6	53.6	0.299	105	97
105	98	528.6	51.5	51.5	0.293	625.3	52.7	52.7	0.291	719.1	53.8	53.8	0.289	105	98
105	99	547.1	51.7	51.7	0.283	647.2	52.9	52.9	0.280	744.4	54.0	54.0	0.278	105	99
105	100	566.1	51.9	51.9	0.273	669.7	53.1	53.1	0.271	770.3	54.3	54.3	0.268	105	100
105	101	585.7	52.0	52.0	0.264	692.8	53.3	53.3	0.261	796.9	54.5	54.5	0.259	105	101
105	102	605.7	52.2	52.2	0.255	716.5	53.5	53.5	0.252	824.1	54.8	54.8	0.250	105	102

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 68
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	AIRFLOW								AIR TEMP. (F)				
			4000 CFM (FPM = 400)				4500 CFM (FPM = 450)				5000 CFM (FPM = 500)				
MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR				
75	59	112.4	49.3	48.4	1.000	125.5	49.5	48.5	1.000	138.5	49.7	48.6	1.000	75	59
75	60	118.8	49.4	49.0	0.945	131.9	49.5	49.2	0.951	144.8	49.7	49.3	0.957	75	60
75	61	126.6	49.8	49.5	0.872	140.2	50.0	49.7	0.879	153.5	50.2	49.9	0.885	75	61
75	62	136.2	50.1	49.8	0.802	150.6	50.4	50.1	0.808	164.6	50.6	50.3	0.814	75	62
75	63	147.2	50.3	50.0	0.738	162.5	50.6	50.3	0.744	177.5	50.8	50.5	0.749	75	63
75	64	159.3	50.4	50.1	0.680	175.8	50.7	50.4	0.685	191.8	51.0	50.7	0.689	75	64
75	65	172.3	50.4	50.2	0.629	190.1	50.7	50.5	0.633	207.3	51.1	50.8	0.636	75	65
75	66	185.7	50.4	50.3	0.584	205.0	50.8	50.6	0.587	223.7	51.1	50.9	0.589	75	66
75	67	199.4	50.4	50.3	0.544	220.2	50.8	50.7	0.546	240.5	51.2	51.0	0.548	75	67
75	68	213.3	50.5	50.4	0.509	235.8	50.9	50.8	0.510	257.5	51.2	51.1	0.511	75	68
75	69	227.6	50.5	50.5	0.477	251.6	50.9	50.8	0.477	274.9	51.3	51.2	0.478	75	69
75	70	242.1	50.5	50.5	0.448	267.7	51.0	50.9	0.448	292.6	51.3	51.3	0.448	75	70
75	71	256.9	50.6	50.6	0.422	284.2	51.0	51.0	0.421	310.8	51.4	51.4	0.421	75	71
75	72	272.1	50.7	50.7	0.397	301.1	51.1	51.1	0.397	329.3	51.5	51.5	0.396	75	72
80	61	133.7	49.4	48.7	1.000	149.4	49.7	48.8	1.000	164.9	49.9	48.9	1.000	80	61
80	62	142.3	49.6	49.1	0.938	158.1	49.8	49.3	0.943	173.6	49.9	49.5	0.949	80	62
80	63	151.0	50.0	49.6	0.873	167.4	50.2	49.8	0.879	183.4	50.4	50.0	0.885	80	63
80	64	161.3	50.2	49.9	0.810	178.6	50.5	50.1	0.816	195.4	50.8	50.4	0.822	80	64
80	65	172.9	50.4	50.1	0.753	191.2	50.7	50.4	0.758	209.0	51.0	50.7	0.763	80	65
80	66	185.5	50.5	50.2	0.700	204.9	50.8	50.5	0.705	223.9	51.2	50.8	0.709	80	66
80	67	198.8	50.6	50.3	0.653	219.6	50.9	50.7	0.657	239.8	51.3	51.0	0.660	80	67
80	68	212.7	50.6	50.4	0.610	235.1	51.0	50.7	0.613	256.7	51.3	51.1	0.616	80	68
80	69	226.9	50.6	50.4	0.572	250.9	51.0	50.8	0.575	274.1	51.4	51.2	0.577	80	69
80	70	241.4	50.7	50.5	0.538	267.0	51.1	50.9	0.540	291.8	51.5	51.3	0.541	80	70
80	71	256.3	50.7	50.6	0.507	283.5	51.1	51.0	0.508	309.9	51.5	51.4	0.509	80	71
80	72	271.4	50.8	50.7	0.479	300.3	51.2	51.1	0.479	328.4	51.6	51.5	0.480	80	72
80	73	286.8	50.8	50.8	0.453	317.5	51.3	51.2	0.453	347.3	51.7	51.7	0.453	80	73
80	74	302.6	50.9	50.9	0.429	335.0	51.3	51.3	0.429	366.6	51.8	51.8	0.428	80	74
80	75	318.8	51.0	51.0	0.406	353.0	51.5	51.5	0.406	386.3	51.9	51.9	0.405	80	75
80	76	335.3	51.1	51.1	0.385	371.4	51.6	51.6	0.385	406.5	52.1	52.1	0.384	80	76
80	77	352.1	51.2	51.2	0.366	390.1	51.7	51.7	0.365	427.1	52.2	52.2	0.364	80	77
85	63	158.7	49.2	48.7	0.987	176.8	49.4	48.9	0.992	191.3	50.0	49.3	1.000	85	63
85	64	166.4	49.8	49.3	0.928	184.9	50.0	49.5	0.934	203.0	50.2	49.7	0.939	85	64
85	65	176.1	50.1	49.7	0.869	195.3	50.4	49.9	0.875	214.1	50.7	50.2	0.880	85	65
85	66	187.2	50.4	50.0	0.812	207.3	50.7	50.3	0.818	227.0	51.0	50.5	0.823	85	66
85	67	199.4	50.6	50.2	0.760	220.7	50.9	50.5	0.765	241.4	51.2	50.8	0.770	85	67
85	68	212.5	50.7	50.3	0.712	235.0	51.0	50.7	0.716	257.0	51.4	51.0	0.721	85	68
85	69	226.3	50.7	50.4	0.668	250.3	51.1	50.8	0.672	273.6	51.5	51.2	0.675	85	69
85	70	240.8	50.8	50.5	0.628	266.3	51.2	50.9	0.631	291.0	51.6	51.3	0.634	85	70
85	71	255.6	50.8	50.6	0.592	282.7	51.3	51.0	0.594	309.1	51.7	51.4	0.597	85	71
85	72	270.7	50.9	50.7	0.559	299.5	51.3	51.1	0.561	327.6	51.7	51.5	0.562	85	72
85	73	286.1	50.9	50.8	0.529	316.7	51.4	51.2	0.530	346.5	51.8	51.6	0.531	85	73
85	74	301.9	51.0	50.9	0.501	334.3	51.5	51.3	0.502	365.7	51.9	51.8	0.503	85	74
85	75	318.0	51.0	51.0	0.475	352.2	51.5	51.4	0.476	385.4	52.0	51.9	0.477	85	75
85	76	334.5	51.1	51.1	0.452	370.5	51.6	51.6	0.452	405.6	52.1	52.0	0.452	85	76
85	77	351.4	51.2	51.2	0.430	389.3	51.7	51.7	0.430	426.2	52.2	52.2	0.430	85	77
85	78	368.6	51.3	51.3	0.409	408.5	51.8	51.8	0.409	447.2	52.3	52.3	0.408	85	78
85	79	386.3	51.4	51.4	0.389	428.1	52.0	52.0	0.389	468.8	52.5	52.5	0.388	85	79
85	80	404.3	51.6	51.6	0.371	448.1	52.1	52.1	0.370	490.8	52.7	52.7	0.370	85	80
85	81	422.8	51.7	51.7	0.354	468.7	52.3	52.3	0.353	513.4	52.8	52.8	0.352	85	81
85	82	441.7	51.8	51.8	0.338	489.7	52.4	52.4	0.337	536.5	53.0	53.0	0.336	85	82

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 68
Leaving Water = 51.67

AIR TEMP. (F)	EDB	EWB	AIRFLOW								AIR TEMP. (F)				
			4000 CFM (FPM = 400)				4500 CFM (FPM = 450)				5000 CFM (FPM = 500)				
MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	EDB	EWB		
90	65	182.4	49.6	49.0	0.971	203.1	49.8	49.2	0.976	223.5	50.0	49.3	0.981	90	65
90	66	191.3	50.0	49.5	0.916	212.6	50.3	49.7	0.922	233.5	50.5	49.9	0.927	90	66
90	67	202.0	50.4	49.8	0.862	224.1	50.7	50.1	0.868	245.7	50.9	50.4	0.873	90	67
90	68	213.9	50.6	50.1	0.810	237.1	50.9	50.4	0.816	259.7	51.2	50.7	0.821	90	68
90	69	226.9	50.7	50.3	0.762	251.2	51.1	50.7	0.767	274.9	51.5	51.0	0.772	90	69
90	70	240.6	50.9	50.4	0.717	266.3	51.3	50.8	0.722	291.3	51.6	51.2	0.726	90	70
90	71	255.0	50.9	50.6	0.677	282.1	51.4	51.0	0.680	308.6	51.8	51.4	0.684	90	71
90	72	270.0	51.0	50.7	0.639	298.8	51.4	51.1	0.642	326.8	51.9	51.5	0.645	90	72
90	73	285.4	51.0	50.8	0.605	315.9	51.5	51.2	0.607	345.6	51.9	51.6	0.610	90	73
90	74	301.2	51.1	50.8	0.573	333.5	51.6	51.3	0.575	364.9	52.0	51.8	0.577	90	74
90	75	317.3	51.2	50.9	0.544	351.4	51.7	51.4	0.545	384.6	52.1	51.9	0.547	90	75
90	76	333.8	51.2	51.1	0.517	369.7	51.7	51.6	0.518	404.7	52.2	52.0	0.519	90	76
90	77	350.6	51.3	51.2	0.492	388.4	51.8	51.7	0.493	425.3	52.3	52.2	0.494	90	77
90	78	367.8	51.4	51.3	0.469	407.6	51.9	51.8	0.469	446.3	52.4	52.3	0.470	90	78
90	79	385.5	51.4	51.4	0.447	427.2	52.0	52.0	0.448	467.8	52.5	52.5	0.448	90	79
90	80	403.5	51.5	51.5	0.427	447.2	52.1	52.1	0.427	489.9	52.6	52.6	0.427	90	80
90	81	422.0	51.7	51.7	0.408	467.8	52.3	52.3	0.407	512.4	52.8	52.8	0.407	90	81
90	82	440.8	51.8	51.8	0.389	488.8	52.4	52.4	0.389	535.5	53.0	53.0	0.388	90	82
90	83	460.2	52.0	52.0	0.372	510.3	52.6	52.6	0.372	559.1	53.2	53.2	0.371	90	83
90	84	480.0	52.1	52.1	0.356	532.3	52.8	52.8	0.355	583.3	53.4	53.4	0.354	90	84
90	85	500.3	52.3	52.3	0.341	554.8	52.9	52.9	0.340	608.0	53.6	53.6	0.339	90	85
90	86	521.0	52.4	52.4	0.327	577.9	53.1	53.1	0.325	633.4	53.8	53.8	0.324	90	86
90	87	542.3	52.6	52.6	0.313	601.5	53.3	53.3	0.312	659.3	54.0	54.0	0.310	90	87
95	67	207.1	49.9	49.3	0.955	230.5	50.1	49.5	0.960	253.6	50.3	49.7	0.964	95	67
95	68	217.3	50.3	49.7	0.903	241.4	50.6	50.0	0.908	265.1	50.9	50.2	0.914	95	68
95	69	228.9	50.6	50.0	0.853	254.0	50.9	50.3	0.858	278.6	51.2	50.6	0.863	95	69
95	70	241.7	50.8	50.3	0.805	267.9	51.2	50.6	0.810	293.6	51.5	50.9	0.815	95	70
95	71	255.3	50.9	50.5	0.760	282.9	51.3	50.8	0.765	309.8	51.7	51.2	0.770	95	71
95	72	269.7	51.1	50.6	0.719	298.7	51.5	51.0	0.723	327.0	51.9	51.4	0.727	95	72
95	73	284.8	51.1	50.7	0.680	315.3	51.6	51.2	0.684	345.0	52.0	51.6	0.688	95	73
95	74	300.5	51.2	50.8	0.645	332.7	51.7	51.3	0.648	364.0	52.1	51.7	0.651	95	74
95	75	316.6	51.3	50.9	0.612	350.6	51.8	51.4	0.615	383.7	52.2	51.9	0.618	95	75
95	76	333.0	51.3	51.0	0.582	368.9	51.8	51.5	0.584	403.8	52.3	52.0	0.586	95	76
95	77	349.8	51.4	51.1	0.554	387.6	51.9	51.7	0.556	424.3	52.4	52.2	0.558	95	77
95	78	367.1	51.5	51.3	0.528	406.7	52.0	51.8	0.530	445.4	52.5	52.3	0.531	95	78
95	79	384.7	51.5	51.4	0.504	426.3	52.1	51.9	0.505	466.9	52.7	52.5	0.506	95	79
95	80	402.7	51.6	51.5	0.481	446.4	52.2	52.1	0.482	488.9	52.8	52.6	0.483	95	80
95	81	421.1	51.7	51.6	0.460	466.9	52.3	52.2	0.461	511.4	52.9	52.8	0.461	95	81
95	82	440.0	51.8	51.8	0.441	487.9	52.4	52.4	0.441	534.5	53.0	53.0	0.441	95	82
95	83	459.3	51.9	51.9	0.421	509.3	52.6	52.6	0.421	558.1	53.2	53.2	0.421	95	83
95	84	479.1	52.1	52.1	0.403	531.3	52.7	52.7	0.403	582.2	53.3	53.3	0.403	95	84
95	85	499.4	52.2	52.2	0.386	553.9	52.9	52.9	0.386	607.0	53.5	53.5	0.385	95	85
95	86	520.1	52.4	52.4	0.370	576.9	53.1	53.1	0.369	632.3	53.7	53.7	0.369	95	86
95	87	541.4	52.6	52.6	0.355	600.5	53.3	53.3	0.354	658.2	54.0	54.0	0.353	95	87
95	88	563.1	52.7	52.7	0.341	624.7	53.5	53.5	0.339	684.8	54.2	54.2	0.338	95	88
95	89	585.4	52.9	52.9	0.327	649.5	53.7	53.7	0.326	712.0	54.4	54.4	0.324	95	89
95	90	608.3	53.1	53.1	0.314	674.9	53.9	53.9	0.312	739.8	54.6	54.6	0.311	95	90
95	91	631.7	53.3	53.3	0.302	700.9	54.1	54.1	0.300	768.4	54.9	54.9	0.298	95	91
95	92	655.6	53.5	53.5	0.290	727.5	54.3	54.3	0.288	797.6	55.1	55.1	0.286	95	92

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART
Entering Water = 45

Coil Size: DW 68
Leaving Water = 51.67

AIR TEMP (°F)				AIRFLOW								AIR TEMP (°F)			
EDB	EWB	4000 CFM (FPM = 400)				4500 CFM (FPM = 450)				5000 CFM (FPM = 500)				EDB	EWB
		MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR	MBH	LDB	LWB	SHR		
100	69	233.0	50.2	49.5	0.937	259.3	50.5	49.8	0.942	285.1	50.8	50.0	0.947	100	69
100	70	244.3	50.6	49.9	0.888	271.4	50.9	50.2	0.894	298.0	51.2	50.5	0.899	100	70
100	71	257.0	50.8	50.2	0.841	285.2	51.2	50.6	0.847	312.8	51.5	50.9	0.852	100	71
100	72	270.6	51.0	50.4	0.797	300.0	51.4	50.8	0.802	328.8	51.8	51.2	0.807	100	72
100	73	285.0	51.2	50.6	0.756	315.9	51.6	51.0	0.760	346.0	52.0	51.4	0.765	100	73
100	74	300.1	51.3	50.8	0.717	332.5	51.8	51.2	0.721	364.1	52.2	51.6	0.725	100	74
100	75	315.9	51.4	50.9	0.681	349.9	51.9	51.4	0.684	383.0	52.3	51.8	0.688	100	75
100	76	332.3	51.4	51.0	0.647	368.1	52.0	51.5	0.651	402.9	52.5	52.0	0.654	100	76
100	77	349.1	51.5	51.1	0.616	386.8	52.1	51.6	0.619	423.4	52.6	52.1	0.622	100	77
100	78	366.3	51.6	51.2	0.588	405.9	52.1	51.8	0.590	444.4	52.7	52.3	0.592	100	78
100	79	383.9	51.7	51.4	0.561	425.5	52.2	51.9	0.562	465.9	52.8	52.4	0.564	100	79
100	80	401.9	51.7	51.5	0.536	445.5	52.3	52.1	0.537	487.9	52.9	52.6	0.538	100	80
100	81	420.3	51.8	51.6	0.512	466.0	52.4	52.2	0.513	510.4	53.0	52.8	0.514	100	81
100	82	439.2	51.9	51.8	0.490	486.9	52.5	52.4	0.491	533.5	53.1	52.9	0.492	100	82
100	83	458.5	52.0	51.9	0.470	508.4	52.7	52.5	0.470	557.1	53.3	53.1	0.470	100	83
100	84	478.2	52.1	52.1	0.450	530.4	52.8	52.7	0.450	581.2	53.4	53.3	0.450	100	84
100	85	498.5	52.2	52.2	0.432	552.9	52.9	52.9	0.432	605.9	53.5	53.5	0.432	100	85
100	86	519.2	52.4	52.4	0.414	575.9	53.1	53.1	0.414	631.2	53.7	53.7	0.414	100	86
100	87	540.4	52.5	52.5	0.397	599.5	53.3	53.3	0.397	657.1	53.9	53.9	0.396	100	87
100	88	562.2	52.7	52.7	0.381	623.7	53.5	53.5	0.380	683.7	54.1	54.1	0.380	100	88
100	89	584.5	52.9	52.9	0.366	648.5	53.7	53.7	0.365	710.8	54.4	54.4	0.364	100	89
100	90	607.3	53.1	53.1	0.351	673.8	53.9	53.9	0.350	738.7	54.6	54.6	0.350	100	90
100	91	630.7	53.3	53.3	0.338	699.8	54.1	54.1	0.337	767.2	54.8	54.8	0.336	100	91
100	92	654.7	53.5	53.5	0.325	726.4	54.3	54.3	0.323	796.4	55.1	55.1	0.322	100	92
100	93	679.2	53.7	53.7	0.312	753.7	54.5	54.5	0.311	826.4	55.3	55.3	0.309	100	93
100	94	704.4	53.9	53.9	0.300	781.7	54.8	54.8	0.299	857.0	55.6	55.6	0.297	100	94
100	95	730.2	54.1	54.1	0.289	810.3	55.0	55.0	0.287	888.5	55.9	55.9	0.286	100	95
100	96	756.6	54.4	54.4	0.278	839.7	55.3	55.3	0.276	920.7	56.2	56.2	0.275	100	96
100	97	783.8	54.6	54.6	0.268	869.8	55.6	55.6	0.266	953.7	56.5	56.5	0.264	100	97
105	71	260.1	50.6	49.8	0.918	289.3	50.9	50.1	0.924	318.1	51.2	50.4	0.928	105	71
105	72	272.7	50.9	50.2	0.873	302.9	51.2	50.5	0.878	332.5	51.6	50.8	0.883	105	72
105	73	286.2	51.1	50.4	0.829	317.7	51.5	50.8	0.834	348.4	51.9	51.2	0.839	105	73
105	74	300.7	51.3	50.6	0.788	333.5	51.7	51.1	0.792	365.6	52.1	51.4	0.797	105	74
105	75	315.9	51.4	50.8	0.749	350.2	51.9	51.3	0.753	383.7	52.3	51.7	0.757	105	75
105	76	331.8	51.5	51.0	0.712	367.8	52.0	51.5	0.716	402.8	52.5	51.9	0.720	105	76
105	77	348.3	51.6	51.1	0.679	386.0	52.2	51.6	0.682	422.7	52.7	52.1	0.685	105	77
105	78	365.5	51.7	51.2	0.647	405.0	52.3	51.8	0.650	443.5	52.8	52.3	0.653	105	78
105	79	383.1	51.8	51.3	0.617	424.6	52.4	51.9	0.620	465.0	52.9	52.4	0.622	105	79
105	80	401.1	51.9	51.5	0.590	444.6	52.4	52.0	0.592	487.0	53.0	52.6	0.594	105	80
105	81	419.5	51.9	51.6	0.564	465.1	52.6	52.2	0.566	509.5	53.1	52.7	0.568	105	81
105	82	438.3	52.0	51.7	0.540	486.0	52.7	52.4	0.541	532.5	53.3	52.9	0.543	105	82
105	83	457.6	52.1	51.9	0.517	507.5	52.8	52.5	0.518	556.0	53.4	53.1	0.519	105	83
105	84	477.4	52.2	52.0	0.496	529.4	52.9	52.7	0.497	580.2	53.5	53.3	0.497	105	84
105	85	497.6	52.3	52.2	0.476	551.9	53.0	52.9	0.476	604.9	53.7	53.5	0.477	105	85
105	86	518.3	52.4	52.4	0.457	574.9	53.1	53.0	0.457	630.1	53.8	53.7	0.457	105	86
105	87	539.5	52.5	52.5	0.439	598.5	53.3	53.2	0.439	656.0	54.0	53.9	0.439	105	87
105	88	561.3	52.7	52.7	0.421	622.7	53.4	53.4	0.421	682.5	54.1	54.1	0.421	105	88
105	89	583.5	52.9	52.9	0.405	647.4	53.6	53.6	0.404	709.7	54.3	54.3	0.404	105	89
105	90	606.3	53.1	53.1	0.389	672.8	53.8	53.8	0.388	737.5	54.6	54.6	0.388	105	90
105	91	629.7	53.3	53.3	0.374	698.7	54.1	54.1	0.373	766.0	54.8	54.8	0.373	105	91
105	92	653.7	53.5	53.5	0.360	725.4	54.3	54.3	0.359	795.2	55.1	55.1	0.358	105	92
105	93	678.2	53.7	53.7	0.346	752.6	54.5	54.5	0.345	825.2	55.3	55.3	0.344	105	93
105	94	703.4	53.9	53.9	0.333	780.6	54.8	54.8	0.332	855.8	55.6	55.6	0.331	105	94
105	95	729.2	54.1	54.1	0.321	809.2	55.0	55.0	0.319	887.2	55.9	55.9	0.318	105	95
105	96	755.6	54.3	54.3	0.309	838.5	55.3	55.3	0.307	919.4	56.1	56.1	0.306	105	96
105	97	782.7	54.6	54.6	0.297	868.6	55.5	55.5	0.296	952.4	56.4	56.4	0.294	105	97
105	98	810.5	54.8	54.8	0.287	899.5	55.8	55.8	0.285	986.2	56.7	56.7	0.283	105	98
105	99	839.0	55.1	55.1	0.276	931.1	56.1	56.1	0.274	1020.9	57.1	57.1	0.273	105	99
105	100	868.2	55.4	55.4	0.266	963.5	56.4	56.4	0.264	1056.4	57.4	57.4	0.262	105	100
105	101	898.1	55.6	55.6	0.257	996.7	56.7	56.7	0.254	1092.9	57.7	57.7	0.253	105	101
105	102	928.8	55.9	55.9	0.247	1030.8	57.0	57.0	0.245	1130.2	58.1	58.1	0.243	105	102

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART Coil Size: DW 68
Entering Water = 45 Leaving Water = 51.67

AIR TEMP. (F)		AIRFLOW 5500 CFM (FPM = 550)				AIR TEMP. (F)	
EDB	EWB	MBH	LDB	LWB	SHR	EDB	EWB
75	59	151.2	49.9	48.7	1.000	75	59
75	60	157.5	49.8	49.5	0.962	75	60
75	61	166.6	50.4	50.0	0.890	75	61
75	62	178.3	50.8	50.5	0.820	75	62
75	63	192.0	51.1	50.8	0.754	75	63
75	64	207.4	51.2	51.0	0.693	75	64
75	65	224.1	51.3	51.1	0.640	75	65
75	66	241.9	51.4	51.2	0.592	75	66
75	67	260.1	51.5	51.3	0.550	75	67
75	68	278.7	51.5	51.4	0.512	75	68
75	69	297.6	51.6	51.6	0.479	75	69
75	70	316.9	51.7	51.7	0.449	75	70
75	71	336.6	51.8	51.8	0.421	75	71
75	72	356.7	51.9	51.9	0.396	75	72
80	61	180.2	50.1	49.0	1.000	80	61
80	62	188.8	50.1	49.6	0.954	80	62
80	63	199.1	50.6	50.2	0.890	80	63
80	64	211.8	51.0	50.6	0.827	80	64
80	65	226.3	51.3	50.9	0.768	80	65
80	66	242.3	51.5	51.1	0.713	80	66
80	67	259.5	51.6	51.3	0.664	80	67
80	68	277.8	51.7	51.4	0.619	80	68
80	69	296.7	51.7	51.5	0.579	80	69
80	70	316.0	51.8	51.7	0.543	80	70
80	71	335.7	51.9	51.8	0.510	80	71
80	72	355.8	52.0	51.9	0.480	80	72
80	73	376.3	52.1	52.1	0.453	80	73
80	74	397.3	52.2	52.2	0.428	80	74
80	75	418.8	52.4	52.4	0.405	80	75
80	76	440.7	52.5	52.5	0.383	80	76
80	77	463.1	52.7	52.7	0.363	80	77
85	63	209.1	50.3	49.4	1.000	85	63
85	64	220.9	50.4	49.9	0.944	85	64
85	65	232.5	50.9	50.4	0.886	85	65
85	66	246.2	51.2	50.8	0.829	85	66
85	67	261.6	51.5	51.1	0.775	85	67
85	68	278.4	51.7	51.3	0.725	85	68
85	69	296.2	51.8	51.5	0.679	85	69
85	70	315.1	52.0	51.6	0.637	85	70
85	71	334.8	52.0	51.8	0.599	85	71
85	72	354.9	52.1	51.9	0.564	85	72
85	73	375.4	52.2	52.0	0.533	85	73
85	74	396.4	52.3	52.2	0.504	85	74
85	75	417.8	52.4	52.3	0.477	85	75
85	76	439.7	52.5	52.5	0.453	85	76
85	77	462.1	52.7	52.7	0.430	85	77
85	78	485.1	52.8	52.8	0.408	85	78
85	79	508.5	53.0	53.0	0.388	85	79
85	80	532.5	53.2	53.2	0.369	85	80
85	81	557.0	53.4	53.4	0.351	85	81
85	82	582.1	53.6	53.6	0.335	85	82

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART Coil Size: DW 68
Entering Water = 45 Leaving Water = 51.67

EDB	EWB	AIRFLOW 5500 CFM (FPM = 550)				AIR TEMP. (F)	
		MBH	LDB	LWB	SHR	EDB	EWB
90	65	243.7	50.1	49.5	0.985	90	65
90	66	254.0	50.7	50.1	0.932	90	66
90	67	267.0	51.2	50.6	0.878	90	67
90	68	281.8	51.5	51.0	0.826	90	68
90	69	298.1	51.8	51.3	0.776	90	69
90	70	315.7	52.0	51.5	0.730	90	70
90	71	334.4	52.1	51.7	0.688	90	71
90	72	354.0	52.3	51.9	0.648	90	72
90	73	374.5	52.4	52.0	0.612	90	73
90	74	395.5	52.5	52.2	0.579	90	74
90	75	416.9	52.6	52.3	0.549	90	75
90	76	438.8	52.7	52.5	0.521	90	76
90	77	461.2	52.8	52.6	0.495	90	77
90	78	484.0	52.9	52.8	0.470	90	78
90	79	507.5	53.0	53.0	0.448	90	79
90	80	531.4	53.2	53.2	0.427	90	80
90	81	555.9	53.3	53.3	0.407	90	81
90	82	581.0	53.5	53.5	0.388	90	82
90	83	606.7	53.7	53.7	0.370	90	83
90	84	633.0	54.0	54.0	0.353	90	84
90	85	659.9	54.2	54.2	0.338	90	85
90	86	687.5	54.4	54.4	0.323	90	86
90	87	715.7	54.6	54.6	0.309	90	87
95	67	276.4	50.6	49.9	0.969	95	67
95	68	288.4	51.1	50.4	0.918	95	68
95	69	302.7	51.5	50.9	0.868	95	69
95	70	318.7	51.8	51.2	0.820	95	70
95	71	336.0	52.1	51.5	0.774	95	71
95	72	354.5	52.3	51.8	0.731	95	72
95	73	374.0	52.4	52.0	0.691	95	73
95	74	394.5	52.6	52.1	0.654	95	74
95	75	415.9	52.7	52.3	0.620	95	75
95	76	437.8	52.8	52.4	0.589	95	76
95	77	460.2	52.9	52.6	0.559	95	77
95	78	483.0	53.0	52.8	0.532	95	78
95	79	506.4	53.2	53.0	0.507	95	79
95	80	530.4	53.3	53.1	0.483	95	80
95	81	554.9	53.4	53.3	0.461	95	81
95	82	579.9	53.6	53.5	0.441	95	82
95	83	605.6	53.7	53.7	0.421	95	83
95	84	631.9	53.9	53.9	0.403	95	84
95	85	658.8	54.1	54.1	0.385	95	85
95	86	686.3	54.4	54.4	0.368	95	86
95	87	714.5	54.6	54.6	0.352	95	87
95	88	743.3	54.8	54.8	0.337	95	88
95	89	772.9	55.1	55.1	0.323	95	89
95	90	803.2	55.3	55.3	0.310	95	90
95	91	834.2	55.6	55.6	0.297	95	91
95	92	866.0	55.9	55.9	0.285	95	92

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX A

DW COIL PERFORMANCE CHART Coil Size: DW 68
Entering Water = 45 Leaving Water = 51.67

EDB	EWB	AIRFLOW			SHR	AIR TEMP	
		MBH	LDB	LWB		EDB	EWB
100	69	310 5	51 0	50 2	0 951	100	69
100	70	324 2	51 5	50 8	0 904	100	70
100	71	339 8	51 9	51 2	0 857	100	71
100	72	357 0	52 2	51 5	0 811	100	72
100	73	375 4	52 4	51 8	0 769	100	73
100	74	394 9	52 6	52 0	0 729	100	74
100	75	415 4	52 8	52 2	0 692	100	75
100	76	436 8	52 9	52 4	0 657	100	76
100	77	459 2	53 0	52 6	0 624	100	77
100	78	482 0	53 2	52 8	0 594	100	78
100	79	505 4	53 3	52 9	0 566	100	79
100	80	529 3	53 4	53 1	0 540	100	80
100	81	553 8	53 5	53 3	0 515	100	81
100	82	578 9	53 7	53 5	0 492	100	82
100	83	604 5	53 8	53 7	0 471	100	83
100	84	630 8	54 0	53 9	0 451	100	84
100	85	657 6	54 1	54 1	0 432	100	85
100	86	685 1	54 3	54 3	0 413	100	86
100	87	713 3	54 6	54 6	0 396	100	87
100	88	742 1	54 8	54 8	0 379	100	88
100	89	771 7	55 0	55 0	0 364	100	89
100	90	802 0	55 3	55 3	0 349	100	90
100	91	832 9	55 6	55 6	0 335	100	91
100	92	864 7	55 8	55 8	0 321	100	92
100	93	897 2	56 1	56 1	0 308	100	93
100	94	930 5	56 4	56 4	0 296	100	94
100	95	964 7	56 7	56 7	0 284	100	95
100	96	999 7	57 0	57 0	0 273	100	96
100	97	1035 5	57 3	57 3	0 262	100	97
105	71	346 4	51 4	50 6	0 933	105	71
105	72	361 6	51 9	51 1	0 888	105	72
105	73	378 6	52 2	51 5	0 844	105	73
105	74	397 0	52 5	51 8	0 801	105	74
105	75	416 5	52 7	52 1	0 762	105	75
105	76	437 0	53 0	52 3	0 724	105	76
105	77	458 5	53 1	52 5	0 689	105	77
105	78	481 0	53 3	52 7	0 656	105	78
105	79	504 4	53 4	52 9	0 625	105	79
105	80	528 3	53 5	53 1	0 596	105	80
105	81	552 8	53 7	53 3	0 569	105	81
105	82	577 8	53 8	53 5	0 544	105	82
105	83	603 4	54 0	53 7	0 521	105	83
105	84	629 6	54 1	53 9	0 498	105	84
105	85	656 5	54 3	54 1	0 477	105	85
105	86	684 0	54 4	54 3	0 458	105	86
105	87	712 1	54 6	54 5	0 439	105	87
105	88	741 0	54 8	54 8	0 421	105	88
105	89	770 5	55 0	55 0	0 404	105	89
105	90	800 7	55 3	55 3	0 388	105	90
105	91	831 7	55 5	55 5	0 372	105	91
105	92	863 4	55 8	55 8	0 357	105	92
105	93	895 9	56 1	56 1	0 343	105	93
105	94	929 3	56 4	56 4	0 330	105	94
105	95	963 4	56 7	56 7	0 317	105	95
105	96	998 3	57 0	57 0	0 305	105	96
105	97	1034 2	57 3	57 3	0 293	105	97
105	98	1070 9	57 6	57 6	0 282	105	98
105	99	1108 5	58 0	58 0	0 271	105	99
105	100	1147 1	58 3	58 3	0 261	105	100
105	101	1186 7	58 7	58 7	0 251	105	101
105	102	1227 2	59 0	59 0	0 241	105	102

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX B DELETED

ENGINEERING DRAWINGS TECHNICAL CONTENT REQUIREMENTS

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX C
OPERATING LIFE

C.1 SCOPE

C.1.1 Scope. This appendix covers the information and procedures necessary to ensure that the reliability requirements of this specification are met. This appendix is a mandatory part of the specification. The information contained herein is intended for compliance.

C.2 APPLICABLE DOCUMENTS

This section is not applicable to this appendix.

C.3 OPERATING LIFE DATA

C.3.1 Operating life analysis. Operating life analysis shall be performed by manufacturers to determine that the equipment meets the requirements of 3.7. The manufacturers' record data shall indicate the degree of conformance to ILS requirements. The reliability analysis shall include:

- a. A list of parts, which according to experience and judgment, are subject to wear, material deterioration, and service failures.
- b. Design features employed to attain the required service life of the parts, with consideration to shipboard environmental and resultant conditions. Design features include: choice of materials, compatibility of materials, repairability and accessibility, hardness, surface finishes, fits and clearances, corrosion control, equipment protection fail-safe features, internal and external operating temperatures, and suitability of the materials at these temperatures.
- c. Preventive maintenance and servicing requirements necessary for the achievement of reliable equipment. Any unusual steps or precautions necessary in carrying out maintenance and servicing requirements shall be pointed out.

C.3.2 Failure reporting, analysis, and feedback. DELETED.

MIL-PRF-2939G(SH)
w/AMENDMENT 2

APPENDIX D
TEST REPORT TECHNICAL CONTENT REQUIREMENT

D.1 SCOPE

D.1.1 Scope. This appendix covers the technical content requirements that should be included in the test report when required by the contract or order. This appendix is not mandatory and is provided for informational purposes only.

D.2. APPLICABLE DOCUMENTS

This section is not applicable to this appendix.

D.3. REPORTS

D.3.1 Test reports. When required by contract or order, test reports should contain the following information.

- a. Results of qualification tests (see 4.2).
- b. Results of quality conformance tests (see 4.3).
- c. Results of shock test (see 4.6.9) with the following unique features:
 - 1. Drawing number identification of cooling coil assembly.
 - 2. Photographs of the cooling coil assembly in each test mounting.
- d. Results of Type I vibration test (see 4.6.8).
- e. Results of capacity test (see 4.6.5).

MIL-PRF-2939G(SH)
w/AMENDMENT 2

Custodian:
Navy – SH

Preparing activity:
Navy – SH
(Project 4130-2014-001)

Review activity:
DLA – IS

NOTE: The activities listed above were interested in this document as of the date of this document. Since organizations and responsibilities can change, you should verify the currency of the information above using the ASSIST Online database at <https://assist.dla.mil>.