

INCH-POUND

MIL-E-24269B(SH)
AMENDMENT 1
8 October 1990

MILITARY SPECIFICATION

**EXTINGUISHER, FIRE, CARBON DIOXIDE, 15 POUND,
PORTABLE, PERMANENT SHUTOFF,
NAVY SHIPBOARD USE**

This amendment forms a part of MIL-E-24269B(SH), dated 14 June 1988, and is approved for use by the Naval Sea Systems Command, Department of the Navy and is available for use by all Departments and Agencies of the Department of Defense.

PAGE 1

1.2: Delete and substitute:

"1.2 Classification. The fire extinguishers covered by this specification shall be of the following classes, as specified (see 6.2.1):

- Class 1 - Alloy steel
- Class 2 - Aluminum
- Class 3 - Stainless steel"

PAGE 4

3.1: Delete and substitute:

" 3.1 First article. When specified (see 6.2.1), a sample shall be subjected to first article inspection (see 6.3) in accordance with 4.4."

AMSC N/A

FSC 4210

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

MIL-E-24269B(SH)
AMENDMENT 1

3.3, Last sentence, delete and substitute:

"The class 2 extinguishers shall be listed as marine type by ANSI/UL in accordance with ANSI/UL 154."

PAGE 7

3.5.3: Delete and substitute:

"3.5.3 Discharge hose assembly. The overall length of the discharge hose shall be 37 ± 2 inches."

3.5.3.3, Second sentence, delete and substitute:

"The discharge horn shall be fabricated of temperature, electric, and water-resistant material having 1/4-18 NPT (for classes 1 and 3) internal or 1/4-18 NPT (for class 2) external thread bronze or brass connection molded or otherwise secured to the horn for attaching the handle."

PAGE 8

3.5.5: Delete and substitute:

"3.5.5 Mounting bracket. Unless otherwise specified (see 6.2.1), a mounting bracket shall be provided. The mounting bracket shall be a heavy duty vehicle type. The bracket shall also be adjustable to retain cylinders at the diameter range specified in 3.5.1."

PAGE 9

3.7.1, Add to the end of paragraph title, "(classes 1 and 3)".

PAGE 10

3.7.3: Add as new paragraph.

"3.7.3 Nameplate (class 2). A nameplate and other markings on class 2 extinguishers shall be provided as specified on ANSI/UL 154."

MIL-E-24269B(SH)
AMENDMENT 1

3.7.4: Add as new paragraph.

"3.7.4 Weight information. The empty weight of the extinguisher (cylinder and valve) shall be stamped on the cylinder dome i.e. curvature area. The marking shall be "WT" followed by the numerical weight to nearest tenth of a pound. For example, a empty extinguisher that weighs 34.5 pounds should be marked "WT 34.5". The letter size shall be 1/4 inch."

3.8: Delete in its entirety.

3.9: Delete and substitute:

"3.9 Drawings. (see 6.2.2)."

4.3: Delete in its entirety.

PAGE 11

4.4, Delete last sentence.

PAGE 16

6., Below "NOTES", add the following:

"(This section contains information of a general or explanatory nature that may be helpful, but is not mandatory.)"

PAGE 17

6.2.2: Delete and substitute:

"6.2.2 Consideration of data requirements. The following data requirements should be considered when this specification is applied on a contract. The applicable Data Item Descriptions (DID's) should be reviewed in conjunction with the specific acquisition to ensure that only essential data are requested/provided and that the DID's are tailored to reflect the requirements of the specific acquisition. To ensure correct contractual application of the data requirements, a Contract Data Requirements List (DD Form 1423) must be prepared to obtain the data, except where DOD FAR Supplement 27.475-1 exempts the requirement for a DD Form 1423.

MIL-E-24269B(SH)
AMENDMENT 1

<u>Reference Paragraph</u>	<u>DID Number</u>	<u>DID Title</u>	<u>Suggested Tailoring</u>
3.9	DI-DRPR-81102	Developmental Design Drawings and Associated Lists	- - - -
4.5.3	DI-T-2072	Reports, tests	- - - -

The above DID's were those cleared as of the date of this specification. The current issue of DoD 5010.12-L, Acquisition Management Systems and Data Requirement Control List (AMSDL), must be researched to ensure that only current, cleared DID's are cited on the DD Form 1423."

6.2.2.1: Delete in its entirety.

6.2.3: Add as new paragraph:

"6.2.3 Technical manuals. The requirement for technical manuals should be considered when this specification is applied on a contract. If technical manuals are required, military specifications and standards that have been cleared and listed on DoD 5010.12-L, Acquisition Management Systems and Data Requirements Control List (AMSDL) must be listed on a separate Contract Data Requirements List (DD Form 1423), which is included as an exhibit to the contract. The technical manuals must be acquired under separate contract line item in the contract."

Preparing activity:
Navy - SH
(Project 4210-N426)