

MIL-I-2781E
INTERIM AMENDMENT-1(SH)
4 November 1977

MILITARY SPECIFICATION

INSULATION, PIPE, THERMAL

This Interim Amendment is issued for use by the Department of the Navy, Naval Ship Engineering Center, with Military Specification MIL-I-2781E, dated 7 October 1975.

PAGE 4

3.7, add as last sentence: "Drying time for each cement after application shall not exceed two hours."

PAGE 7

4.5.9, line 2: Delete "1/4-inch layer" and substitute: "1/8-inch layer".

Preparing activity:
Navy - SH
(Project 5640-NO48)

FSC 5640