

NOTICE.—When Government drawings, specifications, or other data are used for any purpose other than in connection with a definitely related Government procurement operation, the United States Government thereby incurs no responsibility, nor any obligation whatsoever, and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data is not to be regarded by implication or otherwise as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use, or sell any patented invention that may in any way be related thereto.

This military standard is approved by the Department of Defense and is mandatory on all activities. Selection for all new engineering and design applications and for repetitive use shall be made from this document.

FED. SUP CLASS  
5315



DASH NO.	INSIDE WIDTH	INSIDE LENGTH	WIRE THICKNESS (Min.)	WIRE WIDTH (Min.)	TYPE CABLE
-1	9/16	1 1/8	.055	15/64	Non-Metallic Sheathed
-2	9/16	1 3/8	.055	15/64	Regular Armored
-3	9/16	1 1/2	.075	9/32	Heavy Armored

1. Cable staples shall be of flat (rectangular) zinc-coated steel wire.
2. For use on armored and nonmetallic-sheathed electrical cable, as indicated.
3. Inside width dimension is equivalent to inside shoulder spread.
4. Dimensions are in inches.
5. For design feature purposes, this standard takes precedence over procurement documents referenced herein.
6. Referenced documents shall be of the issue in effect on date of invitation for bid.
7. The MS part number consists of the MS number plus the dash number.

APPROVED 18 DEC-1962 REVISED

P.A. DOCKS	TITLE	MILITARY STANDARD
Other Cust CE MOA	STAPLES, CABLE; ELECTRICIAN'S	MS 90719
Procurement Specification	SUPERSEDES:	SHEET 1 OF 1